

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Linn
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B

Month/Year: 2/2023

DAY	12 AM	4 AM	8 AM	NOON	4 PM	8 PM	Highest Reading of the Day (1)
	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]
1	0.01	0.01	0.01	0.01	0.01	0.01	0.01
2	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3	0.01	0.01	0.01	0.01	0.01	0.01	0.01
4	0.01	0.01	0.01	0.01	0.01	0.01	0.01
5	0.01	0.01	0.01	0.01	0.01	0.01	0.01
6	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7	0.01	0.01	0.01	0.01	0.01	0.01	0.01
8	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9	0.01	0.01	0.01	0.01	0.01	0.01	0.01
10	0.01	0.01	0.01	0.01	0.01	0.01	0.01
11	0.01	0.01	0.01	0.01	0.01	0.01	0.01
12	0.01	0.01	0.01	0.01	0.01	0.01	0.01
13	0.01	0.01	0.01	0.01	0.01	0.01	0.01
14	0.01	0.01	0.01	0.01	0.01	0.01	0.01
15	0.01	0.01	0.01	0.01	0.01	0.01	0.01
16	0.01	0.01	0.01	0.01	0.01	0.01	0.01
17	0.01	0.01	0.01	0.01	0.01	0.01	0.01
18	0.01	0.01	0.01	0.01	0.01	0.01	0.01
19	0.01	0.01	0.01	0.01	0.01	0.01	0.01
20	0.01	0.01	0.01	0.01	0.01	0.01	0.01
21	0.01	0.01	0.01	0.01	0.01	0.01	0.01
22	0.01	0.01	0.01	0.01	0.01	0.01	0.01
23	0.01	0.01	0.01	0.01	0.01	0.01	0.01
24	0.01	0.01	0.01	0.01	0.01	0.01	0.01
25	0.01	0.01	0.01	0.01	0.01	0.01	0.01
26	0.01	0.01	0.01	0.01	0.01	0.01	0.01
27	0.01	0.01	0.01	0.01	0.01	0.01	0.01
28	0.01	0.01	0.01	0.01	0.01	0.01	0.01


Membrane Filtration		Monthly Summary (Answer Yes or No)	
95% of turbidity readings <= 1 NTU? (2)	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday?	All CL2 residuals at entry point >= 0.2 mg/l?
All daily turbidity readings <= 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes:	PRINTED NAME: <i>Scott LaRogue</i>		
	SIGNATURE: <i>[Signature]</i>		DATE: <i>3/10/23</i>
	PHONE #: <i>541 791 0175</i>		CERT #: <i>T-9188</i>

(1) Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. (2) Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B	Month/Year: 2/2023
---	--------------------

Date / Time	Minimum CL2 Residual @ 1st User (C) (1)	Contact Time (T)	Actual CT	Temp.	pH	Reqd. CT	CT Met? (1)	Peak Hourly Demand Flow (2)
	[ppm or mg/L]	[minutes]	C x T	[°C]		Use tables	Yes / No	[GPM]
1	1.06	249.2	264.2	3.9	8.32	47.3	Y	5,731
2	0.98	250.3	245.3	4.2	8.36	46.5	Y	6,003
3	1.08	193.3	208.8	4.7	8.38	45.7	Y	5,792
4	0.78	212.2	165.5	5.8	8.47	42.1	Y	6,095
5	1.05	229.6	241.1	6.5	8.38	40.3	Y	5,980
6	0.93	186.7	173.6	6.7	8.48	40.6	Y	6,747
7	0.83	167.4	138.9	6.6	8.37	38.8	Y	8,020
8	1.10	178.0	195.8	5.9	8.36	41.8	Y	8,692
9	0.92	199.0	183.1	6.0	8.21	38.6	Y	6,647
10	0.82	506.1	415.0	6.5	8.20	36.6	Y	6,669
11	1.03	530.6	546.5	6.5	8.23	38.0	Y	7,717
12	1.21	530.6	642.0	6.0	8.16	39.1	Y	8,339
13	1.13	530.6	599.6	6.6	8.22	38.2	Y	7,626
14	1.06	530.6	562.4	5.9	8.23	39.8	Y	5,686
15	1.00	530.6	530.6	4.8	8.32	44.1	Y	6,257
16	0.95	530.6	504.1	4.8	8.33	44.1	Y	7,248
17	0.67	530.6	355.5	4.9	8.33	42.3	Y	7,735
18	0.70	530.6	371.4	5.6	8.23	38.9	Y	6,639
19	1.11	530.6	589.0	6.5	8.40	41.1	Y	6,717
20	0.98	530.6	520.0	7.2	8.48	39.4	Y	6,432
21	0.96	530.6	509.4	7.3	8.37	37.5	Y	6,746
22	1.09	530.6	578.4	5.7	8.33	42.0	Y	7,710
23	1.01	530.6	535.9	4.9	8.30	43.5	Y	6,926
24	0.91	530.6	482.8	4.0	8.31	46.1	Y	7,376
25	0.89	530.6	472.2	3.7	10.11	92.0	Y	7,706
26	0.94	530.6	498.8	4.7	8.21	42.2	Y	7,342
27	1.12	530.6	594.3	5.2	8.21	41.9	Y	7,779
28	1.04	530.6	551.8	5.3	8.15	40.0	Y	6,845

Signature: <u></u>	Date: <u>3/10/23</u>
Print Name: <u>Scott LaRoque</u>	Cert #: <u>T-9188</u>

(1) If Cl2 at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.
 (2) Prior to 11/2014, Peak Instantaneous Demand Flow is used.

Department of Human Services - Drinking Water Section

Membrane Integrity Report Form

Public Water System Name: Albany

PWS ID#: 41 00012 B

Month/Year:

2/ 2023

Albany/Millersburg Water Plant

Date	Membrane 1	Membrane 2	Membrane 3	Membrane 4
02/01/23	Pass	Pass	Pass	Pass
02/02/23	Pass	Pass	Pass	Pass
02/03/23	Pass	Pass	Pass	Pass
02/04/23	Pass	Pass	Pass	Pass
02/05/23	Pass	Pass	Pass	Pass
02/06/23	Pass	Pass	Pass	Pass
02/07/23	Pass	Pass	Pass	Pass
02/08/23	Pass	Pass	Pass	Pass
02/09/23	Pass	Pass	Pass	Pass
02/10/23	Pass	Pass	Pass	Pass
02/11/23	Pass	Pass	Pass	Pass
02/12/23	Pass	Pass	Pass	Pass
02/13/23	Pass	Pass	Pass	Pass
02/14/23	Pass	Pass	Pass	Pass
02/15/23	Pass	Pass	Pass	Pass
02/16/23	Pass	Pass	Pass	Pass
02/17/23	Pass	Pass	Pass	Pass
02/18/23	Pass	Pass	Pass	Pass
02/19/23	Pass	Pass	Pass	Pass
02/20/23	Pass	Pass	Pass	Pass
02/21/23	Pass	Pass	Pass	Pass
02/22/23	Pass	Pass	Pass	Pass
02/23/23	Pass	Pass	Pass	Pass
02/24/23	Pass	Pass	Pass	Pass
02/25/23	Pass	Pass	Pass	Pass
02/26/23	Pass	Pass	Pass	Pass
02/27/23	Pass	Pass	Pass	Pass
02/28/23	Pass	Pass	Pass	Pass

Signature: 

Date: 3/10/23

Print Name: Scott LaRoque

Cert. #: T-9188