

**OHA - Drinking Water Program - Turbidity Monitoring Report Form    County: Linn**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: ALBANY, CITY OF    ID #: OR4100012    WTP:-WTP-B

Month/Year: 3/2023

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day (1) [NTU]
1	0.01	0.01	0.01	0.01	0.01	0.01	0.01
2	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3	0.01	0.01	0.01	0.01	0.01	0.01	0.01
4	0.01	0.01	0.01	0.01	0.01	0.01	0.01
5	0.01	0.01	0.01	0.01	0.01	0.01	0.01
6	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7	0.01	0.01	0.01	0.01	0.01	0.01	0.01
8	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9	0.01	0.01	0.01	0.01	0.01	0.01	0.01
10	0.01	0.01	0.01	0.01	0.01	0.01	0.01
11	0.02	0.01	0.01	0.01	0.01	0.01	0.02
12	0.01	0.01	0.01	0.01	0.01	0.01	0.01
13	0.01	0.01	0.01	0.01	0.01	0.01	0.01
14	0.01	0.01	0.01	0.01	0.02	0.02	0.02
15	0.01	0.01	Plant Off	Plant Off	Plant Off	0.02	0.02
16	0.02	0.02	0.03	0.02	0.02	0.02	0.03
17	0.13	0.01	0.02	0.02	0.02	0.03	0.13
18	0.02	0.02	0.02	0.02	0.02	0.02	0.02
19	0.02	0.02	0.02	0.02	0.02	0.02	0.02
20	0.01	0.02	0.01	0.02	0.01	0.01	0.02
21	0.01	0.01	0.02	0.01	0.03	0.01	0.03
22	0.02	0.02	0.02	0.02	0.02	0.02	0.02
23	0.02	0.02	0.02	0.02	0.02	0.07	0.07
24	0.01	0.01	0.01	0.02	0.01	0.01	0.02
25	0.01	0.02	0.01	0.02	0.02	0.02	0.02
26	0.01	0.01	0.01	0.02	0.01	0.02	0.02
27	0.02	0.02	0.02	0.02	0.01	0.02	0.02
28	0.02	0.01	0.01	0.01	0.02	0.02	0.02
29	0.02	0.02	0.01	0.01	0.01	0.01	0.02
30	0.02	0.01	0.01	0.01	0.01	0.01	0.02
31	0.01	0.01	0.01	0.01	0.01	0.01	0.01


Membrane Filtration	Monthly Summary (Answer Yes or No)	
95% of turbidity readings <= 1 NTU? (2) <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? <input checked="" type="radio"/> Yes / <input type="radio"/> No	All CL2 residuals at entry point >= 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings <= 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
<b>Notes:</b>	PRINTED NAME: <i>Scott LaRoque</i>	
	SIGNATURE: <i>[Signature]</i>	DATE: <i>4/7/23</i>
	PHONE #: <i>541-791-0175</i>	CERT #: <i>T-9188</i>

(1) Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. (2) Filtered systems only.

## OHA - Drinking Water Program - Surface Water Quality Data Form

**System Name: ALBANY, CITY OF ID #: OR4100012 WTP::WTP-B Month/Year: 3/2023**

Date / Time	Minimum CL2 Residual @ 1st User (C) (1)	Contact Time (T)	Actual CT	Temp.	pH	Reqd. CT	CT Met? (1)	Peak Hourly Demand Flow (2)
	[ppm or mg/L]	[minutes]	C x T	[°C]		Use tables	Yes / No	[GPM]
1	0.98	163.0	159.7	5.3	8.10	39.2	Y	7,587
2	0.89	187.0	166.4	6.1	8.16	37.5	Y	7,990
3	0.92	198.0	182.2	5.7	8.07	37.4	Y	6,609
4	1.17	166.0	194.2	6.0	8.14	38.7	Y	7,968
5	1.06	176.0	186.6	5.7	8.07	38.0	Y	7,134
6	1.05	192.0	201.6	5.6	8.14	39.3	Y	7,337
7	1.01	208.0	210.1	6.4	8.21	38.0	Y	7,651
8	1.02	184.0	187.7	6.0	8.10	37.6	Y	7,048
9	0.98	221.0	216.6	6.3	8.13	37.1	Y	6,428
10	1.06	201.0	213.1	6.0	8.14	38.3	Y	7,229
11	0.89	207.0	184.2	6.2	8.14	37.0	Y	7,970
12	0.94	186.0	174.8	7.0	8.17	35.7	Y	7,300
13	1.00	176.0	176.0	7.3	8.83	44.6	Y	7,300
14	0.89	186.0	165.5	5.8	8.14	38.1	Y	7,317
15	1.08	264.0	285.1	6.6	8.41	40.6	Y	5,013
16	1.09	188.0	204.9	6.7	8.54	42.2	Y	7,325
17	1.14	190.0	216.6	7.0	8.40	39.6	Y	7,770
18	1.10	203.0	223.3	7.6	8.30	36.5	Y	6,939
19	1.00	195.0	195.0	8.0	8.23	34.1	Y	7,028
20	1.00	169.0	169.0	7.7	8.25	35.1	Y	8,240
21	0.93	160.0	148.8	7.1	8.37	38.0	Y	7,434
22	0.84	181.0	152.0	7.7	8.46	37.3	Y	7,362
23	0.97	176.0	170.7	7.7	8.40	36.9	Y	9,122
24	0.99	187.0	185.1	6.5	8.36	39.8	Y	6,395
25	0.94	210.0	197.4	6.5	8.36	39.6	Y	6,944
26	0.83	195.0	161.9	6.4	8.33	38.7	Y	7,650
27	0.91	184.0	167.4	6.6	8.32	38.4	Y	7,940
28	0.98	184.0	180.3	6.6	8.45	40.6	Y	8,368
29	1.00	199.0	199.0	6.6	8.41	40.2	Y	7,261
30	0.90	192.0	172.8	7.5	8.49	38.4	Y	7,361
31	0.86	192.0	165.1	7.3	8.30	36.2	Y	7,893

Signature:  Date: 4/7/2023  
 Print Name: Scott LaRoque Cert #: T-9188

(1) If Cl2 at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.  
 (2) Prior to 11/2014, Peak Instantaneous Demand Flow is used.

# Department of Human Services - Drinking Water Section

## Membrane Integrity Report Form

Public Water System Name: Albany

PWS ID#: 41 00012 B


Month/Year:

3/ 2023

Albany/Millersburg Water Plant

Date	Membrane 1	Membrane 2	Membrane 3	Membrane 4
03/01/23	Pass	Pass	Pass	Pass
03/02/23	Pass	Pass	Pass	Pass
03/03/23	Pass	Pass	Pass	Pass
03/04/23	Pass	Pass	Pass	Pass
03/05/23	Pass	Pass	Pass	Pass
03/06/23	Pass	Pass	Pass	Pass
03/07/23	Pass	Pass	Pass	Pass
03/08/23	Pass	Pass	Pass	Pass
03/09/23	Pass	Pass	Pass	Pass
03/10/23	Pass	Pass	Pass	Pass
03/11/23	Pass	Pass	Pass	Pass
03/12/23	Pass	Pass	Pass	Pass
03/13/23	Pass	Pass	Pass	Pass
03/14/23	Pass	Pass	Pass	Pass
03/15/23	Pass	Pass	Pass	Pass
03/16/23	Pass	Pass	Pass	Pass
03/17/23	Pass	Pass	Pass	Pass
03/18/23	Pass	Pass	Pass	Pass
03/19/23	Pass	Pass	Pass	Pass
03/20/23	Pass	Pass	Pass	Pass
03/21/23	Pass	Pass	Pass	Pass
03/22/23	Pass	Pass	Pass	Pass
03/23/23	Pass	Pass	Pass	Pass
03/24/23	Pass	Pass	Pass	Pass
03/25/23	Pass	Pass	Pass	Pass
03/26/23	Pass	Pass	Pass	Pass
03/27/23	Pass	Pass	Pass	Pass
03/28/23	Pass	Pass	Pass	Pass
03/29/23	Pass	Pass	Pass	Pass
03/30/23	Pass	Pass	Pass	Pass
03/31/23	Pass	Pass	Pass	Pass

Signature:



Date:

4/7/2023

Print Name:

Scott LaRoque

Cert. #:

T-9188