

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Linn
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B

Month/Year: 4/2023

DAY	12 AM	4 AM	8 AM	NOON	4 PM	8 PM	Highest Reading of the Day (1)
	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]
1	0.01	0.01	0.01	0.01	0.02	0.01	0.02
2	0.01	0.01	0.02	0.01	0.02	0.02	0.02
3	0.01	0.01	0.01	0.01	0.01	0.01	0.01
4	0.01	0.01	0.01	0.01	0.01	0.01	0.01
5	0.01	0.01	0.01	0.02	0.01	0.01	0.02
6	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7	0.01	0.01	0.01	0.01	0.01	0.01	0.01
8	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9	0.01	0.01	0.01	0.01	0.01	0.01	0.01
10	0.01	0.01	0.01	0.01	0.01	0.01	0.01
11	0.01	0.01	0.01	0.01	0.01	0.01	0.01
12	0.01	0.01	0.01	0.01	0.01	0.01	0.01
13	0.01	0.01	0.01	0.01	0.01	0.01	0.01
14	0.01	0.01	0.01	0.01	0.01	0.01	0.01
15	0.01	0.01	0.01	0.01	0.01	0.01	0.01
16	0.01	0.01	0.01	0.01	0.01	0.01	0.01
17	0.01	0.01	0.01	0.01	0.01	0.01	0.01
18	0.01	0.01	0.01	0.01	0.01	0.01	0.01
19	0.01	0.01	0.01	0.01	0.01	0.01	0.01
20	0.01	0.01	0.01	0.01	0.01	0.01	0.01
21	0.01	0.01	0.01	0.01	0.01	0.01	0.01
22	0.01	0.01	0.01	0.01	0.01	0.01	0.01
23	0.01	0.01	0.01	0.01	0.01	0.01	0.01
24	0.01	0.01	0.01	0.01	0.01	0.01	0.01
25	0.01	0.01	0.01	0.01	0.01	0.01	0.01
26	0.02	0.01	0.01	0.01	0.01	0.01	0.02
27	0.02	0.01	0.01	0.01	0.01	0.01	0.02
28	0.02	0.01	0.01	0.01	0.01	0.01	0.02
29	0.02	0.01	0.01	0.01	0.01	0.01	0.02
30	0.02	0.01	0.01	0.01	0.01	0.01	0.02


Membrane Filtration		Monthly Summary (Answer Yes or No)	
95% of turbidity readings <= 1 NTU? (2)	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday?	All CL2 residuals at entry point >= 0.2 mg/l?
All daily turbidity readings <= 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes:		PRINTED NAME: <i>Scott LaRoque</i>	
		SIGNATURE: <i>SCOTT LAROCHE</i>	DATE: 5/10/23
		PHONE #: 541 791 0775	CERT #: T9188

(1) Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. (2) Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: ALBANY, CITY OF ID #: OR4100012 WTP-:WTP-B	Month/Year: 4/2023
---------------------------------------------------------	--------------------

Date / Time	Minimum CL2 Residual @ 1st User (C) (1)	Contact Time (T)	Actual CT	Temp.	pH	Reqd. CT	CT Met? (1)	Peak Hourly Demand Flow (2)
	[ppm or mg/L]	[minutes]	C x T	[°C]		Use tables	Yes / No	[GPM]
1	0.84	181.0	152.0	7.3	8.35	36.8	Y	7,144
2	0.84	205.0	172.2	7.3	8.06	33.0	Y	6,405
3	1.04	214.0	222.6	6.7	8.06	35.4	Y	5,813
4	1.01	179.0	180.8	6.8	8.24	37.2	Y	7,425
5	0.96	205.0	196.8	7.0	8.33	37.8	Y	6,592
6	1.17	204.0	238.7	7.8	8.25	35.7	Y	6,749
7	1.11	223.5	248.1	8.3	8.29	34.6	Y	6,234
8	1.16	220.8	256.1	7.9	8.24	35.2	Y	6,485
9	1.19	204.7	243.6	8.4	8.30	35.0	Y	6,865
10	0.98	184.8	181.1	8.5	8.29	33.6	Y	6,638
11	0.86	158.9	136.7	7.7	8.22	34.1	Y	7,518
12	1.29	181.3	233.9	7.5	8.09	34.9	Y	7,286
13	1.19	205.8	244.9	7.2	8.22	36.7	Y	6,293
14	1.10	212.7	234.0	7.7	8.52	39.4	Y	6,892
15	1.17	207.3	242.5	8.0	8.30	35.8	Y	6,768
16	1.21	211.1	255.4	8.4	8.38	36.1	Y	7,224
17	1.17	193.0	225.8	8.1	8.45	37.6	Y	7,195
18	1.11	212.2	235.5	7.6	8.46	38.8	Y	7,260
19	0.84	206.8	173.7	7.6	8.36	36.1	Y	7,293
20	0.98	206.6	202.5	7.5	8.30	36.4	Y	6,682
21	0.91	212.2	193.1	7.8	8.27	34.8	Y	7,120
22	0.87	225.0	195.8	8.4	8.30	33.6	Y	6,824
23	1.03	179.8	185.2	9.4	8.37	32.8	Y	7,480
24	0.93	226.0	210.2	8.4	8.33	34.2	Y	6,546
25	0.88	209.8	184.6	8.2	8.37	34.9	Y	6,991
26	0.93	163.0	151.6	8.9	8.41	34.2	Y	7,947
27	1.08	206.6	223.1	9.8	8.35	31.9	Y	6,619
28	1.02	187.0	190.7	10.1	8.30	30.5	Y	7,394
29	1.00	184.3	184.3	10.3	8.36	30.7	Y	7,276
30	1.02	195.0	198.9	10.1	8.43	31.8	Y	7,256

Signature: <u></u>	Date: <u>5/10/23</u>
Print Name: <u>SCOTT LAROQUE</u>	Cert #: <u>T9188</u>

(1) If Cl2 at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.
(2) Prior to 11/2014, Peak Instantaneous Demand Flow is used.

Department of Human Services - Drinking Water Section

Membrane Integrity Report Form

Public Water System Name: Albany

PWS ID#: 41 00012 B


Month/Year:

4/ 2023

Albany/Millersburg Water Plant

Date	Membrane 1	Membrane 2	Membrane 3	Membrane 4
04/01/23	Pass	Pass	Pass	Pass
04/02/23	Pass	Pass	Pass	Pass
04/03/23	Pass	Pass	Pass	Pass
04/04/23	Pass	Pass	Pass	Pass
04/05/23	Pass	Pass	Pass	Pass
04/06/23	Pass	Pass	Pass	Pass
04/07/23	Pass	Pass	Pass	Pass
04/08/23	Pass	Pass	Pass	Pass
04/09/23	Pass	Pass	Pass	Pass
04/10/23	Pass	Pass	Pass	Pass
04/11/23	Pass	Pass	Pass	Pass
04/12/23	Pass	Pass	Pass	Pass
04/13/23	Pass	Pass	Pass	Pass
04/14/23	Pass	Pass	Pass	Pass
04/15/23	Pass	Pass	Pass	Pass
04/16/23	Pass	Pass	Pass	Pass
04/17/23	Pass	Pass	Pass	Pass
04/18/23	Pass	Pass	Pass	Pass
04/19/23	Pass	Pass	Pass	Pass
04/20/23	Pass	Pass	Pass	Pass
04/21/23	Pass	Pass	Pass	Pass
04/22/23	Pass	Pass	Pass	Pass
04/23/23	Pass	Pass	Pass	Pass
04/24/23	Pass	Pass	Pass	Pass
04/25/23	Pass	Pass	Pass	Pass
04/26/23	Pass	Pass	Pass	Pass
04/27/23	Pass	Pass	Pass	Pass
04/28/23	Pass	Pass	Pass	Pass
04/29/23	Pass	Pass	Pass	Pass
04/30/23	Pass	Pass	Pass	Pass

Signature: _____



Date: _____

5/10/23

Print Name: _____

Scott LaRoque

Cert. #: _____

T9188