

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Linn
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B

Month/Year: 5/2023

DAY	12 AM	4 AM	8 AM	NOON	4 PM	8 PM	Highest Reading of the Day (1)
	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]
1	0.01	0.01	0.01	0.01	0.01	0.01	0.01
2	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3	0.01	0.01	0.01	0.01	0.01	0.01	0.01
4	0.01	0.01	0.01	0.01	0.01	0.01	0.01
5	0.01	0.01	0.02	0.01	0.01	0.01	0.02
6	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7	0.01	0.01	0.01	0.01	0.01	0.01	0.01
8	0.02	0.02	0.02	0.02	0.02	0.02	0.02
9	0.02	0.02	0.02	Plant Off	0.01	0.01	0.02
10	0.01	0.01	0.01	0.01	0.01	0.01	0.01
11	0.01	0.01	0.01	0.01	0.01	0.01	0.01
12	0.01	0.01	0.01	0.01	0.01	0.01	0.01
13	0.01	0.01	0.01	0.01	0.02	0.01	0.02
14	0.02	0.04	0.01	0.01	0.01	0.01	0.04
15	0.01	0.01	0.01	0.01	0.01	0.01	0.01
16	0.01	0.01	0.01	0.02	0.01	0.02	0.02
17	0.01	0.01	0.01	0.01	0.01	0.01	0.01
18	0.01	0.01	0.01	0.02	0.01	0.01	0.02
19	0.01	0.02	0.02	0.02	0.01	0.01	0.02
20	0.01	0.01	0.01	0.01	0.01	0.01	0.01
21	0.01	0.01	0.02	0.01	0.01	0.01	0.02
22	0.01	0.01	0.01	0.01	0.01	0.01	0.01
23	0.01	0.01	0.01	0.01	0.01	0.01	0.01
24	0.01	0.01	0.01	0.01	0.01	0.01	0.01
25	0.01	0.01	0.01	Plant Off	0.02	0.02	0.02
26	0.01	0.01	0.01	0.01	0.01	0.02	0.02
27	0.02	0.02	0.01	0.02	0.01	0.01	0.02
28	0.01	0.01	0.01	0.01	0.01	0.01	0.01
29	0.01	0.02	0.01	0.01	0.02	0.01	0.02
30	0.01	0.01	0.01	0.02	0.01	0.02	0.02
31	0.01	0.01	0.01	0.01	0.01	0.01	0.01


Membrane Filtration	Monthly Summary (Answer Yes or No)	
95% of turbidity readings <= 1 NTU? (2) <input checked="" type="radio"/> Yes / No	CT's met everyday? <input checked="" type="radio"/> Yes / No	All CL2 residuals at entry point >= 0.2 mg/l? <input checked="" type="radio"/> Yes / No
All daily turbidity readings <= 5 NTU? <input checked="" type="radio"/> Yes / No		
Notes:	PRINTED NAME: <i>Scott LaRoque</i>	
	SIGNATURE: <i>[Signature]</i>	DATE: <i>6/6/23</i>
	PHONE #: <i>541 791 0175</i>	CERT #: <i>T9188</i>

(1) Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. (2) Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B	Month/Year: 5/2023
---	--------------------

Date / Time	Minimum CL2 Residual @ 1st User (C) (1)	Contact Time (T)	Actual CT	Temp.	pH	Reqd. CT	CT Met? (1)	Peak Hourly Demand Flow (2)
	[ppm or mg/L]	[minutes]	C x T	[°C]		Use tables	Yes / No	[GPM]
1	1.05	212.5	223.1	9.6	8.31	31.9	Y	6,289
2	1.03	197.9	203.8	9.5	8.24	31.2	Y	7,353
3	0.96	182.9	175.6	9.7	8.21	30.1	Y	7,519
4	1.05	196.7	206.5	9.7	8.18	30.0	Y	7,431
5	1.09	196.3	214.0	9.6	8.19	30.6	Y	7,306
6	1.17	199.1	232.9	9.6	8.24	31.4	Y	7,697
7	1.15	193.1	222.1	9.6	8.19	30.8	Y	6,848
8	1.13	209.7	237.0	9.8	8.21	30.4	Y	6,904
9	1.17	202.6	237.0	9.4	8.47	34.5	Y	6,635
10	1.06	163.0	172.8	10.1	8.20	29.6	Y	7,851
11	1.11	158.2	175.6	11.1	8.15	27.4	Y	7,779
12	0.89	164.8	146.7	11.4	8.15	26.1	Y	7,990
13	1.07	168.6	180.4	11.9	8.37	27.7	Y	8,086
14	0.99	154.0	152.5	12.9	8.32	25.4	Y	8,161
15	1.02	143.5	146.4	14.2	8.44	24.5	Y	8,390
16	1.13	141.9	160.3	13.0	8.47	27.1	Y	8,111
17	1.16	143.7	166.7	14.2	8.43	24.8	Y	8,565
18	1.09	175.5	191.3	14.4	8.26	22.8	Y	7,460
19	1.02	155.1	158.2	14.3	8.21	22.3	Y	7,844
20	0.97	167.5	162.5	15.0	8.24	21.4	Y	8,000
21	1.05	152.4	160.0	14.7	8.08	20.9	Y	8,309
22	1.01	168.8	170.5	13.4	8.33	24.8	Y	7,551
23	1.09	145.7	158.8	12.5	8.54	28.5	Y	8,329
24	1.06	146.1	154.9	12.5	8.58	28.8	Y	7,954
25	1.11	132.7	147.3	13.0	8.55	27.8	Y	7,915
26	1.13	144.7	163.5	13.8	8.42	25.3	Y	7,844
27	1.13	156.2	176.5	14.0	8.35	24.4	Y	7,748
28	0.89	155.1	138.0	14.0	8.34	23.6	Y	8,493
29	1.04	139.2	144.8	14.0	8.33	23.9	Y	8,959
30	1.09	156.0	170.0	14.1	8.35	24.0	Y	7,319
31	1.04	151.3	157.4	13.6	8.39	25.0	Y	7,588

Signature: 

Date: 6/6/23

Print Name: Scott LaRoque

Cert #: T-9188

(1) If Cl2 at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.
 (2) Prior to 11/2014, Peak Instantaneous Demand Flow is used.

Department of Human Services - Drinking Water Section

Membrane Integrity Report Form

Public Water System Name: Albany

PWS ID#: 41 00012 B


Month/Year:

5/ 2023

Albany/Millersburg Water Plant

Date	Membrane 1	Membrane 2	Membrane 3	Membrane 4
05/01/23	Pass	Pass	Pass	Pass
05/02/23	Pass	Pass	Pass	Pass
05/03/23	Pass	Pass	Pass	Pass
05/04/23	Pass	Pass	Pass	Pass
05/05/23	Pass	Pass	Pass	Pass
05/06/23	Pass	Pass	Pass	Pass
05/07/23	Pass	Pass	Pass	Pass
05/08/23	Pass	Pass	Pass	Pass
05/09/23	Pass	Pass	Pass	Pass
05/10/23	Pass	Pass	Pass	Pass
05/11/23	Pass	Pass	Pass	Pass
05/12/23	Pass	Pass	Pass	Pass
05/13/23	Pass	Pass	Pass	Pass
05/14/23	Pass	Pass	Pass	Pass
05/15/23	Pass	Pass	Pass	Pass
05/16/23	Pass	Pass	Pass	Pass
05/17/23	Pass	Pass	Pass	Pass
05/18/23	Pass	Pass	Pass	Pass
05/19/23	Pass	Pass	Pass	Pass
05/20/23	Pass	Pass	Pass	Pass
05/21/23	Pass	Pass	Pass	Pass
05/22/23	Pass	Pass	Pass	Pass
05/23/23	Pass	Pass	Pass	Pass
05/24/23	Pass	Pass	Pass	Pass
05/25/23	Pass	Pass	Pass	Pass
05/26/23	Pass	Pass	Pass	Pass
05/27/23	Pass	Pass	Pass	Pass
05/28/23	Pass	Pass	Pass	Pass
05/29/23	Pass	Pass	Pass	Pass
05/30/23	Pass	Pass	Pass	Pass
05/31/23	Pass	Pass	Pass	Pass

Signature:



Date:

6/6/23

Print Name:

Scott LaRoque

Cert. #:

T-9188