

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Linn
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B

Month/Year: 6/2023

DAY	12 AM	4 AM	8 AM	NOON	4 PM	8 PM	Highest Reading of the Day (1)
	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]
1	0.01	0.01	0.01	0.01	0.01	0.02	0.02
2	0.02	0.01	0.01	0.01	0.02	0.01	0.02
3	0.01	0.01	0.02	0.01	0.01	0.02	0.02
4	0.01	0.02	0.02	0.01	0.02	0.01	0.02
5	0.01	0.01	0.01	0.01	0.01	0.01	0.01
6	0.01	0.02	0.02	0.01	0.01	0.01	0.02
7	0.01	0.01	0.02	0.02	0.02	0.01	0.02
8	0.01	0.01	0.02	0.01	0.01	0.01	0.02
9	0.01	0.01	0.01	0.02	0.01	0.01	0.02
10	0.02	0.01	0.01	0.01	0.01	0.01	0.02
11	0.01	0.01	0.01	0.01	0.01	0.02	0.02
12	0.01	0.01	0.02	0.01	0.02	0.01	0.02
13	0.01	0.01	0.01	0.01	0.02	0.01	0.02
14	0.02	0.01	0.02	0.01	0.02	0.01	0.02
15	0.01	0.02	0.01	0.01	0.01	0.01	0.02
16	0.01	0.01	0.01	0.01	0.01	0.01	0.01
17	0.01	0.01	0.01	0.01	0.01	0.01	0.01
18	0.01	0.01	0.01	0.01	0.01	0.02	0.02
19	0.01	0.01	0.01	0.02	0.01	0.01	0.02
20	0.01	0.02	0.01	0.01	0.01	0.01	0.02
21	0.01	0.01	0.01	Plant Off	0.02	0.02	0.02
22	0.01	0.02	0.02	0.01	0.01	0.01	0.02
23	0.02	0.01	0.01	0.02	0.01	0.01	0.02
24	0.02	0.01	0.02	0.01	0.01	0.01	0.02
25	0.01	0.01	0.02	0.02	0.01	0.02	0.02
26	0.01	0.02	0.02	0.02	0.02	0.02	0.02
27	0.02	0.02	0.02	0.02	0.02	0.02	0.02
28	0.02	0.02	0.02	0.02	0.02	0.02	0.02
29	0.02	0.02	0.02	0.02	0.02	0.02	0.02
30	0.02	0.02	0.02	0.02	0.02	0.02	0.02

Membrane Filtration	Monthly Summary (Answer Yes or No)	
95% of turbidity readings <= 1 NTU? (2)	<input checked="" type="radio"/> Yes / <input type="radio"/> No	All CL2 residuals at entry point >= 0.2 mg/l/?
All daily turbidity readings <= 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	
Notes:	CT's met everyday? <input checked="" type="radio"/> Yes / <input type="radio"/> No	
	PRINTED NAME: SCOTT LAROQUE	
	SIGNATURE: <i>SE JRV</i>	DATE: 7/6/23
	PHONE #: 541 791 0175	CERT #: T-918B

(1) Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. (2) Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B Month/Year: 6/2023

Date / Time	Minimum CL2 Residual @ 1st User (C) (1)	Contact Time (T)	Actual CT	Temp.	pH	Reqd. CT	CT Met? (1)	Peak Hourly Demand Flow (2)
	[ppm or mg/L]	[minutes]	C x T	[°C]		Use tables	Yes / No	[GPM]
1	1.03	129.2	133.1	13.7	8.45	25.5	Y	7,723
2	1.00	145.5	145.5	14.0	8.44	24.7	Y	8,001
3	0.96	148.0	142.1	14.4	8.43	23.9	Y	7,253
4	0.87	160.2	139.4	14.7	8.37	22.7	Y	8,408
5	0.98	141.3	138.5	14.8	8.35	22.7	Y	9,304
6	0.93	145.3	135.1	15.5	8.32	21.2	Y	9,221
7	0.96	144.6	138.8	16.0	8.24	20.0	Y	9,297
8	0.89	172.6	153.6	15.6	8.22	20.3	Y	7,966
9	1.01	157.0	158.6	15.0	8.29	22.0	Y	7,981
10	1.02	172.0	175.4	14.4	8.37	23.6	Y	8,138
11	1.02	144.8	147.7	15.0	8.29	22.1	Y	8,904
12	1.04	128.1	133.2	15.0	8.30	22.1	Y	9,091
13	1.04	153.2	159.3	15.7	8.24	20.6	Y	8,817
14	1.02	164.9	168.2	15.2	8.16	20.7	Y	8,357
15	0.98	153.6	150.5	14.5	8.24	22.2	Y	9,387
16	0.93	149.8	139.3	15.1	8.25	21.2	Y	8,961
17	0.98	195.1	191.2	15.9	8.13	19.4	Y	7,444
18	1.00	206.4	206.4	14.5	8.09	21.0	Y	6,680
19	1.11	176.0	195.4	13.5	8.39	25.5	Y	7,735
20	1.09	172.0	187.5	13.3	8.80	29.8	Y	7,410
21	0.99	145.9	144.4	13.5	8.82	29.5	Y	8,301
22	1.00	140.9	140.9	15.2	8.64	24.6	Y	9,150
23	0.95	154.3	146.6	15.9	8.38	21.2	Y	8,816
24	0.98	160.9	157.7	15.8	8.37	21.4	Y	8,703
25	0.98	156.3	153.2	15.6	8.35	21.5	Y	9,293
26	1.00	148.0	148.0	16.0	8.33	20.9	Y	9,098
27	1.02	153.2	156.3	16.0	8.30	20.6	Y	8,783
28	1.01	151.5	153.0	16.0	8.38	21.3	Y	9,537
29	1.02	146.9	149.8	16.6	8.28	19.7	Y	9,359
30	1.03	145.1	149.5	16.8	8.25	19.3	Y	9,103

Signature: Scott Laroque Date: 7/6/23
 Print Name: SCOTT LAROQUE Cert #: T-9188

(1) If Cl2 at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.
 (2) Prior to 11/2014, Peak Instantaneous Demand Flow is used.

Department of Human Services - Drinking Water Section

Membrane Integrity Report Form

Public Water System Name: Albany

PWS ID#: 41 00012 B

Month/Year:

6/ 2023

Albany/Millersburg Water Plant

Date	Membrane 1	Membrane 2	Membrane 3	Membrane 4
06/01/23	Pass	Pass	Pass	Pass
06/02/23	Pass	Pass	Pass	Pass
06/03/23	Pass	Pass	Pass	Pass
06/04/23	Pass	Pass	Pass	Pass
06/05/23	Pass	Pass	Pass	Pass
06/06/23	Pass	Pass	Pass	Pass
06/07/23	Pass	Pass	Pass	Pass
06/08/23	Pass	Pass	Pass	Pass
06/09/23	Pass	Pass	Pass	Pass
06/10/23	Pass	Pass	Pass	Pass
06/11/23	Pass	Pass	Pass	Pass
06/12/23	Pass	Pass	Pass	Pass
06/13/23	Pass	Pass	Pass	Pass
06/14/23	Pass	Pass	Pass	Pass
06/15/23	Pass	Pass	Pass	Pass
06/16/23	Pass	Pass	Pass	Pass
06/17/23	Pass	Pass	Pass	Pass
06/18/23	Pass	Pass	Pass	Pass
06/19/23	Pass	Pass	Pass	Pass
06/20/23	Pass	Pass	Pass	Pass
06/21/23	Pass	Pass	Pass	Pass
06/22/23	Pass	Pass	Pass	Pass
06/23/23	Pass	Pass	Pass	Pass
06/24/23	Pass	Pass	Pass	Pass
06/25/23	Pass	Pass	Pass	Pass
06/26/23	Pass	Pass	Pass	Pass
06/27/23	Pass	Pass	Pass	Pass
06/28/23	Pass	Pass	Pass	Pass
06/29/23	Pass	Pass	Pass	Pass
06/30/23	Pass	Pass	Pass	Pass

Signature: 

Date: 7/6/23

Print Name: SCOTT LAROQUE

Cert. #: T-9188