

**OHA - Drinking Water Program - Turbidity Monitoring Report Form    County: Linn**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: ALBANY, CITY OF    ID #: OR4100012    WTP--WTP-B

Month/Year: 10/2023

DAY	12 AM	4 AM	8 AM	NOON	4 PM	8 PM	Highest Reading of the Day (1)
	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]
1	0.02	0.02	0.02	0.02	0.02	0.03	0.03
2	0.02	0.02	0.02	0.02	0.02	0.02	0.02
3	0.02	0.02	0.02	0.02	0.02	0.02	0.02
4	0.02	0.02	0.02	0.02	0.02	0.02	0.02
5	0.02	0.02	0.02	0.02	0.02	0.02	0.02
6	0.02	0.02	0.02	0.02	0.02	0.01	0.02
7	0.01	0.02	0.02	0.02	0.01	0.01	0.02
8	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9	0.01	0.01	0.01	0.01	0.02	0.02	0.02
10	0.01	0.01	0.01	0.01	0.01	0.01	0.01
11	0.01	0.01	0.02	0.02	0.01	0.01	0.02
12	0.01	0.01	0.01	0.01	0.01	0.01	0.01
13	0.01	0.01	0.01	0.01	0.01	0.01	0.01
14	0.01	0.01	0.01	0.01	0.01	0.01	0.01
15	0.01	0.01	0.01	0.01	0.01	0.01	0.01
16	0.01	0.01	0.01	0.01	0.01	0.03	0.03
17	0.01	0.01	0.01	0.01	0.01	0.01	0.01
18	0.01	0.01	0.01	0.01	0.01	0.01	0.01
19	0.01	0.01	0.01	0.01	0.01	0.01	0.01
20	0.01	0.02	0.01	0.01	0.01	0.01	0.02
21	0.01	0.01	0.01	0.01	0.01	0.01	0.01
22	0.01	0.01	0.01	0.01	0.01	0.01	0.01
23	0.01	0.01	0.01	0.01	0.01	0.01	0.01
24	0.01	0.01	Plant Off	Plant Off	Plant Off	0.04	0.04
25	0.03	0.02	0.02	0.02	0.02	0.02	0.03
26	0.02	0.02	0.02	0.02	0.02	0.02	0.02
27	0.02	0.02	0.02	0.02	0.02	0.02	0.02
28	0.02	0.02	0.02	0.02	0.02	0.02	0.02
29	0.02	0.02	0.02	0.02	0.02	0.02	0.02
30	0.02	0.02	0.02	0.02	0.02	0.02	0.02
31	0.02	0.02	0.02	0.02	0.02	0.02	0.02

Membrane Filtration	Monthly Summary (Answer Yes or No)	
95% of turbidity readings <= 1 NTU? (2)	Yes / No	CT's met everyday? Yes / No
All daily turbidity readings <= 5 NTU?	Yes / No	All CL2 residuals at entry point >= 0.2 mg/l? Yes / No
<b>Notes:</b>	PRINTED NAME: <i>Chris Germond</i>	
	SIGNATURE: <i>Chris Germond</i>	DATE: <i>11/8/23</i>
	PHONE #: <i>541-704-2309</i>	CERT #: <i>7-08682</i>

(1) Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. (2) Filtered systems only.

## OHA - Drinking Water Program - Surface Water Quality Data Form

**System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B**      **Month/Year: 10/2023**

Date / Time	Minimum CL2 Residual @ 1st User (C) (1) [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C x T	Temp. [°C]	pH	Reqd. CT Use tables	CT Met? (1) Yes / No	Peak Hourly Demand Flow (2) [GPM]
1	0.95	184.1	174.9	13.1	8.22	24.1	Y	7,817
2	1.04	184.2	191.6	13.6	8.24	23.8	Y	7,294
3	1.02	175.2	178.7	14.0	8.21	22.9	Y	7,697
4	1.04	155.0	161.2	14.3	8.22	22.5	Y	8,660
5	1.06	174.2	184.7	14.8	8.20	21.7	Y	7,812
6	1.01	180.2	182.0	15.1	8.14	20.6	Y	7,658
7	1.01	180.8	182.6	14.7	8.13	21.1	Y	8,402
8	0.99	190.3	188.4	14.5	8.18	21.7	Y	7,573
9	1.06	166.5	176.5	14.6	8.23	22.2	Y	8,112
10	1.06	175.9	186.5	14.6	8.24	22.3	Y	7,444
11	1.04	154.8	161.0	14.8	8.18	21.5	Y	8,923
12	0.95	144.8	137.6	14.9	8.14	20.7	Y	8,851
13	0.87	173.3	150.8	15.0	8.09	20.0	Y	8,123
14	0.91	148.1	134.8	15.4	8.06	19.3	Y	6,436
15	1.04	119.4	124.2	15.7	8.07	19.4	Y	8,043
16	1.02	115.6	117.9	15.9	8.09	19.2	Y	7,228
17	0.98	136.7	134.0	15.8	8.03	18.8	Y	7,321
18	0.95	119.9	113.9	15.8	8.03	18.9	Y	7,313
19	1.09	164.2	179.0	15.4	8.03	19.6	Y	6,107
20	1.01	195.4	197.4	15.9	8.02	18.8	Y	7,753
21	0.94	169.4	159.2	16.4	8.00	17.9	Y	8,350
22	0.98	174.0	170.5	16.2	8.03	18.4	Y	7,787
23	1.07	183.0	195.8	16.0	8.09	19.2	Y	7,264
24	1.04	164.6	171.2	15.0	8.12	20.7	Y	8,158
25	1.08	164.5	177.7	13.9	8.11	22.2	Y	6,576
26	1.06	150.4	159.4	13.1	8.15	23.9	Y	7,636
27	1.02	138.3	141.1	12.6	8.17	24.6	Y	8,540
28	1.01	119.3	120.5	11.3	8.19	27.0	Y	7,636
29	1.04	111.1	115.5	11.2	8.21	27.5	Y	7,388
30	0.95	133.6	126.9	11.1	8.18	27.0	Y	7,490
31	0.87	133.0	115.7	11.1	8.24	27.4	Y	7,591

Signature: Chris Germond      Date: 11/8/23  
 Print Name: Chris Germond      Cert #: T-08682

(1) If Cl2 at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.  
 (2) Prior to 11/2014, Peak Instantaneous Demand Flow is used.

## Department of Human Services - Drinking Water Section

### Membrane Integrity Report Form

Public Water System Name: Albany

PWS ID#: 41 00012 B

Month/Year:

10/ 2023

Albany/Millersburg Water Plant

Date	Membrane 1	Membrane 2	Membrane 3	Membrane 4
10/01/23	Pass	Pass	Pass	Pass
10/02/23	Pass	Pass	Pass	Pass
10/03/23	Pass	Pass	Pass	Pass
10/04/23	Pass	Pass	Pass	Pass
10/05/23	Pass	Pass	Pass	Pass
10/06/23	Pass	Pass	Pass	Pass
10/07/23	Pass	Pass	Pass	Pass
10/08/23	Pass	Pass	Pass	Pass
10/09/23	Pass	Pass	Pass	Pass
10/10/23	Pass	Pass	Pass	Pass
10/11/23	Pass	Pass	Pass	Pass
10/12/23	Pass	Pass	Pass	Pass
10/13/23	Pass	Pass	Pass	Pass
10/14/23	Pass	Pass	Pass	Pass
10/15/23	Pass	Pass	Pass	Pass
10/16/23	Pass	Pass	Pass	Pass
10/17/23	Pass	Pass	Pass	Pass
10/18/23	Pass	Pass	Pass	Pass
10/19/23	Pass	Pass	Pass	Pass
10/20/23	Pass	Pass	Pass	Pass
10/21/23	Pass	Pass	Pass	Pass
10/22/23	Pass	Pass	Pass	Pass
10/23/23	Pass	Pass	Pass	Pass
10/24/23	Pass	Pass	Pass	Pass
10/25/23	Pass	Pass	Pass	Pass
10/26/23	Pass	Pass	Pass	Pass
10/27/23	Pass	Pass	Pass	Pass
10/28/23	Pass	Pass	Pass	Pass
10/29/23	Pass	Pass	Pass	Pass
10/30/23	Pass	Pass	Pass	Pass
10/31/23	Pass	Pass	Pass	Pass

Signature: Chris Germond

Date: 11/8/23

Print Name: Chris Germond

Cert. #: T-08682