

Membrane Filter Monthly Operating Report

County: Linn

System Name: ALBANY, CITY OF

PWS ID # 41-00012

PlantID: WTP-B

Month/Year: 10/2025

Minimum test pressure (applied || req'd): 15.6 psi || 11.4 psi

Day	CFE Daily Turbidity [NTU]	Highest CFE [NTU]	Highest IFE [NTU]	Highest PDR of the day [psi/min]	Lowest LRV of the day [log removal]	DIT Daily [Yes/No or Off]
1	0.011	0.015	0.026	0.43	4.30	Y
2	0.012	0.022	0.030	0.43	4.30	Y
3	0.011	0.013	0.026	0.41	4.29	Y
4	0.011	0.013	0.025	0.42	4.29	Y
5	0.011	0.013	0.026	0.42	4.33	Y
6	0.011	0.015	0.026	0.42	4.28	Y
7	0.011	0.013	0.026	0.42	4.32	Y
8	0.011	0.013	0.026	0.42	4.31	Y
9	0.011	0.015	0.028	0.41	4.31	Y
10	0.011	0.017	0.026	0.42	4.29	Y
11	0.011	0.015	0.027	0.42	4.30	Y
12	0.011	0.013	0.027	0.41	4.29	Y
13	0.011	0.013	0.026	0.41	4.30	Y
14	0.011	0.017	0.026	0.40	4.32	Y
15	0.012	0.013	0.026	0.39	4.33	Y
16	0.011	0.015	0.028	0.42	4.32	Y
17	0.011	0.015	0.026	0.40	4.32	Y
18	0.011	0.013	0.027	0.40	4.32	Y
19	0.011	0.019	0.030	0.42	4.18	Y
20	0.011	0.013	0.026	0.41	4.25	Y
21	0.012	0.015	0.033	0.41	4.39	Y
22	0.017	0.022	0.030	0.39	4.26	Y
23	0.012	0.019	0.026	0.40	4.15	Y
24	0.011	0.015	0.026	0.41	4.27	Y
25	0.011	0.020	0.026	0.40	4.30	Y
26	0.011	0.013	0.027	0.40	4.24	Y
27	0.011	0.019	0.026	0.39	4.20	Y
28	0.011	0.013	0.026	0.42	4.22	Y
29	0.011	0.013	0.030	0.42	4.20	Y
30	0.011	0.013	0.026	0.43	4.25	Y
31	0.011	0.013	0.026	0.42	4.28	Y

Compliance summary (operator to complete any blank fields)				
95% of daily turbidity readings $\leq$ 1 NTU? <u>(Y) / N</u>	All turbidity readings $\leq$ 5 NTU? <u>(Y) / N</u>	All IFE turbidity readings $\leq$ 0.15 NTU? <u>(Y) / N</u>	Performance std met? (PDR $\leq$ PDRMax, LRV $\geq$ LRC) <u>(Y) / N</u>	DIT Daily? <u>(Y) / N</u>
CT's met daily? <u>(Y) / N</u>	All Cl2 residual at EP $\geq$ 0.2 mg/L? <u>(Y) / N</u>	PDR $\leq$ PDRMax (0.7 psi/min)? <u>(Y) / N</u>	LRV ambient $\geq$ LRC (4.00)? <u>(Y) / N</u>	
PRINT NAME: <u>Chris Germon</u>			DATE: <u>11/6/25</u>	
SIGNATURE: <u>Chris Germon</u>			WT CERT #: <u>T-08682</u>	
NOTES:			PHONE #: <u>541-704-2309</u>	

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Linn

Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: ALBANY, CITY OF ID #: OR4100012 WTP--WTP-B

Month/Year: 10/2025

DAY	12 AM	4 AM	8 AM	NOON	4 PM	8 PM	Highest Reading of the Day (1)
	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]
1	0.01	0.01	0.01	0.01	0.01	0.01	0.01
2	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3	0.01	0.01	0.01	0.01	0.01	0.01	0.01
4	0.01	0.01	0.01	0.01	0.01	0.01	0.01
5	0.01	0.01	0.01	0.01	0.01	0.01	0.01
6	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7	0.01	0.01	0.01	0.01	0.01	0.01	0.01
8	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9	0.01	0.01	0.01	0.01	0.01	0.01	0.01
10	0.01	0.01	0.01	0.01	0.01	0.01	0.01
11	0.01	0.01	0.01	0.01	0.01	0.01	0.01
12	0.01	0.01	0.01	0.01	0.01	0.01	0.01
13	0.01	0.01	0.01	0.01	0.01	0.01	0.01
14	0.01	0.01	0.01	0.01	0.01	0.01	0.01
15	0.01	0.01	0.01	Plant Off	0.01	0.01	0.01
16	0.01	0.01	0.01	0.01	0.01	0.01	0.01
17	0.01	0.01	0.01	0.01	0.01	0.01	0.01
18	0.01	0.01	0.01	0.01	0.01	0.01	0.01
19	0.01	0.01	0.01	0.01	0.01	0.01	0.01
20	0.01	0.01	0.01	0.01	0.01	0.01	0.01
21	0.01	0.01	Plant Off	Plant Off	Plant Off	Plant Off	0.01
22	Plant Off	Plant Off	Plant Off	Plant Off	0.02	0.02	0.02
23	0.01	0.01	0.01	0.01	0.01	0.01	0.01
24	0.01	0.01	0.01	0.01	0.01	0.01	0.01
25	0.01	0.01	0.01	0.01	0.01	0.01	0.01
26	0.01	0.01	0.01	0.01	0.01	0.01	0.01
27	0.01	0.01	0.01	0.01	0.01	0.01	0.01
28	0.01	0.01	0.01	0.01	0.01	0.01	0.01
29	0.01	0.01	0.01	0.01	0.01	0.01	0.01
30	0.01	0.01	0.01	0.01	0.01	0.01	0.01
31	0.01	0.01	0.01	0.01	0.01	0.01	0.01

Membrane Filtration	Monthly Summary (Answer Yes or No)	
95% of turbidity readings <= 1 NTU? (2) Yes / No All daily turbidity readings <= 5 NTU? Yes / No	CT's met everyday? Yes / No	All CL2 residuals at entry point >= 0.2 mg/l? Yes / No
Notes:	PRINTED NAME: <i>Chris Germond</i>	
	SIGNATURE: <i>Chris Germond</i>	DATE: <i>11/6/25</i>
	PHONE #: <i>541-704-2309</i>	CERT #: <i>T-08682</i>

(1) Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. (2) Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: ALBANY, CITY OF **ID #:** OR4100012 **WTP-:**WTP-B **Month/Year:** 10/2025

Date / Time	Minimum CL2 Residual @ 1st User (C) (1) [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C x T	Temp. [°C]	pH	Reqd. CT Use tables	CT Met? (1) Yes / No	Peak Hourly Demand Flow (2) [GPM]
1	0.79	156.7	123.8	15.4	8.07	19.2	Y	7,833
2	0.77	170.5	131.3	15.3	8.01	18.9	Y	6,888
3	0.74	160.5	118.8	16.0	8.06	18.3	Y	7,845
4	0.80	180.6	144.5	16.4	7.99	17.5	Y	6,997
5	0.83	144.2	119.7	16.0	8.04	18.4	Y	9,019
6	0.97	180.6	175.2	15.3	8.04	19.6	Y	7,046
7	0.98	162.2	159.0	14.8	8.03	20.1	Y	8,224
8	0.95	173.5	164.8	14.5	7.99	20.1	Y	7,022
9	0.97	173.3	168.1	13.9	8.04	21.4	Y	7,407
10	0.85	171.1	145.4	14.3	8.08	21.0	Y	7,601
11	0.86	168.7	145.1	14.2	8.01	20.6	Y	7,262
12	0.89	142.0	126.4	14.0	8.03	21.0	Y	8,321
13	0.89	155.5	138.4	13.3	8.05	22.1	Y	8,557
14	0.91	184.6	168.0	12.9	8.04	22.7	Y	6,315
15	0.87	181.4	157.8	12.8	8.04	22.8	Y	7,806
16	0.76	163.5	124.3	12.9	8.04	22.3	Y	7,586
17	0.94	165.8	155.9	13.8	8.06	21.7	Y	7,131
18	1.05	138.5	145.4	13.5	8.04	22.2	Y	6,934
19	0.97	129.3	125.4	14.7	8.10	20.8	Y	5,764
20	0.93	156.0	145.1	14.1	8.07	21.3	Y	3,902
21	OFFLINE	0.0		13.9	8.17	20.2		4,616
22	0.76	219.0	166.4	14.3	9.52	35.2	Y	3,646
23	1.02	155.2	158.3	14.0	8.19	22.6	Y	7,335
24	0.95	164.9	156.7	14.5	8.20	21.8	Y	6,714
25	0.90	167.3	150.6	13.8	8.10	21.8	Y	8,072
26	0.84	146.7	123.2	13.0	8.11	23.0	Y	7,956
27	0.69	150.8	104.1	12.7	8.09	22.9	Y	7,717
28	0.67	160.4	107.5	13.1	8.07	22.1	Y	8,300
29	0.98	142.9	140.0	14.3	8.07	21.2	Y	6,888
30	0.98	157.2	154.1	13.0	8.05	23.0	Y	7,154
31	0.89	161.1	143.4	13.1	8.08	22.7	Y	7,182

Signature: Chris Germond

Date: 11/6/25

Print Name: Chris Germond

Cert #: T-08682

- (1) If Cl2 at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.
 (2) Prior to 11/2014, Peak Instantaneous Demand Flow is used.

Department of Human Services - Drinking Water Section

Membrane Integrity Report Form

Public Water System Name: Albany

PWS ID#: 41 00012 B

Month/Year: 10/ 2025

Albany/Millersburg Water Plant

Date	Membrane 1	Membrane 2	Membrane 3	Membrane 4
10/01/25	Pass	Pass	Pass	Pass
10/02/25	Pass	Pass	Pass	Pass
10/03/25	Pass	Pass	Pass	Pass
10/04/25	Pass	Pass	Pass	Pass
10/05/25	Pass	Pass	Pass	Pass
10/06/25	Pass	Pass	Pass	Pass
10/07/25	Pass	Pass	Pass	Pass
10/08/25	Pass	Pass	Pass	Pass
10/09/25	Pass	Pass	Pass	Pass
10/10/25	Pass	Pass	Pass	Pass
10/11/25	Pass	Pass	Pass	Pass
10/12/25	Pass	Pass	Pass	Pass
10/13/25	Pass	Pass	Pass	Pass
10/14/25	Pass	Pass	Pass	Pass
10/15/25	Pass	Pass	Pass	Pass
10/16/25	Pass	Pass	Pass	Pass
10/17/25	Pass	Pass	Pass	Pass
10/18/25	Pass	Pass	Pass	Pass
10/19/25	Pass	Pass	Pass	Pass
10/20/25	Pass	Pass	Pass	Pass
10/21/25	Pass	Pass	Pass	Pass
10/22/25	Pass	Pass	Pass	Pass
10/23/25	Pass	Pass	Pass	Pass
10/24/25	Pass	Pass	Pass	Pass
10/25/25	Pass	Pass	Pass	Pass
10/26/25	Pass	Pass	Pass	Pass
10/27/25	Pass	Pass	Pass	Pass
10/28/25	Pass	Pass	Pass	Pass
10/29/25	Pass	Pass	Pass	Pass
10/30/25	Pass	Pass	Pass	Pass
10/31/25	Pass	Pass	Pass	Pass

Signature:

Chris Germond

Date:

11/6/25

Print Name:

Chris Germond

Cert. #:

T-08682