

Membrane Filter Monthly Operating Report

County: Linn

System Name: ALBANY, CITY OF

PWS ID # 41-00012

PlantID: WTP-B

Month/Year: 1/2026

Minimum test pressure (applied || req'd): 15.3 psi || 11.4 psi

| Day | CFE Daily Turbidity [NTU] | Highest CFE [NTU] | Highest IFE [NTU] | Highest PDR of the day [psi/min] | Lowest LRV of the day [log removal] | DIT Daily [Yes/No or Off] |
|-----|---------------------------|-------------------|-------------------|----------------------------------|-------------------------------------|---------------------------|
| 1   | 0.015                     | 0.026             | 0.041             | 0.52                             | 4.26                                | Y                         |
| 2   | 0.015                     | 0.030             | 0.041             | 0.51                             | 4.21                                | Y                         |
| 3   | 0.014                     | 0.026             | 0.043             | 0.51                             | 4.28                                | Y                         |
| 4   | 0.015                     | 0.026             | 0.041             | 0.52                             | 4.22                                | Y                         |
| 5   | 0.014                     | 0.020             | 0.035             | 0.55                             | 4.21                                | Y                         |
| 6   | 0.013                     | 0.020             | 0.037             | 0.54                             | 4.26                                | Y                         |
| 7   | 0.012                     | 0.024             | 0.037             | 0.55                             | 4.26                                | Y                         |
| 8   | 0.013                     | 0.022             | 0.036             | 0.54                             | 4.24                                | Y                         |
| 9   | 0.013                     | 0.022             | 0.035             | 0.54                             | 4.24                                | Y                         |
| 10  | 0.014                     | 0.024             | 0.037             | 0.55                             | 4.26                                | Y                         |
| 11  | 0.013                     | 0.020             | 0.035             | 0.54                             | 4.24                                | Y                         |
| 12  | 0.013                     | 0.019             | 0.035             | 0.54                             | 4.26                                | Y                         |
| 13  | 0.013                     | 0.020             | 0.035             | 0.55                             | 4.26                                | Y                         |
| 14  | 0.013                     | 0.018             | 0.031             | 0.00                             | 4.26                                | N                         |
| 15  | 0.012                     | 0.019             | 0.033             | 0.54                             | 4.28                                | Y                         |
| 16  | 0.013                     | 0.031             | 0.030             | 0.54                             | 4.27                                | Y                         |
| 17  | 0.013                     | 0.025             | 0.031             | 0.54                             | 4.27                                | Y                         |
| 18  | 0.012                     | 0.018             | 0.031             | 0.55                             | 4.25                                | Y                         |
| 19  | 0.012                     | 0.019             | 0.030             | 0.55                             | 4.28                                | Y                         |
| 20  | 0.012                     | 0.019             | 0.030             | 0.55                             | 4.26                                | Y                         |
| 21  | 0.013                     | 0.020             | 0.031             | 0.55                             | 4.28                                | Y                         |
| 22  | 0.013                     | 0.019             | 0.030             | 0.55                             | 4.28                                | Y                         |
| 23  | 0.013                     | 0.019             | 0.030             | 0.56                             | 4.27                                | Y                         |
| 24  | 0.013                     | 0.019             | 0.030             | 0.55                             | 4.25                                | Y                         |
| 25  | 0.012                     | 0.018             | 0.030             | 0.55                             | 4.28                                | Y                         |
| 26  | 0.013                     | 0.019             | 0.031             | 0.56                             | 4.25                                | Y                         |
| 27  | 0.013                     | 0.018             | 0.030             | 0.56                             | 4.28                                | Y                         |
| 28  | 0.013                     | 0.020             | 0.030             | 0.57                             | 4.23                                | Y                         |
| 29  | 0.013                     | 0.020             | 0.030             | 0.56                             | 4.26                                | Y                         |
| 30  | 0.013                     | 0.019             | 0.030             | 0.56                             | 4.26                                | Y                         |
| 31  | 0.013                     | 0.019             | 0.033             | 0.56                             | 4.24                                | Y                         |

PDI's weren't run due to plant being shut down for maintenance. PDI's were run within a 24 hour period the day before.

| Compliance summary (operator to complete any blank fields)                           |  |   |   |  |
|--|--|---|---|--|
| 95% of daily turbidity readings ≤ 1 NTU?<br><input checked="" type="checkbox"/> / N] | All turbidity readings ≤ 5 NTU?<br><input checked="" type="checkbox"/> / N]    | All IFE turbidity readings ≤ 0.15 NTU?<br><input checked="" type="checkbox"/> / N]  | Performance std met? (PDR ≤ PDR <sub>Max</sub> , LRV ≥ LRC)<br><input checked="" type="checkbox"/> / N] | DIT Daily?<br><input checked="" type="checkbox"/> / N] |
| CT's met daily?<br><input checked="" type="checkbox"/> / N]                          | All Cl2 residual at EP ≥ 0.2 mg/L?<br><input checked="" type="checkbox"/> / N] | PDR ≤ PDR <sub>Max</sub> (0.7 psi/min)?<br><input checked="" type="checkbox"/> / N] | LRV <sub>ambient</sub> ≥ LRC (4.00)?<br><input checked="" type="checkbox"/> / N]                        |  |
| PRINT NAME: <u>Chris Germond</u>   |  | DATE: <u>1/1/26</u>   |   |  |
| SIGNATURE: <u>Chris Germond</u>  |  | WT CERT #: <u>7-08682</u>   |   |  |
| NOTES:   |  | PHONE #: <u>541-744-704-2309</u>  |   |  |

**OHA - Drinking Water Program - Turbidity Monitoring Report Form    County: Linn**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: ALBANY, CITY OF    ID #: OR4100012    WTP:-WTP-B

Month/Year: 1/2026

| DAY | 12 AM     | 4 AM      | 8 AM      | NOON      | 4 PM      | 8 PM      | Highest Reading of the Day (1) |
|-----|-----------|-----------|-----------|-----------|-----------|-----------|--------------------------------|
|     | [NTU]                          |
| 1   | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.02      | 0.02                           |
| 2   | 0.01      | 0.02      | 0.01      | 0.02      | 0.01      | 0.01      | 0.02                           |
| 3   | 0.01      | 0.01      | 0.01      | 0.01      | 0.02      | 0.01      | 0.02                           |
| 4   | 0.01      | 0.01      | 0.01      | 0.02      | 0.01      | 0.01      | 0.02                           |
| 5   | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01                           |
| 6   | 0.01      | 0.01      | 0.01      | 0.01      | 0.02      | 0.01      | 0.02                           |
| 7   | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01                           |
| 8   | 0.01      | 0.01      | 0.02      | 0.02      | 0.01      | 0.01      | 0.02                           |
| 9   | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01                           |
| 10  | 0.01      | 0.02      | 0.01      | 0.01      | 0.01      | 0.01      | 0.02                           |
| 11  | 0.02      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.02                           |
| 12  | 0.01      | 0.01      | 0.02      | 0.01      | 0.01      | 0.01      | 0.02                           |
| 13  | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01                           |
| 14  | 0.01      | 0.01      | Plant Off | Plant Off | Plant Off | Plant Off | 0.01                           |
| 15  | Plant Off | Plant Off | Plant Off | Plant Off | 0.01      | 0.01      | 0.01                           |
| 16  | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01                           |
| 17  | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01                           |
| 18  | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01                           |
| 19  | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01                           |
| 20  | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01                           |
| 21  | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01                           |
| 22  | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01                           |
| 23  | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01                           |
| 24  | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01                           |
| 25  | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01                           |
| 26  | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01                           |
| 27  | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01                           |
| 28  | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01                           |
| 29  | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01                           |
| 30  | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01                           |
| 31  | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01      | 0.01                           |

| Membrane Filtration   | Monthly Summary (Answer Yes or No)   |   |
|---|--|---|
| 95% of turbidity readings <= 1 NTU? (2) <input checked="" type="radio"/> Yes / <input type="radio"/> No | CT's met everyday? <input checked="" type="radio"/> Yes / <input type="radio"/> No | All CL2 residuals at entry point >= 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No |
| All daily turbidity readings <= 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No  |  |   |
| Notes:  | PRINTED NAME: Chris Germond  |   |
|   | SIGNATURE: <i>Chris Germond</i>  | DATE: 2/7/26  |
|   | PHONE #: 541-704-2309  | CERT #: T-08682   |

(1) Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. (2) Filtered systems only.

## OHA - Drinking Water Program - Surface Water Quality Data Form

|   |                    |
|---|--------------------|
| System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B | Month/Year: 1/2026 |
|---|--------------------|

| Date / Time | Minimum CL2 Residual @ 1st User (C) (1) | Contact Time (T) | Actual CT | Temp. | pH   | Reqd. CT   | CT Met? (1) | Peak Hourly Demand Flow (2) |
|-------------|---|------------------|-----------|-------|------|------------|-------------|-----------------------------|
|             | [ppm or mg/L]                           | [minutes]        | C x T     | [°C]  |      | Use tables | Yes / No    | [GPM]                       |
| 1           | 1.06                                    | 202.4            | 214.5     | 7.9   | 8.18 | 34.0       | Y           | 6,810                       |
| 2           | 1.10                                    | 188.2            | 207.0     | 8.4   | 8.18 | 33.0       | Y           | 6,802                       |
| 3           | 0.97                                    | 199.2            | 193.2     | 9.6   | 8.19 | 30.0       | Y           | 6,112                       |
| 4           | 0.86                                    | 179.0            | 153.9     | 9.9   | 8.17 | 29.0       | Y           | 7,482                       |
| 5           | 0.78                                    | 171.9            | 134.1     | 9.1   | 8.18 | 30.2       | Y           | 7,040                       |
| 6           | 0.98                                    | 172.4            | 169.0     | 8.6   | 8.18 | 32.2       | Y           | 6,980                       |
| 7           | 1.17                                    | 163.2            | 190.9     | 8.2   | 8.19 | 33.9       | Y           | 6,764                       |
| 8           | 0.95                                    | 178.1            | 169.2     | 7.9   | 8.18 | 33.7       | Y           | 6,645                       |
| 9           | 0.93                                    | 204.8            | 190.5     | 8.3   | 8.15 | 32.2       | Y           | 6,243                       |
| 10          | 1.08                                    | 191.3            | 206.6     | 8.2   | 8.14 | 33.1       | Y           | 6,480                       |
| 11          | 1.13                                    | 155.3            | 175.5     | 8.6   | 8.17 | 32.6       | Y           | 8,401                       |
| 12          | 1.05                                    | 181.0            | 190.1     | 8.3   | 8.18 | 33.0       | Y           | 6,521                       |
| 13          | 1.09                                    | 176.2            | 192.1     | 7.8   | 8.16 | 34.2       | Y           | 6,354                       |
| 14          | 1.07                                    | 409.1            | 437.7     | 7.8   | 8.10 | 33.4       | Y           | 2,878                       |
| 15          | 0.97                                    | 183.0            | 177.5     | 7.9   | 8.09 | 32.7       | Y           | 4,871                       |
| 16          | 0.79                                    | 190.0            | 150.1     | 7.3   | 8.08 | 33.1       | Y           | 6,393                       |
| 17          | 1.02                                    | 176.0            | 179.5     | 7.0   | 8.08 | 34.8       | Y           | 6,697                       |
| 18          | 0.80                                    | 170.3            | 136.2     | 6.8   | 8.11 | 34.7       | Y           | 6,435                       |
| 19          | 1.04                                    | 167.0            | 173.7     | 6.6   | 8.10 | 36.2       | Y           | 7,189                       |
| 20          | 0.59                                    | 177.6            | 104.8     | 6.3   | 8.08 | 34.8       | Y           | 7,005                       |
| 21          | 0.97                                    | 171.1            | 166.0     | 6.1   | 8.11 | 37.2       | Y           | 7,739                       |
| 22          | 0.95                                    | 200.0            | 190.0     | 5.7   | 8.07 | 37.6       | Y           | 6,301                       |
| 23          | 0.95                                    | 202.7            | 192.6     | 6.6   | 8.05 | 35.0       | Y           | 6,033                       |
| 24          | 0.97                                    | 184.2            | 178.7     | 5.7   | 8.10 | 38.1       | Y           | 6,952                       |
| 25          | 0.95                                    | 149.1            | 141.6     | 5.0   | 8.15 | 40.5       | Y           | 7,427                       |
| 26          | 1.00                                    | 182.7            | 182.7     | 5.3   | 8.10 | 39.2       | Y           | 6,515                       |
| 27          | 0.87                                    | 159.0            | 138.3     | 5.9   | 8.08 | 37.0       | Y           | 6,892                       |
| 28          | 0.82                                    | 173.3            | 142.1     | 6.4   | 8.07 | 35.2       | Y           | 7,044                       |
| 29          | 0.81                                    | 187.0            | 151.5     | 7.7   | 8.09 | 32.4       | Y           | 6,959                       |
| 30          | 0.96                                    | 183.2            | 175.9     | 8.1   | 8.11 | 32.4       | Y           | 7,338                       |
| 31          | 0.93                                    | 184.4            | 171.5     | 8.1   | 8.11 | 32.1       | Y           | 7,003                       |

|                                  |                       |
|----------------------------------|-----------------------|
| Signature: <u>Chris Germond</u>  | Date: <u>2/7/26</u>   |
| Print Name: <u>Chris Germond</u> | Cert #: <u>T-0682</u> |

(1) If Cl2 at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.  
(2) Prior to 11/2014, Peak Instantaneous Demand Flow is used.