

Membrane Filter Monthly Operating Report

County: Linn

System Name: ALBANY, CITY OF

PWS ID # 41-00012

PlantID: WTP-B

Month/Year: 2/2026

Minimum test pressure (applied || req'd): 15.2 psi || 11.4 psi

Day	CFE Daily Turbidity [NTU]	Highest CFE [NTU]	Highest IFE [NTU]	Highest PDR of the day [psi/min]	Lowest LRV of the day [log removal]	DIT Daily [Yes/No or Off]
1	0.012	0.019	0.032	0.57	4.26	Y
2	0.013	0.020	0.030	0.57	4.25	Y
3	0.013	0.026	0.030	0.56	4.25	Y
4	0.012	0.024	0.030	0.62	4.26	Y
5	0.013	0.020	0.030	0.62	4.23	Y
6	0.013	0.020	0.028	0.60	4.25	Y
7	0.013	0.017	0.030	0.61	4.25	Y
8	0.012	0.024	0.030	0.60	4.23	Y
9	0.015	0.046	0.061	0.59	4.21	Y
10	0.016	0.043	0.050	0.60	4.19	Y
11	0.013	0.024	0.033	0.61	4.23	Y
12	0.013	0.019	0.031	0.60	4.20	Y
13	0.013	0.020	0.031	0.59	4.22	Y
14	0.012	0.020	0.030	0.60	4.24	Y
15	0.013	0.019	0.033	0.60	4.23	Y
16	0.014	0.024	0.037	0.82	4.18	Y
17	0.012	0.017	0.024	0.48	4.36	Y
18	0.012	0.037	0.024	0.58	4.19	Y
19	0.011	0.015	0.024	0.57	4.23	Y
20	0.011	0.015	0.022	0.57	4.28	Y
21	0.011	0.025	0.024	0.56	4.24	Y
22	0.011	0.015	0.022	0.57	4.27	Y
23	0.012	0.017	0.029	0.57	4.26	Y
24	0.012	0.019	0.024	0.57	4.19	Y
25	0.012	0.054	0.030	0.57	4.15	Y
26	0.011	0.020	0.022	0.57	4.19	Y
27	0.011	0.015	0.024	0.57	4.19	Y
28	0.011	0.017	0.022	0.57	4.21	Y

2/16 We programmed and changed parameters for PDT's which caused Cell 3 to have a PDR above 0.61 psi/min PDR. Cell 3 was shutdown and not run after. The issue was resolved the next day. 2/16 highest PDR was 0.48 on Cell 1.

Compliance summary (operator to complete any blank fields)				
95% of daily turbidity readings ≤ 1 NTU? <u>(Y/N)</u>	All turbidity readings ≤ 5 NTU? <u>(Y/N)</u>	All IFE turbidity readings ≤ 0.15 NTU? <u>(Y/N)</u>	Performance std met? (PDR ≤ PDR _{Max} , LRV ≥ LRC) <u>(Y/N)</u>	DIT Daily? <u>(Y/N)</u>
CT's met daily? <u>(Y/N)</u>	All Cl ₂ residual at EP ≥ 0.2 mg/L? <u>(Y/N)</u>	PDR ≤ PDR _{Max} (0.7 psi/min)? <u>(Y/N)</u>	LRV _{ambient} ≥ LRC (4.00)? <u>(Y/N)</u>	
PRINT NAME: <u>Chris Germond</u>		DATE: <u>2/16/2026</u>		
SIGNATURE: <u>Chris Germond</u>		WT CERT #: <u>T-08682</u>		
NOTES:		PHONE #: <u>541-704-2309</u>		

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Linn
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: ALBANY, CITY OF ID #: OR4100012 WTP--WTP-B

Month/Year: 2/2026

DAY	12 AM	4 AM	8 AM	NOON	4 PM	8 PM	Highest Reading of the Day (1)
	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]
1	0.01	0.01	0.01	0.01	0.01	0.01	0.01
2	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3	0.01	0.01	0.01	0.01	0.01	0.01	0.01
4	0.01	0.01	0.01	0.01	0.01	0.01	0.01
5	0.01	0.01	0.01	0.01	0.01	0.01	0.01
6	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7	0.01	0.01	0.01	0.01	0.01	0.01	0.01
8	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9	0.01	0.01	0.02	0.01	0.02	0.02	0.02
10	0.02	0.02	0.02	0.01	0.01	0.01	0.02
11	0.01	0.01	0.01	0.01	0.01	0.01	0.01
12	0.01	0.01	0.01	0.01	0.01	0.02	0.02
13	0.01	0.01	0.01	0.01	0.01	0.01	0.01
14	0.01	0.01	0.01	0.01	0.01	0.01	0.01
15	0.01	0.01	0.01	0.01	0.01	0.01	0.01
16	0.01	0.02	0.01	0.01	0.02	0.02	0.02
17	0.01	0.01	0.01	0.01	0.01	0.01	0.01
18	0.01	0.01	0.01	0.01	0.01	0.01	0.01
19	0.01	0.01	0.01	0.01	0.01	0.01	0.01
20	0.01	0.01	0.01	0.01	0.01	0.01	0.01
21	0.01	0.01	0.01	0.01	0.01	0.01	0.01
22	0.01	0.01	0.01	0.01	0.01	0.01	0.01
23	0.01	0.01	0.01	0.01	0.01	0.01	0.01
24	0.01	0.01	0.01	0.01	0.01	0.01	0.01
25	0.01	0.01	0.01	0.02	0.01	0.01	0.02
26	0.01	0.01	0.01	0.01	0.01	0.01	0.01
27	0.01	0.01	0.01	0.01	0.01	0.01	0.01
28	0.01	0.01	0.01	0.01	0.01	0.01	0.01

Membrane Filtration	Monthly Summary (Answer Yes or No)	
95% of turbidity readings <= 1 NTU? (2) <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? <input checked="" type="radio"/> Yes / <input type="radio"/> No	All CL2 residuals at entry point >= 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings <= 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes:	PRINTED NAME: <i>Chris Germond</i>	
	SIGNATURE: <i>Chris Germond</i>	DATE: <i>3/4/26</i>
	PHONE #: <i>541-704-2309</i>	CERT #: <i>T-28682</i>

(1) Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. (2) Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B Month/Year: 2/2026

Date / Time	Minimum CL2 Residual @ 1st User (C) (1)	Contact Time (T)	Actual CT	Temp.	pH	Reqd. CT	CT Met? (1)	Peak Hourly Demand Flow (2)
	[ppm or mg/L]	[minutes]	C x T	[°C]		Use tables	Yes / No	[GPM]
1	0.84	166.5	139.9	8.3	8.10	31.5	Y	7,251
2	0.90	153.4	138.1	8.5	8.19	32.2	Y	7,552
3	0.70	179.8	125.9	8.3	8.10	30.8	Y	7,148
4	0.71	177.0	125.7	8.6	8.09	30.3	Y	6,687
5	0.56	189.4	106.1	8.3	8.08	30.2	Y	6,578
6	0.69	196.1	135.3	8.2	8.09	31.0	Y	6,433
7	0.62	184.6	114.5	8.2	8.09	30.6	Y	7,036
8	0.63	161.5	101.7	8.9	8.14	29.7	Y	7,897
9	0.29	160.5	46.5	9.2	8.12	28.0	Y	7,781
10	0.29	144.7	42.0	8.2	8.08	29.3	Y	7,003
11	0.97	155.2	150.5	7.4	8.10	33.9	Y	7,764
12	1.08	182.3	196.9	7.8	8.10	33.4	Y	6,378
13	1.12	197.8	221.5	8.4	9.48	53.5	Y	6,500
14	1.13	220.6	249.3	8.8	8.08	31.2	Y	6,139
15	0.97	167.8	162.8	9.1	8.11	30.3	Y	7,421
16	0.86	164.8	141.7	8.1	8.06	31.5	Y	7,666
17	0.84	175.1	147.1	7.5	8.03	32.3	Y	6,647
18	0.91	202.0	183.8	7.7	8.05	32.4	Y	6,195
19	0.98	176.5	173.0	7.8	8.05	32.3	Y	6,689
20	1.07	184.8	197.7	7.3	8.05	33.8	Y	7,038
21	1.02	187.8	191.6	7.9	8.05	32.3	Y	7,467
22	1.03	161.7	166.6	8.9	7.98	29.4	Y	7,217
23	0.79	155.0	122.5	9.1	8.05	29.1	Y	8,041
24	0.68	178.7	121.5	8.8	7.94	28.1	Y	7,004
25	0.69	150.9	104.1	9.2	7.94	27.3	Y	7,538
26	0.80	192.8	154.2	8.0	8.02	31.0	Y	6,741
27	1.13	192.4	217.4	8.0	8.09	33.0	Y	6,854
28	1.14	189.3	215.8	8.1	8.14	33.4	Y	6,874

We experienced a heavy rain event which affected the 9th and 10th free chlorine in the finish reservoir. We were able to get by by adjusting the free chlorine dosage higher. Had high turb peak 42 NTU, and high UV-254 raw at 0.272 cm⁻¹.

Signature: Chris Germond Date: 3/4/26
 Print Name: Chris Germond Cert #: T-08682

(1) If Cl2 at entry point < 0.2 mg/l. OR CT not met, notify DWP by end of next business day.
 (2) Prior to 11/2014, Peak Instantaneous Demand Flow is used.