

Membrane Filter Monthly Operating Report

County: **Linn**

System Name: **ALBANY, CITY OF**

PWS ID # **41-00012**

PlantID: **WTP-B**

Month/Year: **3/2026**

Minimum test pressure (applied || req'd): **18.2** psi || **11.4** psi

Day	CFE Daily Turbidity [NTU]	Highest CFE [NTU]	Highest IFE [NTU]	Highest PDR of the day [psi/min]	Lowest LRV of the day [log removal]	DIT Daily [Yes/No or Off]
1	0.011	0.019	0.023	0.58	4.24	Y
2	0.011	0.030	0.024	0.56	4.21	Y
3	0.011	0.017	0.022	0.56	4.30	Y
4	0.011	0.017	0.022	0.48	4.32	Y
5	0.011	0.015	0.023	0.49	4.31	Y
6	0.011	0.024	0.024	0.48	4.21	Y
7	0.011	0.015	0.022	0.49	4.29	Y
8	0.011	0.020	0.022	0.48	4.32	Y
9	0.011	0.015	0.022	0.48	4.28	Y
10	0.011	0.013	0.022	0.48	4.28	Y
11	0.011	0.017	0.022	0.48	4.29	Y
12	0.011	0.017	0.022	0.49	4.29	Y
13	0.012	0.017	0.030	0.48	4.15	Y
14	0.012	0.018	0.024	0.49	4.29	Y
15	0.011	0.015	0.022	0.49	4.29	Y
16	0.011	0.019	0.022	0.48	4.28	Y
17	0.011	0.015	0.022	0.48	4.12	Y
18	0.011	0.015	0.022	0.48	4.29	Y
19	0.011	0.015	0.022	0.46	4.31	Y
20	0.011	0.017	0.022	0.54	4.28	Y
21	0.011	0.015	0.022	0.55	4.30	Y
22	0.011	0.015	0.022	0.53	4.10	Y
23	0.011	0.015	0.022	0.53	4.28	Y
24	0.011	0.017	0.024	0.54	4.19	Y
25	0.011	0.015	0.022	0.54	4.30	Y
26	0.012	0.013	0.022	0.54	4.21	Y
27	0.012	0.035	0.022	0.54	4.24	Y
28	0.012	0.017	0.023	0.67	4.27	Y
29	0.011	0.013	0.024	0.54	4.31	Y
30	0.011	0.015	0.024	0.54	4.27	Y
31	0.011	0.015	0.023	0.52	4.19	Y

Compliance summary (operator to complete any blank fields)				
95% of daily turbidity readings $\leq$ 1 NTU? <input checked="" type="checkbox"/> / N]	All turbidity readings $\leq$ 5 NTU? <input checked="" type="checkbox"/> / N]	All IFE turbidity readings $\leq$ 0.15 NTU? <input checked="" type="checkbox"/> / N]	Performance std met? (PDR $\leq$ PDRMax, LRV $\geq$ LRC) <input checked="" type="checkbox"/> N]	DIT Daily? <input checked="" type="checkbox"/> / N]
CT's met daily? <input checked="" type="checkbox"/> / N]	All Cl2 residual at EP $\geq$ 0.2 mg/L? <input checked="" type="checkbox"/> / N]	PDR $\leq$ PDRMax (0.7 psi/min)? <input checked="" type="checkbox"/> / N]	LRVambient $\geq$ LRC (4.00)? <input checked="" type="checkbox"/> / N]	
PRINT NAME: <i>Chris Germond</i>		DATE: <i>4/3/26</i>		
SIGNATURE: <i>Chris Germond</i>		WT CERT #: <i>T-0662</i>		
NOTES:		PHONE #: <i>541-704-2309</i>		

**OHA - Drinking Water Program - Turbidity Monitoring Report Form    County: Linn**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: ALBANY, CITY OF    ID #: OR4100012    WTP--WTP-B

Month/Year: 3/2026

DAY	12 AM	4 AM	8 AM	NOON	4 PM	8 PM	Highest Reading of the Day (1)
	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]
1	0.01	0.01	0.01	0.01	0.01	0.01	0.01
2	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3	0.01	0.01	0.01	0.01	0.01	0.01	0.01
4	0.01	0.01	0.01	0.01	0.02	0.01	0.02
5	0.01	0.01	0.01	0.01	0.01	0.01	0.01
6	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7	0.01	0.01	0.01	0.01	0.01	0.01	0.01
8	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9	0.01	0.01	0.01	0.01	0.01	0.01	0.01
10	0.01	0.01	0.01	0.01	0.01	0.01	0.01
11	0.01	0.01	0.01	0.01	0.01	0.01	0.01
12	0.01	0.01	0.01	0.01	0.01	0.01	0.01
13	0.01	0.01	0.01	0.01	0.01	0.01	0.01
14	0.01	0.01	0.01	0.01	0.01	0.01	0.01
15	0.01	0.01	0.01	0.01	0.01	0.01	0.01
16	0.01	0.01	0.01	0.01	0.01	0.01	0.01
17	0.01	0.01	0.01	0.01	0.01	0.01	0.01
18	0.01	0.01	0.01	0.01	0.01	0.01	0.01
19	0.01	0.01	0.01	0.01	0.01	0.01	0.01
20	0.01	0.01	0.01	0.01	0.01	0.01	0.01
21	0.01	0.01	0.01	0.01	0.01	0.01	0.01
22	0.01	0.01	0.01	0.01	0.01	0.01	0.01
23	0.01	0.01	0.01	0.01	0.01	0.01	0.01
24	0.01	0.01	0.01	0.01	0.01	0.01	0.01
25	0.01	0.01	0.01	0.01	0.01	0.01	0.01
26	0.01	0.01	0.01	0.01	0.02	0.01	0.02
27	0.01	0.01	0.01	0.01	0.01	0.01	0.01
28	0.01	0.01	0.01	0.01	0.01	0.01	0.01
29	0.01	0.01	0.01	0.01	0.01	0.01	0.01
30	0.01	0.01	0.01	0.01	0.01	0.01	0.01
31	0.01	0.01	0.01	0.01	0.01	0.01	0.01

Membrane Filtration	Monthly Summary (Answer Yes or No)	
95% of turbidity readings <= 1 NTU? (2) <input checked="" type="radio"/> Yes / No	CT's met everyday? <input checked="" type="radio"/> Yes / No	All CL2 residuals at entry point >= 0.2 mg/l? <input checked="" type="radio"/> Yes / No
All daily turbidity readings <= 5 NTU? <input checked="" type="radio"/> Yes / No		
Notes:	PRINTED NAME: <i>Chris Germond</i>	
	SIGNATURE: <i>Chris Germond</i>	DATE: <i>4/3/26</i>
	PHONE #: <i>515-704-2309</i>	CERT #: <i>7-08682</i>

(1) Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. (2) Filtered systems only.

## OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: ALBANY, CITY OF ID #: OR4100012 WTP--WTP-B	Month/Year: 3/2026
---	--------------------

Date / Time	Minimum CL2 Residual @ 1st User (C) (1)	Contact Time (T)	Actual CT	Temp.	pH	Reqd. CT	CT Met? (1)	Peak Hourly Demand Flow (2)
	[ppm or mg/L]	[minutes]	C x T	[°C]		Use tables	Yes / No	[GPM]
1	1.11	154.3	171.3	8.6	8.11	31.8	Y	7,629
2	1.16	156.8	181.9	9.2	8.17	31.5	Y	7,121
3	1.04	163.0	169.5	9.8	8.17	29.9	Y	7,197
4	0.90	174.9	157.4	10.4	8.23	28.7	Y	7,380
5	0.84	203.1	170.6	9.8	8.19	29.3	Y	6,417
6	0.93	195.0	181.4	9.4	8.16	30.1	Y	6,574
7	0.99	183.5	181.7	10.2	8.16	28.7	Y	6,919
8	1.10	185.5	204.1	10.8	8.19	28.2	Y	6,954
9	1.13	152.3	172.1	10.1	8.21	29.9	Y	7,575
10	1.06	193.5	205.1	9.3	8.24	31.5	Y	7,101
11	1.08	142.2	153.6	9.3	8.25	31.7	Y	7,983
12	1.07	197.9	211.8	9.7	8.23	30.7	Y	6,524
13	0.91	175.4	159.6	10.0	8.17	29.0	Y	6,989
14	0.93	178.8	166.3	10.2	8.23	29.2	Y	7,101
15	0.91	153.9	140.0	8.9	8.17	31.3	Y	8,765
16	1.15	175.9	202.3	9.5	8.20	31.0	Y	6,890
17	1.04	173.0	179.9	10.1	8.15	28.9	Y	7,545
18	1.02	199.3	203.3	10.2	8.15	28.7	Y	6,889
19	0.96	181.4	174.1	10.7	8.17	27.8	Y	6,699
20	1.02	209.0	213.2	11.0	8.15	27.2	Y	6,195
21	1.07	178.1	190.6	11.5	8.19	26.8	Y	6,936
22	1.09	172.6	188.1	10.2	8.14	28.8	Y	7,225
23	1.06	153.7	162.9	10.3	8.15	28.7	Y	8,768
24	1.02	179.1	182.7	11.3	8.16	26.8	Y	6,751
25	1.01	158.1	159.7	11.2	8.14	26.7	Y	7,833
26	1.00	181.6	181.6	9.9	8.19	29.6	Y	6,366
27	0.99	159.0	157.4	10.2	8.22	29.4	Y	7,797
28	0.98	181.7	178.1	10.5	8.22	28.6	Y	6,845
29	0.94	170.1	159.9	10.8	8.22	28.0	Y	7,280
30	1.09	160.8	175.3	10.3	8.23	29.6	Y	7,264
31	1.02	109.6	111.8	10.9	8.25	28.3	Y	7,887

Signature: <u>Chris Germond</u>	Date: <u>4/3/26</u>
Print Name: <u>Chris Germond</u>	Cert #: <u>7-08682</u>

(1) If Cl2 at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.  
 (2) Prior to 11/2014, Peak Instantaneous Demand Flow is used.