

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Linn
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B

Month/Year: 9/2023

DAY	12 AM	4 AM	8 AM	NOON	4 PM	8 PM	Highest Reading of the Day (1)
	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]
1	0.02	0.02	0.02	0.02	0.02	0.02	0.02
2	0.02	0.02	0.02	0.02	0.02	0.02	0.02
3	0.02	0.02	0.02	0.02	0.02	0.02	0.02
4	0.02	0.02	0.02	0.02	0.02	0.02	0.02
5	0.02	0.02	0.02	0.02	0.02	0.02	0.02
6	0.02	0.02	0.02	0.02	0.02	0.02	0.02
7	0.02	0.02	0.02	0.02	0.02	0.02	0.02
8	0.02	0.02	0.02	0.02	0.02	0.02	0.02
9	0.02	0.02	0.02	0.02	0.02	0.02	0.02
10	0.02	0.02	0.02	0.02	0.02	0.02	0.02
11	0.02	0.02	0.02	0.02	0.02	0.02	0.02
12	0.02	0.02	0.02	0.02	0.02	0.02	0.02
13	0.02	0.02	0.02	0.02	0.02	0.02	0.02
14	0.02	0.02	0.02	0.02	0.02	0.02	0.02
15	0.02	0.02	0.02	0.02	0.02	0.02	0.02
16	0.02	0.02	0.02	0.02	0.02	0.02	0.02
17	0.02	0.02	0.02	0.02	0.02	0.02	0.02
18	0.02	0.02	0.02	0.02	0.02	0.02	0.02
19	0.02	0.02	0.02	0.02	0.02	0.02	0.02
20	0.02	0.02	0.02	0.02	0.02	0.02	0.02
21	0.02	0.02	0.02	0.02	0.02	0.02	0.02
22	0.02	0.02	0.02	0.02	0.02	0.02	0.02
23	0.02	0.02	0.02	0.02	0.02	0.02	0.02
24	0.02	0.02	0.02	0.02	0.02	0.02	0.02
25	0.02	0.02	0.02	0.02	0.02	0.02	0.02
26	0.02	0.02	0.02	0.02	0.02	0.02	0.02
27	0.02	0.02	0.02	0.02	0.02	0.02	0.02
28	0.02	0.02	0.02	0.02	0.02	0.02	0.02
29	0.02	0.02	0.02	0.02	0.02	0.02	0.02
30	0.02	0.02	0.02	0.02	0.02	0.02	0.02

Membrane Filtration	Monthly Summary (Answer Yes or No)	
95% of turbidity readings <= 1 NTU? (2)	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday?
All daily turbidity readings <= 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes:	PRINTED NAME: <i>Chris Germond</i>	
	SIGNATURE: <i>Chris Germond</i>	DATE: <i>10/4/23</i>
	PHONE #: <i>541-704-2309</i>	CERT #: <i>7-08682</i>

(1) Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. (2) Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B **Month/Year: 9/2023**

Date / Time	Minimum CL2 Residual @ 1st User (C) (1)	Contact Time (T)	Actual CT	Temp.	pH	Reqd. CT	CT Met? (1)	Peak Hourly Demand Flow (2)
	[ppm or mg/L]	[minutes]	C x T	[°C]		Use tables	Yes / No	[GPM]
1	0.96	171.3	164.4	12.1	8.18	25.3	Y	7,548
2	0.92	188.2	173.1	12.6	8.20	24.7	Y	6,845
3	0.86	194.6	167.4	13.0	8.14	23.3	Y	7,528
4	0.88	200.7	176.6	13.7	8.17	22.6	Y	7,246
5	0.91	169.2	154.0	12.1	8.18	25.1	Y	7,827
6	1.02	162.8	166.1	12.8	8.24	25.0	Y	8,113
7	1.04	160.5	166.9	13.3	8.21	23.9	Y	7,766
8	1.04	165.9	172.5	12.6	8.31	26.0	Y	8,131
9	0.95	187.0	177.7	13.2	8.31	24.8	Y	7,644
10	0.92	157.3	144.7	13.6	8.37	24.6	Y	8,569
11	1.00	167.3	167.3	13.5	8.38	25.1	Y	8,224
12	0.93	189.4	176.1	13.3	8.38	25.2	Y	7,879
13	0.98	150.5	147.5	13.9	8.37	24.3	Y	8,738
14	1.00	163.1	163.1	13.6	8.36	24.7	Y	8,584
15	0.97	159.6	154.8	13.6	8.28	23.9	Y	8,640
16	0.96	149.8	143.8	13.6	8.20	23.1	Y	8,595
17	0.98	159.3	156.1	13.4	8.23	23.7	Y	8,652
18	0.97	187.6	182.0	13.6	8.23	23.4	Y	7,564
19	0.94	188.1	176.8	12.8	8.18	24.3	Y	7,952
20	1.01	184.7	186.5	13.0	8.20	24.3	Y	7,849
21	0.93	165.5	153.9	12.2	8.19	25.2	Y	7,859
22	0.94	167.1	157.1	12.5	8.21	24.9	Y	7,599
23	0.98	178.4	174.8	12.8	8.26	25.0	Y	8,446
24	1.04	200.8	208.8	12.4	8.33	26.4	Y	7,207
25	1.04	213.1	221.6	12.4	8.25	25.6	Y	7,660
26	0.98	195.0	191.1	12.9	8.22	24.6	Y	7,400
27	1.00	169.0	169.0	13.6	8.24	23.6	Y	7,411
28	0.99	154.5	153.0	13.7	8.24	23.4	Y	8,211
29	1.00	190.2	190.2	14.0	8.24	23.0	Y	8,183
30	0.93	173.3	161.2	13.5	8.22	23.4	Y	7,969

Signature: Chris Germond Date: 10/4/23
 Print Name: Chris Germond Cert #: T-08682

(1) If Cl2 at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.
 (2) Prior to 11/2014, Peak Instantaneous Demand Flow is used.

Department of Human Services - Drinking Water Section

Membrane Integrity Report Form

Public Water System Name: Albany

PWS ID#: 41 00012 B

Month/Year:

9/ 2023

Albany/Millersburg Water Plant

Date	Membrane 1	Membrane 2	Membrane 3	Membrane 4
09/01/23	Pass	Pass	Pass	Pass
09/02/23	Pass	Pass	Pass	Pass
09/03/23	Pass	Pass	Pass	Pass
09/04/23	Pass	Pass	Pass	Pass
09/05/23	Pass	Pass	Pass	Pass
09/06/23	Pass	Pass	Pass	Pass
09/07/23	Pass	Pass	Pass	Pass
09/08/23	Pass	Pass	Pass	Pass
09/09/23	Pass	Pass	Pass	Pass
09/10/23	Pass	Pass	Pass	Pass
09/11/23	Pass	Pass	Pass	Pass
09/12/23	Pass	Pass	Pass	Pass
09/13/23	Pass	Pass	Pass	Pass
09/14/23	Pass	Pass	Pass	Pass
09/15/23	Pass	Pass	Pass	Pass
09/16/23	Pass	Pass	Pass	Pass
09/17/23	Pass	Pass	Pass	Pass
09/18/23	Pass	Pass	Pass	Pass
09/19/23	Pass	Pass	Pass	Pass
09/20/23	Pass	Pass	Pass	Pass
09/21/23	Pass	Pass	Pass	Pass
09/22/23	Pass	Pass	Pass	Pass
09/23/23	Pass	Pass	Pass	Pass
09/24/23	Pass	Pass	Pass	Pass
09/25/23	Pass	Pass	Pass	Pass
09/26/23	Pass	Pass	Pass	Pass
09/27/23	Pass	Pass	Pass	Pass
09/28/23	Pass	Pass	Pass	Pass
09/29/23	Pass	Pass	Pass	Pass
09/30/23	Pass	Pass	Pass	Pass

Signature: Chris Germond
 Print Name: Chris Germond

Date: 10/4/2023
 Cert. #: T-08682