

OHA - Drink Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems


County: CLATSOP
Month/Year: Nov, 2025

System Name: City of Astoria

ID#: 41-00055

WTP: WTP-A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day (1) [NTU]
01	0.06	0.06	0.06	0.06	0.06	0.07	0.07
02	0.07	0.06	0.06	0.07	0.07	0.08	0.08
03	0.07	0.07	0.07	0.07	0.07	0.07	0.07
04	0.07	0.07	0.07	0.07	0.07	0.07	0.08
05	0.07	0.07	0.07	0.07	0.06	0.06	0.07
06	0.06	0.06	0.06	0.06	0.07	0.06	0.07
07	0.06	0.06	0.06	0.06	0.06	0.06	0.07
08	0.06	0.06	0.06	0.06	0.06	0.06	0.06
09	0.06	0.06	0.06	0.06	0.07	0.07	0.07
10	0.06	0.06	0.06	0.06	0.06	0.06	0.06
11	0.06	0.06	0.05	0.05	0.06	0.06	0.06
12	0.06	0.05	0.05	0.05	0.05	0.05	0.06
13	0.05	0.05	0.05	0.05	0.05	0.06	0.06
14	0.05	0.05	0.05	0.05	0.05	0.05	0.05
15	0.05	0.05	0.05	0.05	0.05	0.05	0.05
16	0.05	0.05	0.05	0.05	0.05	0.05	0.05
17	0.05	0.05	0.05	0.05	0.05	0.05	0.05
18	0.05	0.05	0.05	0.05	0.05	0.05	0.05
19	0.05	0.04	0.04	0.04	0.04	0.04	0.05
20	0.04	0.04	0.04	0.04	0.04	0.04	0.04
21	0.04	0.04	0.04	0.04	0.04	0.04	0.04
22	0.04	0.04	0.04	0.04	0.04	0.04	0.04
23	0.04	0.04	0.04	0.04	0.04	0.04	0.04
24	0.04	0.04	0.04	0.04	0.04	0.04	0.04
25	0.04	0.04	0.04	0.04	0.04	0.04	0.04
26	0.04	0.04	0.04	0.04	0.05	0.05	0.06
27	0.05	0.05	0.05	0.05	0.06	0.11	0.18
28	0.17	0.23	0.05	0.05	0.05	0.05	0.27
29	0.05	0.04	0.04	0.04	0.04	0.04	0.05
30	0.04	0.04	0.04	0.04	0.04	0.04	0.04

Slow Sand / Membrane / DE Filtration / Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings =< 1 NTU? YES		CT's met everyday? (see back) YES	All CL2 residual at entry point >= 0.2 mg/L? YES
All daily turbidity readings =< 5 NTU? YES			
Notes:		PRINTED NAME: Nathan Bartlett	
		SIGNATURE: 	DATE: 12/9/2025
		PHONE #: (503)325-3524	CERT: T-08872

OHA - Drinking Water Services - Surface Water Quality Data Form
WTP : WTP-A
System Name: City of Astoria
ID#: 41-00055
Month/Year: Nov,2025
Disinfection Giardia Log
Inactiv:
1.0

Date / Time	Minimum CL2 Residual at 1st User (C)	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met	Peak Hourly Demand Flow
	[ppm]	[minutes]	C X T	[Celsius]		formula	Yes / No	[GPM]
01 / 4:12	1.7	146	247	10.63	6.97	40	YES	1292
02 / 10:20	1.71	127	217	11.35	6.98	38	YES	1481
03 / 1:39	1.67	127	212	11.11	6.97	38	YES	1483
04 / 18:02	1.66	143	238	10.91	6.99	39	YES	1314
05 / 13:03	1.72	156	269	11.03	6.97	39	YES	1204
06 / 14:54	1.74	97	169	11.05	6.98	39	YES	1941
07 / 6:39	1.75	119	208	10.76	6.98	40	YES	1578
08 / 7:32	1.81	120	217	10.45	6.99	41	YES	1565
09 / 21:39	1.85	120	222	10.54	6.98	41	YES	1564
10 / 15:19	1.82	120	219	10.7	6.96	40	YES	1564
11 / 4:00	1.81	120	218	10.39	7.02	41	YES	1561
12 / 0:23	1.81	121	218	10.39	7.01	41	YES	1559
13 / 6:59	1.76	120	211	10.44	7.01	41	YES	1566
14 / 1:39	1.75	120	210	10.82	7	40	YES	1569
15 / 11:43	1.72	120	207	10.92	7.01	40	YES	1565
16 / 23:38	1.72	121	208	10.89	7.01	40	YES	1556
17 / 8:39	1.69	120	204	10.65	7.01	40	YES	1561
18 / 14:43	1.74	120	209	10.06	7.04	42	YES	1565
19 / 0:22	1.81	120	218	9.32	7.04	45	YES	1564
20 / 9:08	1.69	120	203	9.32	7.08	45	YES	1562
21 / 15:09	1.59	120	191	9.39	7.09	44	YES	1564
22 / 9:58	1.59	120	191	9.45	7.09	44	YES	1565
23 / 21:44	1.57	120	189	9.55	7.09	44	YES	1563
24 / 9:29	1.56	121	188	9.16	7.09	45	YES	1560
25 / 2:55	1.68	120	202	8.8	7.1	47	YES	1565
26 / 1:14	1.48	121	178	8.81	7.09	45	YES	1559
27 / 21:14	1.48	120	178	9.19	7.07	44	YES	1563
28 / 21:52	1.5	120	180	9.59	7.06	43	YES	1566
29 / 0:53	1.52	120	183	9.34	7.07	44	YES	1563
30 / 0:54	1.59	121	192	9.22	7.07	44	YES	1558

If CL2 at entry point < 0.2 mg/L or CT not met, notify DWS within 24 hours.