

**OHA - Drink Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**


**County:** CLATSOP  
**Month/Year:** Feb, 2026

**System Name:** City of Astoria

**ID#:** 41-00055

**WTP:** WTP-A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day (1) [NTU]
01	0.04	0.04	0.03	0.03	0.03	0.04	0.04
02	0.04	0.04	0.04	0.03	0.04	0.04	0.04
03	0.04	0.04	0.04	0.04	0.04	0.04	0.09
04	0.04	0.04	0.04	0.34	0.45	0.57	0.6
05	0.47	0.42	0.4	0.38	0.43	0.5	0.52
06	0.46	0.42	0.41	0.38	0.24	0.33	0.47
07	0.37	0.37	0.35	0.33	0.36	0.42	0.49
08	0.43	0.47	0.46	0.42	0.47	0.52	0.63
09	0.59	0.58	0.53	0.53	0.7	0.67	0.76
10	0.67	0.59	0.56	0.55	0.72	0.55	0.78
11	0.53	0.48	0.45	0.41	0.64	0.7	0.71
12	0.58	0.51	0.5	0.48	0.54	0.62	0.63
13	0.56	0.5	0.48	0.46	0.5	0.53	0.57
14	0.5	0.48	0.47	0.46	0.52	0.61	0.61
15	0.54	0.47	0.45	0.44	0.49	0.59	0.6
16	0.44	0.37	0.35	0.34	0.38	0.43	0.44
17	0.39	0.35	0.34	0.33	0.39	0.45	0.46
18	0.4	0.36	0.34	0.34	0.04	0.04	0.46
19	0.03	0.03	0.03	0.03	0.04	0.04	0.04
20	0.03	0.03	0.03	0.03	0.03	0.04	0.04
21	0.03	0.03	0.03	0.03	0.03	0.04	0.04
22	0.03	0.03	0.03	0.33	0.34	0.36	0.38
23	0.38	0.37	0.37	0.43	0.43	0.43	0.5
24	0.44	0.43	0.43	0.42	0.31	0.27	0.62
25	0.26	0.23	0.39	0.37	0.37	0.37	0.39
26	0.37	0.35	0.34	0.32	0.33	0.36	0.37
27	0.36	0.34	0.32	0.31	0.32	0.35	0.36
28	0.34	0.32	0.31	0.29	0.3	0.32	0.35

<b>Slow Sand / Membrane / DE Filtration / Unfiltered</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings =< 1 NTU? <b>YES</b>		CT's met everyday? (see back) <b>YES</b>	All CL2 residual at entry point >= 0.2 mg/L? <b>YES</b>
All daily turbidity readings =< 5 NTU? <b>YES</b>			
<b>Notes:</b>		<b>PRINTED NAME:</b> Nathan Bartlett	
		<b>SIGNATURE:</b> 	<b>DATE:</b> 3/2/2026
		<b>PHONE #:</b> (503)325-3524	<b>CERT:</b> T-08872

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP : WTP-A

System Name: City of Astoria

ID#: 41-00055

Month/Year: Feb,2026

Disinfection Giardia Log

Inactiv:

1.0

Date / Time	Minimum CL2 Residual at 1st User (C)	Contact Time (T)	Actual CT C X T	Temp [Celsius}	pH	Required CT formula	CT Met Yes / No	Peak Hourly Demand Flow [GPM]
01 / 22:23	1.66	143	237	8.6	7.38	52	YES	1318
02 / 13:39	1.67	119	198	8.72	7.36	51	YES	1582
03 / 9:46	1.73	125	217	8.7	7.38	52	YES	1500
04 / 18:04	1.74	90	156	8.82	7.39	52	YES	2095
05 / 20:56	1.78	89	159	9.2	7.41	51	YES	2106
06 / 3:00	1.74	89	155	9	7.42	52	YES	2110
07 / 2:15	1.46	109	159	9.01	7.37	49	YES	1728
08 / 3:42	1.43	142	204	9.12	7.38	49	YES	1320
09 / 9:01	1.78	142	254	8.78	7.34	51	YES	1320
10 / 0:02	1.74	144	250	8.43	7.34	52	YES	1308
11 / 20:24	1.76	143	251	8.51	7.38	53	YES	1318
12 / 14:13	1.93	145	280	8.38	7.4	55	YES	1296
13 / 11:11	1.73	146	253	8.5	7.42	54	YES	1287
14 / 17:47	1.65	142	234	8.17	7.43	55	YES	1326
15 / 10:48	1.66	147	245	8.14	7.45	55	YES	1276
16 / 2:32	1.69	146	247	7.69	7.47	57	YES	1285
17 / 7:42	1.7	146	249	7.17	7.46	59	YES	1286
18 / 23:18	1.71	146	250	7.11	7.46	60	YES	1287
19 / 1:39	1.86	146	272	6.96	7.49	62	YES	1284
20 / 15:59	1.71	144	246	6.78	7.5	62	YES	1308
21 / 16:20	1.71	157	269	6.87	7.51	62	YES	1195
22 / 3:40	1.71	157	269	7.08	7.5	61	YES	1195
23 / 8:57	1.73	119	205	7.75	7.44	57	YES	1583
24 / 20:19	1.72	128	220	7.76	7.45	57	YES	1473
25 / 10:28	1.79	127	227	7.55	7.45	58	YES	1481
26 / 1:57	1.89	125	236	7.71	7.46	59	YES	1503
27 / 2:28	1.93	125	241	8.03	7.44	57	YES	1506
28 / 16:17	1.94	125	242	7.82	7.44	58	YES	1506

If CL2 at entry point < 0.2 mg/L or CT not met, notify DWS within 24 hours.