

OHA - Drink Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems


County: CLATSOP
Month/Year: Mar, 2026

System Name: City of Astoria

ID#: 41-00055

WTP: WTP-A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day (1) [NTU]
01	0.31	0.3	0.3	0.29	0.31	0.34	0.35
02	0.33	0.33	0.32	0.15	0.16	0.28	0.34
03	0.27	0.27	0.19	0.18	0.18	0.21	0.29
04	0.19	0.18	0.18	0.19	0.21	0.24	0.25
05	0.22	0.22	0.21	0.22	0.22	0.31	0.33
06	0.29	0.26	0.26	0.25	0.27	0.32	0.33
07	0.28	0.26	0.27	0.27	0.32	0.54	0.56
08	0.46	0.43	0.41	0.39	0.45	0.51	0.53
09	0.5	0.43	0.39	0.37	0.55	0.62	0.65
10	0.6	0.48	0.43	0.25	0.29	0.38	0.61
11	0.37	0.3	0.28	0.39	0.42	0.49	0.53
12	0.53	0.54	0.56	0.57	0.62	0.79	0.81
13	0.77	0.35	0.36	0.36	0.4	0.49	0.78
14	0.51	0.53	0.54	0.52	0.3	0.14	0.6
15	0.13	0.12	0.12	0.13	0.11	0.09	0.16
16	0.07	0.06	0.06	0.06	0.07	0.07	0.08
17	0.07	0.07	0.07	0.04	0.05	0.05	0.1
18	0.04	0.04	0.04	0.04	0.04	0.04	0.06
19	0.04	0.04	0.04	0.51	0.52	0.53	0.55
20	0.54	0.54	0.54	0.52	0.62	0.64	0.95
21	0.64	0.6	0.56	0.52	0.52	0.55	0.65
22	0.53	0.48	0.43	0.4	0.41	0.48	0.54
23	0.47	0.44	0.41	0.28	0.29	0.32	0.48
24	0.31	0.3	0.29	0.28	0.31	0.34	0.36
25	0.33	0.31	0.29	0.29	0.35	0.38	0.41
26	0.35	0.31	0.28	0.24	0.3	0.37	0.4
27	0.33	0.28	0.25	0.24	0.34	0.46	0.49
28	0.37	0.29	0.26	0.26	0.4	0.48	0.5
29	0.39	0.31	0.26	0.26	0.33	0.35	0.41
30	0.31	0.28	0.25	0.25	0.3	0.32	0.34
31	0.31	0.3	0.3	0.26	0.28	0.28	0.32

Slow Sand / Membrane / DE Filtration / Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings =< 1 NTU? YES	CT's met everyday? (see back) YES	All CL2 residual at entry point >= 0.2 mg/L? YES
All daily turbidity readings =< 5 NTU? YES		
Notes:	PRINTED NAME: Nathan Bartlett	
	SIGNATURE: 	DATE: 4/6/2026
	PHONE #: (503)325-3524	CERT: T-08872

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP : WTP-A

System Name: City of Astoria ID#: 41-00055 Month/Year: Mar,2026 Disinfection Giardia Log Inactiv: 1.0

Date / Time	Minimum CL2 Residual at 1st User (C)	Contact Time (T)	Actual CT C X T	Temp [Celsius}	pH	Required CT formula	CT Met Yes / No	Peak Hourly Demand Flow [GPM]
01 / 12:30	1.93	127	245	8.05	7.47	58	YES	1480
02 / 22:03	1.88	120	225	8.66	7.43	54	YES	1570
03 / 10:29	1.72	120	207	8.8	7.47	53	YES	1561
04 / 12:33	1.62	120	195	9.21	7.45	51	YES	1562
05 / 22:28	1.56	109	170	8.86	7.44	52	YES	1725
06 / 8:01	1.68	109	183	8.8	7.41	52	YES	1725
07 / 1:47	1.83	109	199	8.99	7.4	52	YES	1726
08 / 3:50	1.76	125	220	9.54	7.33	49	YES	1506
09 / 12:10	1.53	121	185	8.31	7.34	52	YES	1553
10 / 16:59	1.93	157	304	7.33	7.35	58	YES	1195
11 / 11:44	1.89	157	298	7.5	7.37	57	YES	1194
12 / 21:13	1.83	157	287	7.97	7.33	54	YES	1198
13 / 3:35	1.79	157	281	8.69	7.33	52	YES	1197
14 / 9:43	1.79	157	281	8.81	7.32	51	YES	1197
15 / 0:45	1.75	157	275	8.87	7.29	50	YES	1195
16 / 0:23	1.8	158	284	8.82	7.36	52	YES	1193
17 / 10:06	1.85	134	248	9.4	7.32	49	YES	1405
18 / 13:49	1.72	146	251	9.59	7.37	49	YES	1288
19 / 11:59	1.84	147	270	9.74	7.36	49	YES	1282
20 / 19:46	1.81	126	229	9.9	7.35	48	YES	1488
21 / 17:22	1.87	125	233	9.56	7.36	50	YES	1506
22 / 19:20	1.94	126	245	8.62	7.38	54	YES	1490
23 / 11:45	1.77	118	208	8.44	7.4	54	YES	1600
24 / 10:02	1.78	109	195	8.72	7.39	53	YES	1719
25 / 11:20	1.78	104	184	9.02	7.39	52	YES	1816
26 / 20:04	1.79	120	215	8.33	7.41	54	YES	1564
27 / 18:50	1.79	120	214	8.44	7.43	54	YES	1573
28 / 4:15	1.79	121	216	8.98	7.42	52	YES	1558
29 / 22:39	1.82	121	220	9.12	7.36	51	YES	1557
30 / 10:29	1.78	105	187	8.62	7.46	54	YES	1786
31 / 17:05	1.77	120	213	8.77	7.47	54	YES	1562

If CL2 at entry point < 0.2 mg/L or CT not met, notify DWS within 24 hours.