

MONTH / YEAR: February 2021

System Name: Youngs River Lewis & Clark Water District **System ID # 4100062**

Day	4AM NTU	8 AM NTU	Noon NTU	4 PM NTU	8 PM NTU	12:00 AM NTU	Highest Reading	Peak Hourly Flow
1	0.030	0.030	0.030	0.030	0.030	0.030	0.030	163
2	0.030	0.029	0.029	0.030	0.030	0.029	0.030	231
3	0.029	0.030	0.030	0.029	0.029	0.029	0.030	229
4	0.030	0.029	0.028	0.028	0.029	0.029	0.030	229
5	0.029	0.029	0.029	0.029	0.029	0.030	0.030	122
6	0.030	0.029	0.029	0.028	0.028	0.028	0.030	164
7	0.029	0.029	0.029	0.029	0.029	0.029	0.029	148
8	0.029	0.030	0.029	0.028	0.030	0.028	0.030	148
9	0.028	0.028	0.030	0.031	0.028	0.028	0.031	153
10	0.030	0.028	0.028	0.029	0.031	0.028	0.031	248
11	0.053	0.029	0.028	0.030	0.033	0.028	0.053	212
12	0.029	0.029	0.029	0.029	0.028	0.029	0.029	212
13	0.034	0.029	0.029	0.030	0.030	0.030	0.034	201
14	0.029	0.029	0.029	0.029	0.030	0.029	0.030	193
15	0.029	0.029	0.029	0.029	0.029	0.029	0.029	128
16	0.029	0.030	0.030	0.029	0.028	0.029	0.030	125
17	0.029	0.029	0.030	0.029	0.029	0.029	0.030	154
18	0.029	0.029	0.029	0.029	0.028	0.029	0.029	163
19	0.028	0.028	0.030	0.028	0.029	0.028	0.030	236
20	0.029	0.028	0.029	0.029	0.028	0.028	0.029	255
21	0.030	0.028	0.029	0.028	0.028	0.029	0.030	243
22	0.029	0.029	0.029	0.030	0.030	0.032	0.032	209
23	0.030	0.030	0.029	0.030	PAUSE	PAUSE	0.030	197
24	0.029	PAUSE	0.029	0.029	0.028	0.029	0.029	133
25	0.029	0.032	0.028	0.028	0.029	0.029	0.032	125
26	0.029	0.030	0.028	0.029	0.028	0.028	0.030	130
27	0.029	0.030	0.028	0.029	0.029	0.028	0.030	150
28	0.028	0.029	0.028	0.029	0.028	0.028	0.029	162
29								
30								
31								
Average							0.031	181

95% of Turb readings <.5 MCL

YES / NO

CT's meet everyday

YES / NO

Cl. Residual at entry point always: >.2

mg/l YES / NO

All Turbidity readings < 5 NTU

YES / NO

Cl2 Measured in 95% of the

distribution system YES / NO

Are you using a Slow Sand or Cartridge Filter YES / NO

MCL is .5 for conventional and direct filtration

MCL is 1 for slow sand and diatomaceous earth filters

Phone (503) 325-4330

Name print Carl Gifford

Signature 

Date: April / 8th / 2021

Certification #: T-08408

