


OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Clatsop
 Month/Year: Apr-22

System Name: Wickiup Water District ID#: 41- 00063 WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.35				0.35
2			0.21				0.21
3			0.23				0.23
4			0.16				0.16
5			0.24				0.24
6			0.18				0.18
7			0.15				0.15
8			0.22				0.22
9			0.24				0.24
10			0.32				0.32
11			0.36				0.36
12			0.37				0.37
13			0.34				0.34
14			0.11				0.11
15			0.16				0.16
16			0.32				0.32
17			0.17				0.17
18			0.13				0.13
19			0.33				0.33
20			0.22				0.22
21			0.27				0.27
22			0.31				0.31
23			0.34				0.34
24			0.26				0.26
25			0.29				0.29
26			0.36				0.36
27			0.26				0.26
28			0.29				0.29
29			0.12				0.12
30			0.12				0.12
31							0.00

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No

Notes:	PRINTED NAME: Dan Waterbury	
	SIGNATURE: 	DATE: 5/10/2022
	PHONE #: (503)791-5751	CERT #: T-08798

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :A

System Name: Wickiup Water District ID#: 41-00063

Month/Year: Apr-22

Disinfection *Giardia* Log

Inactiv:

1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T			formula	Yes / No	[GPM]
1	1.09	149	162.4	9.2	8.48	69.7	YES	
2	0.78	149	116.2	9.2	8.27	62.3	YES	
3	0.79	149	117.7	9.3	8.28	62.2	YES	
4	0.84	149	125.2	9.3	8.25	61.9	YES	
5	1.16	149	172.8	8.7	8.40	70.7	YES	
6	1.24	149	184.8	7.8	8.56	80.5	YES	
7	0.91	149	135.6	9.0	8.61	72.6	YES	
8	1.01	149	150.5	9.9	8.71	71.6	YES	
9	1.2	149	178.8	9.7	8.64	72.4	YES	
10	1.22	149	181.8	9.7	8.67	73.4	YES	
11	1.27	149	189.2	8.4	8.64	79.8	YES	
12	1.09	149	162.4	7.9	8.72	83.3	YES	
13	1.06	149	157.9	7.5	8.58	81.0	YES	
14	1.23	149	183.3	7.7	8.59	81.9	YES	
15	1.23	149	183.3	6.4	8.87	99.4	YES	
16	1.69	149	251.8	7.8	8.88	95.6	YES	
17	1.8	149	268.2	7.2	9.09	109.3	YES	
18	1.23	149	183.3	8.9	8.70	78.5	YES	
19	1.79	149	266.7	8.5	8.93	93.9	YES	
20	1.81	149	269.7	7.6	9.06	105.2	YES	
21	1.31	149	195.2	9.0	8.70	78.7	YES	
22	1.72	149	256.3	8.1	9.00	98.2	YES	
23	1.79	149	266.7	8.0	8.96	98.3	YES	
24	1.92	149	286.1	9.0	9.00	94.5	YES	
25	1.26	149	187.7	10.1	8.63	70.7	YES	
26	1.98	149	295.0	10.1	8.86	83.7	YES	
27	1.16	149	172.8	10.4	8.41	63.1	YES	
28	1.69	149	251.8	9.1	8.86	86.7	YES	
29	1.15	149	171.4	10.7	8.45	62.7	YES	
30	1.78	149	265.2	11.0	8.89	77.7	YES	
31		149						

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350