


OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Clatsop
 Month/Year: Dec-22

System Name: Wickiup Water District ID#: 41- 00063 WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.01				0.01
2			0.01				0.01
3			0.01				0.01
4			Off				Off
5			0.14				0.14
6			0.19				0.19
7			0.13				0.13
8			0.01				0.01
9			0.12				0.12
10			0.04				0.04
11			0.20				0.20
12			0.21				0.21
13			0.20				0.20
14			0.34				0.34
15			0.27				0.27
16			0.19				0.19
17			0.23				0.23
18			0.21				0.21
19			0.46				0.46
20			0.46				0.46
21			0.10				0.10
22			0.27				0.27
23			0.35				0.35
24			0.38				0.38
25			0.06				0.06
26			0.14				0.14
27			0.25				0.25
28			0.19				0.19
29			0.01				0.01
30			0.21				0.21
31			0.23				0.23

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes:		PRINTED NAME: Dan Waterbury	
		SIGNATURE: 	DATE: 1/07/2023
		PHONE #: (503)791-5751	CERT #: T-08798

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :A

System Name: Wickiup Water District ID#: 41-00063

Month/Year: Dec-22

Disinfection *Giardia* Log Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T			formula	Yes / No	[GPM]
1	1.33	149	198.2	5.8	7.95	74.6	YES	65
2	0.99	149	147.5	5.6	8.79	99.2	YES	58
3	1.34	149	199.7	6.8	8.81	95.8	YES	46
4	0.89	149	132.6	7.4	8.52	78.2	YES	59
5	0.77	149	114.7	8.6	8.30	65.5	YES	74
6	1.26	149	187.7	6.1	8.58	91.5	YES	64
7	1.59	149	236.9	6.1	8.47	91.3	YES	68
8	1.34	149	199.7	6.4	8.41	84.9	YES	76
9	1.18	149	175.8	6.7	8.28	77.8	YES	77
10	0.78	149	116.2	7.5	8.14	66.7	YES	84
11	0.92	149	137.1	7.3	8.02	65.8	YES	56
12	0.76	149	113.2	6.6	8.03	68.0	YES	43
13	1.22	149	181.8	6.5	8.02	72.0	YES	45
14	1.05	149	156.5	6.0	8.01	72.8	YES	43
15	1.22	149	181.8	7.4	7.98	66.7	YES	48
16	1.3	149	193.7	7.5	7.88	64.5	YES	54
17	1.26	149	187.7	7.4	7.96	66.6	YES	56
18	1.3	149	193.7	7.4	8.02	68.4	YES	58
19	1.3	149	193.7	6.5	7.82	67.6	YES	57
20	1.02	149	152.0	7.9	7.90	61.2	YES	50
21	0.91	149	135.6	7.2	7.94	64.3	YES	57
22	0.9	149	134.1	6.7	7.92	66.0	YES	58
23	1.13	149	168.4	4.4	7.81	76.3	YES	68
24	1.13	149	168.4	5.8	7.86	70.5	YES	80
25	0.8	149	119.2	5.9	7.92	68.9	YES	84
26	0.86	149	128.1	6.6	7.91	65.9	YES	82
27	0.71	149	105.8	7.9	7.91	59.3	YES	75
28	0.69	149	102.8	7.0	7.83	61.1	YES	70
29	0.74	149	110.3	7.3	8.00	64.0	YES	64
30	0.8	149	119.2	8.5	8.22	64.3	YES	65
31	0.81	149	120.7	8.3	8.21	65.0	YES	66

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350