


OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Clatsop
 Month/Year: May-24

System Name: Wickiup Water District ID#: 41- 00063 WTP : TP - A

| Day | 12 AM [NTU] | 4 AM [NTU] | 8 AM [NTU] | NOON [NTU] | 4 PM [NTU] | 8 PM [NTU] | Highest Reading of the day ¹ [NTU] |
|-----|-------------|------------|------------|------------|------------|------------|---|
| 1 | | | 0.01 | | | | 0.01 |
| 2 | | | 0.01 | | | | 0.01 |
| 3 | | | 0.01 | | | | 0.01 |
| 4 | | | 0.01 | | | | 0.01 |
| 5 | | | 0.01 | | | | 0.01 |
| 6 | | | 0.01 | | | | 0.01 |
| 7 | | | 0.01 | | | | 0.01 |
| 8 | | | 0.01 | | | | 0.01 |
| 9 | | | 0.01 | | | | 0.01 |
| 10 | | | 0.01 | | | | 0.01 |
| 11 | | | 0.01 | | | | 0.01 |
| 12 | | | 0.01 | | | | 0.01 |
| 13 | | | 0.01 | | | | 0.01 |
| 14 | | | 0.01 | | | | 0.01 |
| 15 | | | 0.01 | | | | 0.01 |
| 16 | | | 0.01 | | | | 0.01 |
| 17 | | | 0.01 | | | | 0.01 |
| 18 | | | 0.01 | | | | 0.01 |
| 19 | | | 0.01 | | | | 0.01 |
| 20 | | | 0.01 | | | | 0.01 |
| 21 | | | 0.01 | | | | 0.01 |
| 22 | | | 0.01 | | | | 0.01 |
| 23 | | | 0.01 | | | | 0.01 |
| 24 | | | 0.01 | | | | 0.01 |
| 25 | | | 0.01 | | | | 0.01 |
| 26 | | | 0.01 | | | | 0.01 |
| 27 | | | 0.01 | | | | 0.01 |
| 28 | | | 0.01 | | | | 0.01 |
| 29 | | | 0.01 | | | | 0.01 |
| 30 | | | 0.01 | | | | 0.01 |
| 31 | | | 0.01 | | | | 0.01 |

| | | | |
|--|--|---|--|
| Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="radio"/> Yes / <input type="radio"/> No All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No | | Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No | |
| Notes: | | PRINTED NAME: Dan Waterbury SIGNATURE:  PHONE #: (503) 791-5751 DATE: 6/03/2024 CERT #: T-08798 | |

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :A
 Disinfection *Giardia* Log
 Inactiv: 1.0

System Name: Wickiup Water District ID#: 41-00063 Month/Year: May-24

| Date / Time | Minimum Cl ₂ Residual at 1st User (C) ³ | Contact Time (T) | Actual CT | Temp | pH | Required CT | CT Met? ³ | Peak Hourly Demand Flow |
|-------------|---|------------------|-----------|------|------|-------------|----------------------|-------------------------|
| | [ppm or mg/L] | [minutes] | C X T | | | formula | Yes / No | [GPM] |
| 1 | 1.01 | 149 | 150.5 | 10.3 | 8.28 | 59.6 | YES | 60 |
| 2 | 1.23 | 149 | 183.3 | 9.4 | 8.24 | 64.1 | YES | 55 |
| 3 | 1.17 | 149 | 174.3 | 10.6 | 8.37 | 61.5 | YES | 65 |
| 4 | 0.74 | 149 | 110.3 | 10.5 | 8.22 | 55.8 | YES | 50 |
| 5 | 0.81 | 149 | 120.7 | 10.2 | 7.83 | 49.9 | YES | 52 |
| 6 | 1.28 | 149 | 190.7 | 10.8 | 8.35 | 61.0 | YES | 56 |
| 7 | 1.36 | 149 | 202.6 | 10.6 | 8.23 | 59.7 | YES | 76 |
| 8 | 0.65 | 149 | 96.9 | 10.0 | 8.27 | 58.1 | YES | 74 |
| 9 | 1.14 | 149 | 169.9 | 10.9 | 8.27 | 57.9 | YES | 68 |
| 10 | 0.69 | 149 | 102.8 | 11.5 | 8.33 | 53.9 | YES | 58 |
| 11 | 0.96 | 149 | 143.0 | 12.8 | 8.42 | 53.0 | YES | 64 |
| 12 | 0.95 | 149 | 141.6 | 12.3 | 8.36 | 53.2 | YES | 61 |
| 13 | 0.87 | 149 | 129.6 | 12.7 | 8.24 | 49.4 | YES | 75 |
| 14 | 0.99 | 149 | 147.5 | 12.1 | 8.49 | 56.8 | YES | 77 |
| 15 | 0.93 | 149 | 138.6 | 12.0 | 8.53 | 57.6 | YES | 75 |
| 16 | 1.37 | 149 | 204.1 | 12.8 | 8.24 | 51.9 | YES | 200 |
| 17 | 1.24 | 149 | 184.8 | 12.7 | 8.20 | 50.8 | YES | 77 |
| 18 | 0.79 | 149 | 117.7 | 13.5 | 8.16 | 45.1 | YES | 76 |
| 19 | 1.46 | 149 | 217.5 | 12.6 | 8.14 | 51.3 | YES | 58 |
| 20 | 0.83 | 149 | 123.7 | 13.0 | 8.08 | 45.5 | YES | 62 |
| 21 | 1.09 | 149 | 162.4 | 12.7 | 8.48 | 55.3 | YES | 63 |
| 22 | 1.05 | 149 | 156.5 | 12.1 | 8.03 | 48.5 | YES | 45 |
| 23 | 0.87 | 149 | 129.6 | 12.0 | 8.04 | 48.0 | YES | 56 |
| 24 | 0.77 | 149 | 114.7 | 11.9 | 7.88 | 45.2 | YES | 55 |
| 25 | 1.4 | 149 | 208.6 | 12.4 | 8.19 | 52.4 | YES | 68 |
| 26 | 1.16 | 149 | 172.8 | 12.6 | 8.29 | 52.4 | YES | 62 |
| 27 | 0.83 | 149 | 123.7 | 12.5 | 8.07 | 46.8 | YES | 63 |
| 28 | 0.71 | 149 | 105.8 | 12.0 | 8.31 | 51.9 | YES | 66 |
| 29 | 1.3 | 149 | 193.7 | 12.3 | 8.35 | 55.2 | YES | 68 |
| 30 | 0.91 | 149 | 135.6 | 11.4 | 7.99 | 49.3 | YES | 64 |
| 31 | 1.1 | 149 | 163.9 | 11.3 | 8.02 | 51.3 | YES | 58 |

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350