


OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Clatsop  
 Month/Year: Feb-24

Conventional or Direct Filtration

System Name:	Wickiup Water District		ID#: 41-00063				WTP : TP -	B
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]	
1	Off	Off	0.025	0.029	0.034	Off	0.034	
2	Off	0.034	0.022	Off	Off	Off	0.034	
3	0.032	0.033	0.022	Off	0.020	Off	0.033	
4	Off	Off	Off	0.032	0.032	0.031	0.032	
5	Off	Off	Off	0.026	0.030	0.042	0.042	
6	Off	Off	Off	0.026	0.028	Off	0.028	
7	Off	Off	Off	0.022	0.027	0.030	0.030	
8	Off	Off	Off	0.017	0.020	Off	0.020	
9	Off	Off	Off	Off	0.021	0.025	0.025	
10	0.026	Off	Off	Off	0.019	0.022	0.026	
11	0.035	Off	Off	0.016	0.025	0.023	0.035	
12	0.026	Off	Off	0.034	0.021	0.022	0.034	
13	Off	Off	0.037	0.033	0.039	0.021	0.039	
14	Off	Off	Off	0.038	0.044	0.043	0.044	
15	0.093	Off	Off	0.032	0.035	0.045	0.093	
16	0.028	Off	Off	0.053	0.043	0.028	0.053	
17	Off	Off	Off	0.036	0.042	0.068	0.068	
18	0.029	Off	Off	0.047	0.042	0.027	0.047	
19	Off	Off	Off	0.047	0.026	0.037	0.047	
20	0.033	Off	Off	0.047	0.026	0.028	0.047	
21	Off	Off	0.036	0.047	0.045	0.033	0.047	
22	Off	Off	Off	0.040	0.050	0.050	0.050	
23	Off	Off	Off	0.047	0.057	0.045	0.057	
24	Off	Off	Off	0.036	0.036	0.050	0.050	
25	0.053	Off	Off	0.049	0.032	0.042	0.053	
26	0.210	0.052	Off	0.048	0.060	0.055	0.210	
27	0.072	0.036	0.035	0.034	0.039	0.043	0.072	
28	0.066	0.048	0.065	Off	Off	Off	0.066	
29	0.052	0.055	Off	0.090	0.047	0.044	0.090	
30								
31								

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? All 4-hour turbidity readings ≤ 1 NTU? All turbidity readings < IFE <sup>2</sup> triggers	CT's met everyday? (see back)  Yes/No	All Cl2 residual at entry point ≥ 0.2 mg/l?  Yes/No

Notes:	PRINTED NAME: Dan Waterbury	
	SIGNATURE: 	DATE: 3/08/24
	PHONE #: (503) 791-5751	CERT #: T-08798

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

<b>System Name:</b> Wickiup Water District	<b>ID#:</b> 41-00063	<b>Month/Year:</b> Feb-24	<b>WTP - :B</b>
			<b>Disinfection <i>Giardia</i> Log Inactive:</b> 1

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	GPM
1	1.63	241	392.8	9.5	7.91	59.2	YES	140
2	1.62	241	390.4	9.8	7.79	55.5	YES	136
3	1.57	241	378.4	8.8	7.81	59.4	YES	129
4	1.48	241	356.7	8.5	7.84	60.7	YES	133
5	1.69	241	407.3	8.4	7.87	63.3	YES	145
6	1.37	241	330.2	8.3	7.91	62.3	YES	132
7	1.71	241	412.1	7.7	8.03	70.5	YES	190
8	1.56	241	376.0	7.8	7.99	67.8	YES	178
9	1.64	241	395.2	7.6	7.95	68.4	YES	178
10	1.65	241	397.7	7.2	7.97	70.9	YES	180
11	1.48	241	356.7	7.3	7.99	69.5	YES	178
12	1.49	241	359.1	7.4	8.05	70.7	YES	215
13	1.59	241	383.2	7.4	8.11	73.1	YES	181
14	1.44	241	347.0	8.0	8.22	71.8	YES	184
15	1.49	241	359.1	7.0	8.30	79.6	YES	192
16	1.41	241	339.8	6.9	8.34	80.6	YES	176
17	1.54	241	371.1	6.6	8.36	84.2	YES	174
18	1.55	241	373.6	8.4	8.24	71.2	YES	173
19	1.62	241	390.4	7.3	8.25	77.8	YES	178
20	1.64	241	395.2	7.4	8.32	79.4	YES	175
21	1.64	241	395.2	8.4	8.43	77.2	YES	184
22	1.59	241	383.2	8.0	8.51	81.2	YES	188
23	1.55	241	373.6	7.9	8.53	82.0	YES	176
24	1.48	241	356.7	7.6	8.48	81.5	YES	178
25	1.39	241	335.0	7.4	8.39	79.1	YES	197
26	1.45	241	349.5	8.1	8.65	83.6	YES	248
27	1.43	241	344.6	7.2	8.72	91.1	YES	204
28	1.41	241	339.8	7.1	8.63	88.5	YES	193
29	1.43	241	344.6	7.3	8.71	90.1	YES	192
30		241						
31		241						

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:  
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350