


OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: COOS

Conventional or Direct Filtration

Month/Year: Feb-25

System Name:	Bandon, City of		ID#: 4100074		WTP : TP -		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	0.02	0.05	0.03	0.02	OFF	0.05
2	OFF	OFF	0.03	0.03	0.02	OFF	0.03
3	OFF	OFF	0.03	0.03	0.02	OFF	0.03
4	OFF	OFF	0.03	0.03	0.02	OFF	0.03
5	OFF	OFF	0.03	0.03	0.02	OFF	0.03
6	OFF	OFF	0.03	0.02	0.02	OFF	0.03
7	OFF	OFF	0.02	0.02	0.02	OFF	0.02
8	OFF	OFF	0.02	0.02	0.02	OFF	0.02
9	OFF	OFF	0.02	0.02	0.02	OFF	0.02
10	OFF	OFF	0.02	0.02	0.02	OFF	0.02
11	OFF	0.04	0.03	0.03	0.03	OFF	0.04
12	OFF	0.04	0.04	0.03	0.03	OFF	0.04
13	OFF	0.03	0.03	0.03	0.03	0.03	0.03
14	OFF	OFF	0.03	0.03	0.03	OFF	0.03
15	OFF	0.03	0.03	0.03	OFF	OFF	0.03
16	OFF	OFF	0.03	0.03	0.03	OFF	0.03
17	OFF	OFF	0.03	0.03	0.03	OFF	0.03
18	OFF	0.03	0.05	0.03	OFF	OFF	0.05
19	OFF	0.04	0.04	0.02	0.02	OFF	0.04
20	OFF	0.02	0.04	0.03	0.03	0.02	0.04
21	OFF	OFF	0.03	0.03	0.03	OFF	0.03
22	OFF	OFF	0.04	0.04	0.03	OFF	0.04
23	OFF	OFF	0.06	0.04	0.03	OFF	0.06
24	OFF	OFF	0.07	0.07	0.03	OFF	0.07
25	OFF	OFF	0.03	0.03	0.03	OFF	0.03
26	OFF	0.03	0.03	0.03	0.03	OFF	0.03
27	OFF	0.04	0.05	0.04	0.03	OFF	0.05
28	OFF	0.04	0.07	0.06	0.04	OFF	0.07
29							
30							
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No		
Notes:		PRINTED NAME: JAMES J. YOURAVISH	
		SIGNATURE: 	3-3-2025
		PHONE #: (541) 347-3007	CERT #: T-09155

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Bandon, City of ID#: 4100074 Month/Year: Feb-25						WTP - : Disinfection <i>Giardia</i> Log Inactiv: 0.5		
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.81	424	343.4	7.6	8.06	32.3	YES	443
2	0.78	424	330.7	8.2	8.01	30.3	YES	430
3	0.74	424	313.8	8.1	7.93	29.5	YES	534
4	0.71	424	301.0	8.0	7.92	29.5	YES	460
5	0.67	424	284.1	7.9	7.92	29.6	YES	442
6	0.65	424	275.6	7.9	7.85	28.8	YES	411
7	0.63	424	267.1	7.8	7.83	28.7	YES	509
8	0.61	424	258.6	7.9	7.81	28.3	YES	491
9	0.6	424	254.4	7.9	7.81	28.2	YES	489
10	0.6	424	254.4	7.8	7.79	28.2	YES	1759
11	0.58	424	245.9	7.8	7.79	28.1	YES	766
12	0.58	424	245.9	8.1	7.78	27.5	YES	950
13	0.58	424	245.9	8.2	7.81	27.6	YES	990
14	0.6	424	254.4	7.9	7.89	29.0	YES	436
15	0.61	424	258.6	7.8	7.94	29.8	YES	452
16	0.58	424	245.9	8.0	7.94	29.3	YES	490
17	0.57	424	241.7	8.1	7.92	28.9	YES	686
18	0.58	424	245.9	8.2	7.95	29.0	YES	592
19	0.58	424	245.9	8.3	7.94	28.7	YES	1450
20	0.59	424	250.2	8.5	7.90	28.0	YES	1142
21	0.61	424	258.6	9.1	7.86	26.5	YES	998
22	0.6	424	254.4	8.9	7.80	26.3	YES	622
23	0.58	424	245.9	9.1	7.79	25.8	YES	639
24	0.57	424	241.7	9.4	7.79	25.2	YES	803
25	0.55	424	233.2	9.4	7.83	25.5	YES	694
26	0.54	424	229.0	9.7	7.83	25.0	YES	1754
27	0.53	424	224.7	9.9	7.83	24.7	YES	1347
28	0.52	424	220.5	10.1	7.82	24.2	YES	709
29		424					NO	
30		424					NO	
31		424					NO	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013