


OHA - Drinking Water Services -Turbidity Monitoring Report Form

Conventional or Direct Filtration

County: COOS
Month/Year: Jul-25

System Name: Bandon, City of		ID#: 4100074					WTP : TP -
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	0.06	0.05	0.05	0.04	OFF	0.06
2	OFF	0.06	0.05	0.04	0.04	OFF	0.05
3	0.05	0.12	0.05	0.05	0.04	0.04	0.12
4	OFF	0.19	0.06	0.05	0.04	0.04	0.19
5	OFF	0.05	0.06	0.05	0.04	0.04	0.05
6	OFF	0.05	0.05	0.04	0.04	0.04	0.05
7	OFF	0.05	0.05	0.04	0.04	OFF	0.05
8	0.05	0.12	0.06	0.05	0.04	0.04	0.12
9	OFF	0.12	0.06	0.05	0.04	0.04	0.12
10	OFF	0.05	0.05	0.05	0.04	OFF	0.05
11	OFF	0.05	0.05	0.04	0.04	OFF	0.05
12	OFF	0.06	0.05	0.04	0.04	0.04	0.06
13	OFF	0.19	0.06	0.05	0.04	0.04	0.19
14	0.04	0.11	0.06	0.05	0.04	0.04	0.11
15	OFF	0.05	0.05	0.04	0.04	OFF	0.05
16	0.05	0.05	0.05	0.04	0.04	OFF	0.05
17	OFF	0.05	0.05	0.04	0.04	OFF	0.05
18	0.05	0.17	0.05	0.04	0.04	OFF	0.17
19	0.05	0.15	0.05	0.04	0.04	0.04	0.15
20	OFF	0.05	0.05	0.04	0.04	OFF	0.05
21	OFF	0.05	0.05	0.04	0.04	OFF	0.05
22	0.05	0.05	0.05	0.04	0.04	0.04	0.05
23	OFF	0.14	0.06	0.04	0.03	0.03	0.14
24	OFF	0.12	0.04	0.03	0.03	0.02	0.12
25	OFF	0.03	0.03	0.02	0.02	OFF	0.03
26	0.03	0.03	0.03	0.02	0.02	OFF	0.03
27	OFF	0.03	0.03	0.12	0.03	0.02	0.12
28	0.02	0.15	0.13	0.03	0.03	0.03	0.15
29	OFF	0.03	0.03	0.03	0.03	OFF	0.03
30	0.04	0.03	0.03	0.03	0.04	0.04	0.04
31							

Conventional or Direct Filtration 95% of 4-hour turbidity readings $\leq$ 0.3 NTU? ☒ Yes / ☐ No All 4-hour turbidity readings $\leq$ 1 NTU? ☒ Yes / ☐ No All turbidity readings < IFE ² triggers ☒ Yes / ☐ No		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) ☒ Yes / ☐ No All Cl ₂ residual at entry point $\geq$ 0.2 mg/l? ☒ Yes / ☐ No	
Notes:		PRINTED NAME: JAMES J. YOURAVISH	
		SIGNATURE: 	
		PHONE #: (541)-347-3007	
		CERT #: T-09155	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Bandon, City of ID#: 4100074 Month/Year: Jul-25						WTP - : Disinfection <i>Giardia</i> Log Inactiv: 0.5		
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.76	424	322.2	15.7	7.84	17.3	YES	867
2	0.73	424	309.5	15.8	7.79	16.8	YES	790
3	0.73	424	309.5	15.8	7.73	16.4	YES	735
4	0.73	424	309.5	15.7	7.55	15.5	YES	748
5	0.76	424	322.2	15.5	7.64	16.2	YES	956
6	0.75	424	318.0	15.5	7.56	15.8	YES	753
7	0.73	424	309.5	15.5	7.68	16.4	YES	760
8	0.71	424	301.0	15.6	7.70	16.4	YES	902
9	0.72	424	305.3	15.5	7.63	16.1	YES	861
10	0.73	424	309.5	15.5	7.75	16.9	YES	831
11	0.72	424	305.3	15.6	7.83	17.2	YES	808
12	0.7	424	296.8	15.8	7.80	16.8	YES	776
13	0.69	424	292.6	16.0	7.65	15.7	YES	983
14	0.69	424	292.6	16.2	7.77	16.1	YES	1264
15	0.72	424	305.3	16.2	7.91	17.1	YES	912
16	0.69	424	292.6	16.2	7.95	17.3	YES	1000
17	0.72	424	305.3	16.1	7.71	15.9	YES	860
18	0.72	424	305.3	16.0	7.60	15.4	YES	1023
19	0.72	424	305.3	15.9	7.50	15.0	YES	874
20	0.74	424	313.8	16.1	7.50	14.8	YES	1016
21	0.74	424	313.8	16.0	7.48	14.8	YES	1122
22	0.74	424	313.8	16.0	7.54	15.1	YES	1101
23	0.78	424	330.7	16.0	7.67	15.9	YES	971
24	0.79	424	335.0	17.6	8.24	17.7	YES	999
25	0.8	424	339.2	17.6	8.17	17.3	YES	1072
26	0.79	424	335.0	17.5	8.07	16.7	YES	874
27	0.78	424	330.7	17.5	7.92	15.8	YES	1077
28	0.83	424	351.9	17.4	7.71	14.8	YES	1014
29	0.85	424	360.4	17.3	7.69	14.8	YES	1014
30	0.82	424	347.7	17.3	7.60	14.3	YES	888
31	0.8	424	339.2	17.3	7.88	15.8	YES	907

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013