

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: COOS

Conventional or Direct Filtration

Month/Year: Jan-26

System Name: Bandon, City of ID#: 4100074 WTP : TP -

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	0.04	0.05	0.04	OFF	0.05
2	OFF	0.05	0.06	0.04	0.03	OFF	0.06
3	OFF	OFF	0.04	0.03	0.03	OFF	0.04
4	OFF	OFF	0.04	0.02	0.02	OFF	0.04
5	OFF	0.10	0.02	0.02	0.02	OFF	0.10
6	OFF	0.02	0.04	0.03	0.03	0.02	0.04
7	OFF	0.03	0.23	0.03	0.03	OFF	0.23
8	OFF	OFF	0.24	0.02	0.03	OFF	0.24
9	OFF	OFF	0.23	0.05	0.06	OFF	0.23
10	OFF	0.22	0.09	0.11	0.08	0.05	0.22
11	OFF	OFF	0.08	0.08	OFF	OFF	0.08
12	OFF	OFF	0.16	0.15	0.07	0.03	0.16
13	0.03	0.03	0.03	0.03	0.03	OFF	0.03
14	OFF	0.03	0.03	0.02	0.02	OFF	0.03
15	OFF	0.03	0.02	0.02	0.02	OFF	0.03
16	OFF	0.05	0.03	0.02	0.02	0.02	0.05
17	OFF	0.03	0.05	0.02	0.02	0.02	0.05
18	OFF	OFF	0.03	0.02	0.02	OFF	0.03
19	OFF	OFF	0.03	0.02	0.02	0.02	0.03
20	OFF	OFF	0.03	0.02	0.02	OFF	0.03
21	OFF	0.03	0.02	0.02	0.02	OFF	0.03
22	OFF	0.02	0.05	0.02	0.02	0.02	0.05
23	OFF	0.05	0.04	0.02	0.02	OFF	0.05
24	OFF	0.03	0.02	0.02	0.02	OFF	0.03
25	0.03	0.02	OFF	0.02	0.02	0.02	0.03
26	OFF	0.02	0.02	0.02	0.02	OFF	0.02
27	OFF	0.02	0.02	0.02	0.02	OFF	0.02
28	OFF	0.02	0.02	0.02	0.03	OFF	0.03
29	OFF	0.03	0.06	0.02	0.02	0.02	0.06
30	OFF	0.02	0.05	0.02	0.02	0.02	0.05
31	OFF	0.02	0.02	0.02	0.02	OFF	0.02

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? Yes / No	CT's met everyday? (see back) Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No
All 4-hour turbidity readings ≤ 1 NTU? Yes / No		
All turbidity readings < IFE ² triggers Yes / No		

Notes:	PRINTED NAME: JAMES J. YOURAVISH	
	SIGNATURE: <i>[Signature]</i>	2-3-2026
	PHONE #: (541)-347-3007	CERT #: T-09155

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Bandon, City of				ID#: 4100074	Month/Year: Jan-26	WTP - :	
						Disinfection <i>Giardia</i> Log Inactiv:	0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1	0.62	424	262.9	11.4	7.79	22.2	YES	464
2	0.58	424	245.9	11.4	7.79	22.1	YES	490
3	0.53	424	224.7	11.4	7.73	21.5	YES	490
4	0.51	424	216.2	11.5	7.64	20.7	YES	521
5	0.46	424	195.0	11.5	7.57	20.1	YES	452
6	0.47	424	199.3	11.2	7.54	20.3	YES	483
7	0.49	424	207.8	11.5	7.43	19.2	YES	601
8	0.51	424	216.2	11.4	7.34	18.8	YES	602
9	0.51	424	216.2	11.3	7.42	19.4	YES	542
10	0.51	424	216.2	11.3	7.45	19.6	YES	447
11	0.51	424	216.2	11.1	7.50	20.2	YES	435
12	0.52	424	220.5	11.0	7.60	21.1	YES	731
13	0.55	424	233.2	10.8	7.69	22.2	YES	516
14	0.49	424	207.8	10.9	7.66	21.6	YES	500
15	0.46	424	195.0	10.8	7.60	21.2	YES	449
16	0.47	424	199.3	11.0	7.62	21.1	YES	513
17	0.52	424	220.5	11.0	7.61	21.2	YES	496
18	0.58	424	245.9	11.0	7.58	21.1	YES	475
19	0.57	424	241.7	10.9	7.60	21.4	YES	515
20	0.64	424	271.4	10.8	7.64	22.0	YES	478
21	0.67	424	284.1	10.7	7.66	22.4	YES	499
22	0.69	424	292.6	10.7	7.63	22.2	YES	507
23	0.75	424	318.0	10.6	7.72	23.2	YES	467
24	0.76	424	322.2	10.5	7.78	23.9	YES	511
25	0.84	424	356.2	10.5	7.83	24.5	YES	687
26	0.82	424	347.7	10.4	7.70	23.5	YES	568
27	0.82	424	347.7	10.5	7.72	23.5	YES	621
28	0.8	424	339.2	10.5	7.73	23.6	YES	558
29	0.77	424	326.5	10.6	7.70	23.1	YES	490
30	0.71	424	301.0	10.8	7.59	21.8	YES	451
31	0.69	424	292.6	10.9	7.53	21.1	YES	446

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013