

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Washington**
 Month/Year: **May/2024**

System Name: **Banks Water Department** ID#: **41 00076** WTP: **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day 1 [NTU]
1	0.11	0.12	0.11	0.11	0.09	0.1	0.13
2	0.13	0.13	0.12	0.09	0.09	0.09	0.15
3	0.12	0.14	0.13	0.12	0.11	0.12	0.21
4	0.14	0.12	0.1	0.08	0.08	0.08	0.14
5	0.08	0.09	0.08	0.08	0.08	0.07	0.09
6	0.07	0.08	0.08	0.07	0.05	0.04	0.08
7	0.04	0.04	0.03	0.01	0.01	0.01	0.04
8	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9	0.01	0.01	0.01	0.01	0.01	0.03	0.08
10	0.08	0.12	0.12	0.12	0.23	0.32	0.44
11	0.42	0.52	0.36	0.26	0.2	0.17	0.54
12	0.19	0.19	0.16	0.14	0.12	0.12	0.25
13	0.14	0.16	0.14	0.11	0.11	0.1	0.19
14	0.14	0.18	0.14	0.11	0.09	0.09	0.18
15	0.15	0.19	0.15	0.11	0.11	0.1	0.19
16	0.16	0.21	0.15	0.11	0.09	0.09	0.21
17	0.17	0.19	0.14	0.08	0.08	0.08	0.20
18	0.11	0.14	0.09	0.07	0.05	0.07	0.14
19	0.09	0.11	0.08	0.05	0.05	0.05	0.11
20	0.08	0.09	0.08	0.05	0.04	0.04	0.1
21	0.08	0.09	0.08	0.06	0.05	0.05	0.1
22	0.08	0.08	0.07	0.05	0.05	0.05	0.09
23	0.08	0.09	0.08	0.07	0.04	0.05	0.09
24	0.05	0.05	0.05	0.04	0.08	0.04	0.08
25	0.04	0.04	0.04	0.03	0.03	0.03	0.05
26	0.04	0.04	0.04	0.03	0.03	0.03	0.05
27	0.04	0.04	0.04	0.03	0.03	0.03	0.05
28	0.04	0.05	0.05	0.04	0.04	0.06	0.07
29	0.06	0.07	0.07	0.05	0.08	0.05	0.08
30	0.06	0.06	0.08	0.09	0.08	0.09	0.09
31	0.11	0.17	0.07	0.19	0.06	0.07	0.20

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? 2	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes:	PRINTED NAME: Troy Van Roekel		
	SIGNATURE: <i>Troy Van Roekel</i>		DATE: 6-3-2024
	PHONE #: 503-809-1349		T-9282 D-3805

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not

correspond to continuous readings' maximum. 2 Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP-: **A**

System Name: **Banks Water Department ID#: 41 00076**

Month/Year:

Disinfection Giardia Log

Inactiv: **1.0**

Date / Time	Minimum Cl2 Residual at 1st User (C) 3	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 3	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.79	201	158.8	10.11	7.52	44.6	YES	215
2	0.78	201	156.8	10.72	7.55	43.3	YES	215
3	0.75	201	150.8	11.00	7.5	41.6	YES	215
4	0.75	201	150.8	10.94	7.49	41.6	YES	215
5	0.78	201	156.8	11.17	7.49	41.1	YES	215
6	0.82	201	164.8	11.00	7.46	41.3	YES	215
7	0.80	201	160.8	11.17	7.46	40.7	YES	215
8	0.81	201	162.8	10.72	7.46	42.0	YES	215
9	0.86	201	172.9	11.22	7.58	42.7	YES	215
10	0.85	201	170.9	12.39	7.56	39.2	YES	215
11	0.85	201	170.9	12.61	7.56	38.6	YES	215
12	0.81	201	162.8	13.56	7.46	34.8	YES	215
13	0.77	201	154.8	13.89	7.45	33.8	YES	215
14	0.77	201	154.8	13.89	7.46	33.9	YES	215
15	0.82	201	164.8	13.78	7.49	34.7	YES	215
16	0.85	201	170.9	13.89	7.45	34.1	YES	215
17	0.88	201	176.9	14.17	7.5	34.2	YES	215
18	0.91	201	182.9	13.72	7.5	35.3	YES	215
19	0.93	201	186.9	13.22	7.5	36.6	YES	215
20	0.93	201	186.9	12.78	7.53	38.1	YES	215
21	0.91	201	182.9	12.78	7.53	38.0	YES	215
22	0.91	201	182.9	12.33	7.57	39.8	YES	215
23	0.89	201	178.9	11.33	7.53	41.8	YES	215
24	0.85	201	170.9	12.17	7.51	39.1	YES	215
25	0.82	201	164.8	12.83	7.54	37.7	YES	215
26	0.80	201	160.8	12.83	7.51	37.2	YES	215
27	0.77	201	154.8	13.17	7.5	36.1	YES	215
28	0.77	201	154.8	13.17	7.43	35.2	YES	215
29	0.89	201	178.9	13.61	7.35	33.6	YES	215
30	0.89	201	178.9	13.56	7.37	34.0	YES	215
31	0.85	201	170.9	13.06	7.42	35.6	YES	215

3 If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350