

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Washington**
 Month/Year: **September/2025**

System Name: **Banks Water Department** ID#: **41 00076** WTP: **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day 1 [NTU]
1	0.07	0.08	0.07	0.07	0.07	0.07	0.08
2	0.07	0.07	0.07	0.07	0.07	0.07	0.08
3	0.07	0.07	0.08	0.07	0.07	0.08	0.08
4	0.08	0.08	0.08	0.08	0.07	0.07	0.11
5	0.11	0.08	0.08	0.08	0.08	0.07	0.11
6	0.07	0.08	0.08	0.08	0.07	0.08	0.09
7	0.08	0.1	0.08	0.08	0.08	0.08	0.1
8	0.08	0.1	0.1	0.09	0.08	0.09	0.1
9	0.07	0.08	0.07	0.07	0.07	0.06	0.14
10	0.07	0.07	0.07	0.08	0.07	0.05	0.09
11	0.07	0.07	0.07	0.05	0.05	0.05	0.08
12	0.05	0.06	0.05	0.05	0.05	0.05	0.07
13	0.05	0.07	0.05	0.07	0.07	0.05	0.08
14	0.08	0.07	0.07	0.07	0.07	0.07	0.08
15	0.07	0.07	0.07	0.06	0.06	0.05	0.09
16	0.07	0.07	0.08	0.07	0.07	0.07	0.08
17	0.07	0.09	0.07	0.07	0.07	0.07	0.16
18	0.08	0.08	0.07	0.05	0.05	0.05	0.09
19	0.07	0.07	0.07	0.07	0.05	0.05	0.08
20	0.07	0.08	0.07	0.07	0.07	0.07	0.08
21	0.08	0.08	0.07	0.07	0.07	0.07	0.08
22	0.07	0.07	0.07	0.05	0.05	0.05	0.09
23	0.05	0.07	0.07	0.05	0.07	0.05	0.07
24	0.07	0.07	0.07	0.07	0.07	0.07	0.08
25	0.07	0.08	0.69	0.07	0.07	0.07	0.69
26	0.07	0.07	0.07	0.07	0.07	0.07	0.07
27	0.07	0.08	0.07	0.07	0.07	0.07	0.08
28	0.07	0.07	0.07	0.07	0.05	0.05	0.1
29	0.07	0.08	0.07	0.11	0.09	0.05	0.11
30	0.05	0.07	0.05	0.07	0.07	0.07	0.07
31							

Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings ≤ 1 NTU? 2 ☒ Yes ☐ No All daily turbidity readings ≤ 5 NTU? ☒ Yes ☐ No		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) ☒ Yes ☐ No All Cl2 residual at entry point ≥ 0.2 mg/l? ☒ Yes ☐ No	
Notes:		PRINTED NAME: Troy Van Roekel	
		SIGNATURE: <i>Troy Van Roekel</i>	
		DATE: 10-2-25	
		PHONE #: 503-809-1349	
		T-9282 D-3805	

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not

correspond to continuous readings' maximum. 2 Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

A

Disinfection Giardia Log

System Name:

Banks Water Department

ID#: 41

00076

Month/Year:

Inactiv:

1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) 3	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 3	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.51	201	102.5	17.67	7.49	25.8	YES	143
2	0.50	201	100.5	17.50	7.49	26.1	YES	115
3	0.48	201	96.5	18.11	7.46	24.7	YES	59
4	0.45	201	90.5	18.17	7.49	24.8	YES	58
5	0.48	201	96.5	18.28	7.45	24.4	YES	167
6	0.51	201	102.5	18.17	7.44	24.5	YES	141
7	0.59	201	118.6	17.94	7.44	25.1	YES	164
8	0.58	201	116.6	17.56	7.43	25.7	YES	148
9	0.57	201	114.6	17.67	7.46	25.7	YES	140
10	0.58	201	116.6	17.2	7.43	26.3	YES	93
11	0.55	201	110.6	16.94	7.43	26.7	YES	55
12	0.55	201	110.6	17.06	7.46	26.7	YES	162
13	0.56	201	112.6	16.67	7.45	27.4	YES	147
14	0.59	201	118.6	16.50	7.46	27.9	YES	139
15	0.59	201	118.6	15.78	7.49	29.6	YES	148
16	0.59	201	118.6	16.11	7.49	28.9	YES	130
17	0.57	201	114.6	16.28	7.49	28.6	YES	139
18	0.53	201	106.5	16.17	7.49	28.6	YES	143
19	0.57	201	114.6	16.00	7.52	29.4	YES	149
20	0.59	201	118.6	15.89	7.51	29.6	YES	149
21	0.60	201	120.6	15.72	7.51	30.0	YES	148
22	0.60	201	120.6	15.17	7.52	31.2	YES	150
23	0.62	201	124.6	15.28	7.55	31.4	YES	160
24	0.60	201	120.6	15.61	7.55	30.6	YES	168
25	0.57	201	114.6	15.33	7.55	31.1	YES	158
26	0.63	201	126.6	14.83	7.56	32.5	YES	146
27	0.63	201	126.6	14.94	7.58	32.5	YES	142
28	0.62	201	124.6	14.89	7.58	32.6	YES	149
29	0.65	201	130.7	15.00	7.58	32.5	YES	146
30	0.64	201	128.6	14.89	7.58	32.7	YES	143
31								

3 If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350