

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Washington**
 Month/Year: **October/2025**

System Name:		Banks Water Department		ID#: 41 00076		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day 1 [NTU]
1	0.05	0.05	0.05	0.05	0.05	0.04	0.07
2	0.04	0.04	0.04	0.04	0.04	0.04	0.07
3	0.04	0.05	0.04	0.04	0.04	0.04	0.05
4	0.04	0.04	0.04	0.04	0.04	0.04	0.05
5	0.04	0.05	0.04	0.04	0.04	0.04	0.06
6	0.04	0.05	0.04	0.04	0.04	0.04	0.05
7	0.05	0.04	0.04	0.04	0.04	0.04	0.05
8	0.04	0.05	0.05	0.04	0.05	0.04	0.05
9	0.04	0.05	0.05	0.04	0.04	0.04	0.08
10	0.04	0.04	0.05	0.05	0.05	0.04	0.05
11	0.04	0.05	0.04	0.04	0.04	0.04	0.05
12	0.04	0.04	0.04	0.04	0.04	0.04	0.07
13	0.04	0.04	0.05	0.04	0.04	0.04	0.05
14	0.04	0.05	0.05	0.04	0.04	0.04	0.05
15	0.04	0.05	0.04	0.04	0.04	0.04	0.09
16	0.04	0.06	0.05	0.05	0.04	0.04	0.07
17	0.04	0.07	0.05	0.04	0.04	0.04	0.07
18	0.05	0.05	0.08	0.05	0.05	0.04	0.09
19	0.05	0.05	0.07	0.05	0.05	0.05	0.07
20	0.05	0.05	0.05	0.05	0.05	0.05	0.11
21	0.05	0.05	0.05	0.05	0.05	0.05	0.07
22	0.05	0.07	0.07	0.07	0.05	0.06	0.12
23	0.07	0.07	0.07	0.07	0.07	0.07	0.09
24	0.07	0.07	0.07	0.07	0.07	0.07	0.07
25	0.07	0.07	0.07	0.07	0.07	0.07	0.11
26	0.07	0.08	0.07	0.07	0.08	0.08	0.08
27	0.08	0.08	0.08	0.08	0.08	0.08	0.08
28	0.08	0.08	0.09	0.09	0.09	0.09	0.09
29	0.09	0.09	0.09	0.11	0.11	0.11	0.11
30	0.11	0.11	0.11	0.12	0.11	0.11	0.12
31	0.11	0.11	0.11	0.11	0.11	0.14	0.14

Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings ≤ 1 NTU? 2 ☒ Yes / No All daily turbidity readings ≤ 5 NTU? ☒ Yes / No		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) ☒ Yes / No All Cl2 residual at entry point ≥ 0.2 mg/l? ☒ Yes / No	
---	--	--	--

Notes:	PRINTED NAME: Troy Van Roekel	
	SIGNATURE:	DATE: 11-5-25
	PHONE #: 503-809-1349 T-9282 D-3805	

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not

correspond to continuous readings' maximum. 2 Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form
WTP- : A
System Name: Banks Water Department ID#: 41 00076 Month/Year:
Disinfection Giardia Log
Inactiv: 1.0

Date / Time	Minimum Cl ₂ Residual at 1st User (C) 3	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 3	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.50	201	100.5	14.78	7.44	30.7	YES	153
2	0.36	201	72.4	14.83	7.42	29.9	YES	188
3	0.44	201	88.4	14.44	7.4	30.8	YES	160
4	0.62	201	124.6	14.56	7.37	30.8	YES	99
5	0.71	201	142.7	14.06	7.37	32.2	YES	108
6	0.93	201	186.9	13.78	7.38	33.7	YES	106
7	0.89	201	178.9	13.89	7.37	33.2	YES	105
8	0.83	201	166.8	13.83	7.36	33.0	YES	111
9	0.85	201	170.9	13.50	7.37	33.9	YES	109
10	0.83	201	166.8	13.56	7.37	33.7	YES	106
11	0.81	201	162.8	13.33	7.37	34.2	YES	104
12	0.79	201	158.8	13.00	7.37	34.9	YES	111
13	0.79	201	158.8	12.11	7.4	37.4	YES	108
14	0.77	201	154.8	11.78	7.4	38.1	YES	104
15	0.75	201	150.8	11.56	7.4	38.6	YES	104
16	0.72	201	144.7	11.44	7.41	38.9	YES	105
17	0.75	201	150.8	11.89	7.42	38.1	YES	104
18	0.78	201	156.8	11.61	7.43	39.0	YES	106
19	0.83	201	166.8	11.89	7.43	38.5	YES	100
20	0.78	201	156.8	11.89	7.42	38.2	YES	103
21	0.74	201	148.7	11.44	7.4	38.9	YES	100
22	0.73	201	146.7	11.67	7.37	37.8	YES	63
23	0.74	201	148.7	12.00	7.32	36.4	YES	66
24	0.73	201	146.7	12.22	7.36	36.3	YES	100
25	0.75	201	150.8	11.78	7.34	37.2	YES	101
26	0.73	201	146.7	11.11	7.31	38.4	YES	99
27	0.67	201	134.7	10.89	7.29	38.4	YES	102
28	0.68	201	136.7	10.94	7.29	38.3	YES	106
29	0.71	201	142.7	11.00	7.27	38.0	YES	105
30	0.71	201	142.7	10.89	7.27	38.3	YES	107
31	0.82	201	164.8	10.83	7.27	38.9	YES	106

 3 If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350