


**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Washington**  
 Month/Year: **November/2025**

| System Name: <b>Banks Water Department</b> |                | ID#: <b>41 00076</b> |               | WTP : <b>TP - A</b> |               |               |                                    |
|--------------------------------------------|----------------|----------------------|---------------|---------------------|---------------|---------------|------------------------------------|
| Day                                        | 12 AM<br>[NTU] | 4 AM<br>[NTU]        | 8 AM<br>[NTU] | NOON<br>[NTU]       | 4 PM<br>[NTU] | 8 PM<br>[NTU] | Highest Reading of the day 1 [NTU] |
| 1                                          | 0.15           | 0.15                 | 0.15          | 0.16                | 0.16          | 0.16          | 0.31                               |
| 2                                          | 0.15           | 0.16                 | 0.15          | 0.15                | 0.16          | 0.15          | 0.27                               |
| 3                                          | 0.16           | 0.16                 | 0.16          | 0.16                | 0.16          | 0.16          | 0.20                               |
| 4                                          | 0.01           | 0.01                 | 0.01          | 0.01                | 0.01          | 0.01          | 0.20                               |
| 5                                          | 0.01           | 0.01                 | 0.01          | 0.01                | 0.01          | 0.01          | 0.02                               |
| 6                                          | 0.01           | 0.01                 | 0.01          | 0.01                | 0.01          | 0.01          | 0.15                               |
| 7                                          | 0.01           | 0.01                 | 0.01          | 0.01                | 0.01          | 0.01          | 0.16                               |
| 8                                          | 0.01           | 0.01                 | 0.01          | 0.01                | 0.01          | 0.01          | 0.31                               |
| 9                                          | 0.01           | 0.01                 | 0.01          | 0.01                | 0.01          | 0.01          | 0.01                               |
| 10                                         | 0.01           | 0.01                 | 0.01          | 0.06                | 0.01          | 0.01          | 0.06                               |
| 11                                         | 0.01           | 0.01                 | 0.01          | 0.01                | 0.01          | 0.01          | 0.03                               |
| 12                                         | 0.01           | 0.01                 | 0.01          | 0.01                | 0.01          | 0.01          | 0.23                               |
| 13                                         | 0.01           | 0.01                 | 0.01          | 0.01                | 0.01          | 0.01          | 0.11                               |
| 14                                         | 0.01           | 0.01                 | 0.01          | 0.01                | 0.01          | 0.01          | 0.04                               |
| 15                                         | 0.01           | 0.01                 | 0.01          | 0.01                | 0.03          | 0.01          | 0.03                               |
| 16                                         | 0.01           | 0.01                 | 0.01          | 0.01                | 0.01          | 0.01          | 0.03                               |
| 17                                         | 0.01           | 0.01                 | 0.01          | 0.01                | 0.01          | 0.01          | 0.07                               |
| 18                                         | 0.01           | 0.01                 | 0.01          | 0.01                | 0.01          | 0.01          | 0.1                                |
| 19                                         | 0.01           | 0.01                 | 0.01          | 0.01                | 0.01          | 0.01          | 0.08                               |
| 20                                         | 0.01           | 0.01                 | 0.01          | 0.01                | 0.01          | 0.01          | 0.01                               |
| 21                                         | 0.01           | 0.01                 | 0.01          | 0.01                | 0.01          | 0.01          | 0.01                               |
| 22                                         | 0.01           | 0.01                 | 0.01          | 0.01                | 0.01          | 0.01          | 0.01                               |
| 23                                         | 0.01           | 0.01                 | 0.01          | 0.01                | 0.01          | 0.01          | 0.01                               |
| 24                                         | 0.01           | 0.01                 | 0.01          | 0.01                | 0.01          | 0.01          | 0.01                               |
| 25                                         | 0.01           | 0.01                 | 0.01          | 0.01                | 0.01          | 0.01          | 0.01                               |
| 26                                         | 0.01           | 0.01                 | 0.01          | 0.01                | 0.01          | 0.01          | 0.01                               |
| 27                                         | 0.01           | 0.01                 | 0.01          | 0.01                | 0.01          | 0.01          | 0.01                               |
| 28                                         | 0.01           | 0.01                 | 0.01          | 0.01                | 0.01          | 0.01          | 0.01                               |
| 29                                         | 0.01           | 0.01                 | 0.01          | 0.01                | 0.01          | 0.01          | 0.01                               |
| 30                                         | 0.01           | 0.01                 | 0.01          | 0.01                | 0.01          | 0.01          | 0.01                               |
| 31                                         |                |                      |               |                     |               |               |                                    |

|                                                    |               |                                                                                                 |                                             |
|----------------------------------------------------|---------------|-------------------------------------------------------------------------------------------------|---------------------------------------------|
| <b>Slow Sand/Membrane/DE Filtration/Unfiltered</b> |               | <b>Monthly Summary (Answer Yes or No)</b>                                                       |                                             |
| 95% of daily turbidity readings ≤ 1 NTU? 2         | <b>Yes</b> No | CT's met everyday? (see back)                                                                   | All Cl2 residual at entry point ≥ 0.2 mg/l? |
| All daily turbidity readings ≤ 5 NTU?              | <b>Yes</b> No | <b>Yes</b> / No                                                                                 | <b>Yes</b> / No                             |
| Notes:                                             |               | PRINTED NAME: <b>Troy Van Roekel</b>                                                            |                                             |
|                                                    |               | SIGNATURE:  | DATE: <b>12-8-25</b>                        |
|                                                    |               | PHONE #: <b>503-809-1349</b>                                                                    | <b>T-9282 D-3805</b>                        |

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not

correspond to continuous readings' maximum. 2 Filtered systems only.

**OHA - Drinking Water Services - Surface Water Quality Data Form**
**WTP- :**
**A**
**Disinfection Giardia Log**
**System Name:** Banks Water Department **ID#: 41 00076** **Month/Year:**
**Inactiv:**
**1.0**

| Date / Time | Minimum<br>Cl <sub>2</sub><br>Residual at<br>1st User<br>( C ) 3 | Contact<br>Time<br>(T) | Actual CT | Temp  | pH   | Required CT | CT Met? 3 | Peak Hourly Demand<br>Flow |
|-------------|------------------------------------------------------------------|------------------------|-----------|-------|------|-------------|-----------|----------------------------|
|             | [ppm or mg/L]                                                    | [minutes]              | C X T     | [° C] |      | formula     | Yes / No  | [GPM]                      |
| 1           | 0.91                                                             | 201                    | 182.9     | 11.44 | 7.27 | 37.8        | YES       | 99                         |
| 2           | 0.86                                                             | 201                    | 172.9     | 11.00 | 7.29 | 39.0        | YES       | 99                         |
| 3           | 0.83                                                             | 201                    | 166.8     | 10.78 | 7.28 | 39.3        | YES       | 103                        |
| 4           | 0.82                                                             | 201                    | 164.8     | 11.00 | 7.28 | 38.6        | YES       | 98                         |
| 5           | 0.84                                                             | 201                    | 168.8     | 11.17 | 7.28 | 38.3        | YES       | 98                         |
| 6           | 0.82                                                             | 201                    | 164.8     | 11.39 | 7.28 | 37.7        | YES       | 98                         |
| 7           | 0.70                                                             | 201                    | 140.7     | 11.28 | 7.28 | 37.4        | YES       | 145                        |
| 8           | 0.78                                                             | 201                    | 156.8     | 10.94 | 7.27 | 38.5        | YES       | 69                         |
| 9           | 0.77                                                             | 201                    | 154.8     | 10.94 | 7.27 | 38.4        | YES       | 70                         |
| 10          | 0.83                                                             | 201                    | 166.8     | 11.22 | 7.28 | 38.1        | YES       | 104                        |
| 11          | 0.84                                                             | 201                    | 168.8     | 10.89 | 7.28 | 39.0        | YES       | 67                         |
| 12          | 0.86                                                             | 201                    | 172.9     | 11.17 | 7.29 | 38.5        | YES       | 60                         |
| 13          | 0.91                                                             | 201                    | 182.9     | 11.44 | 7.29 | 38.1        | YES       | 85                         |
| 14          | 0.90                                                             | 201                    | 180.9     | 11.67 | 7.27 | 37.2        | YES       | 97                         |
| 15          | 0.91                                                             | 201                    | 182.9     | 11.89 | 7.27 | 36.7        | YES       | 110                        |
| 16          | 0.92                                                             | 201                    | 184.9     | 11.67 | 7.27 | 37.2        | YES       | 103                        |
| 17          | 0.95                                                             | 201                    | 191.0     | 11.44 | 7.27 | 37.9        | YES       | 110                        |
| 18          | 0.95                                                             | 201                    | 191.0     | 10.72 | 7.27 | 39.8        | YES       | 123                        |
| 19          | 0.94                                                             | 201                    | 188.9     | 10.22 | 7.27 | 41.1        | YES       | 122                        |
| 20          | 0.93                                                             | 201                    | 186.9     | 10.22 | 7.28 | 41.2        | YES       | 122                        |
| 21          | 0.87                                                             | 201                    | 174.9     | 9.67  | 7.28 | 42.4        | YES       | 113                        |
| 22          | 0.86                                                             | 201                    | 172.9     | 9.33  | 7.28 | 43.4        | YES       | 102                        |
| 23          | 0.87                                                             | 201                    | 174.9     | 9.33  | 7.28 | 43.4        | YES       | 98                         |
| 24          | 0.83                                                             | 201                    | 166.8     | 9.06  | 7.29 | 44.2        | YES       | 98                         |
| 25          | 0.87                                                             | 201                    | 174.9     | 8.83  | 7.27 | 44.7        | YES       | 102                        |
| 26          | 0.84                                                             | 201                    | 168.8     | 9.22  | 7.28 | 43.6        | YES       | 109                        |
| 27          | 0.78                                                             | 201                    | 156.8     | 9.61  | 7.29 | 42.3        | YES       | 103                        |
| 28          | 0.78                                                             | 201                    | 156.8     | 10.11 | 7.27 | 40.7        | YES       | 102                        |
| 29          | 0.74                                                             | 201                    | 148.7     | 9.61  | 7.27 | 41.8        | YES       | 100                        |
| 30          | 0.72                                                             | 201                    | 144.7     | 9.11  | 7.27 | 43.1        | YES       | 101                        |
| 31          |                                                                  |                        |           |       |      |             |           |                            |

 3 If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350