

**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Washington**  
 Month/Year: **February/2026**

System Name: <b>Banks Water Department</b>		ID#: <b>41 00076</b>		WTP : <b>TP - A</b>			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day 1 [NTU]
1	0.07	0.07	0.07	0.07	0.05	0.05	0.07
2	0.05	0.07	0.07	0.07	0.07	0.08	0.12
3	0.09	0.09	0.11	0.11	0.11	0.11	0.12
4	0.12	0.12	0.11	0.09	0.09	0.09	0.12
5	0.09	0.11	0.09	0.08	0.08	0.08	0.12
6	0.08	0.09	0.08	0.07	0.07	0.07	0.11
7	0.07	0.07	0.07	0.07	0.05	0.05	0.09
8	0.05	0.05	0.07	0.07	0.07	0.08	0.09
9	0.09	0.13	0.28	0.5	0.46	0.63	0.7
10	0.7	0.69	0.59	0.47	0.38	0.31	0.71
11	0.24	0.22	0.17	0.13	0.12	0.11	0.25
12	0.09	0.09	0.09	0.08	0.07	0.07	0.15
13	0.07	0.07	0.07	0.07	0.05	0.06	0.08
14	0.05	0.07	0.05	0.05	0.05	0.05	0.07
15	0.05	0.05	0.05	0.05	0.05	0.01	0.06
16	0.05	0.05	0.05	0.05	0.04	0.05	0.12
17	0.04	0.04	0.05	0.04	0.04	0.04	0.05
18	0.04	0.04	0.04	0.04	0.04	0.04	0.05
19	0.04	0.04	0.03	0.03	0.03	0.01	0.04
20	0.03	0.03	0.03	0.03	0.04	0.03	0.04
21	0.03	0.02	0.03	0.03	0.04	0.03	0.09
22	0.04	0.04	0.04	0.03	0.04	0.03	0.06
23	0.04	0.05	0.04	0.04	0.04	0.05	0.08
24	0.05	0.05	0.05	0.07	0.07	0.08	0.09
25	0.08	0.11	0.11	0.11	0.12	0.12	0.15
26	0.13	0.15	0.13	0.12	0.12	0.12	0.15
27	0.12	0.12	0.11	0.09	0.12	0.08	0.22
28	0.09	0.09	0.09	0.08	0.08	0.07	0.10
29							
30							
31							

<b>Slow Sand/Membrane/DE Filtration/Unfiltered</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 1 NTU? 2	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
<b>Notes:</b>	PRINTED NAME: <b>Troy Van Roekel</b>		
	SIGNATURE: <i>Troy Van Roekel</i>		DATE: <b>3-2-2026</b>
	PHONE #: <b>503-809-1349</b>		<b>T-9282 D-3805</b>

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 Filtered systems only.

**OHA - Drinking Water Services - Surface Water Quality Data Form**

WTP- : **A**  
 Disinfection Giardia Log  
 Inactiv: **1.0**

System Name: **Banks Water Department ID#: 41 00076 Month/Year:**

Date / Time	Minimum Cl2 Residual at 1st User (C) 3	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 3	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1	0.77	201	154.8	8.50	7.4	47.4	YES	109
2	0.73	201	146.7	8.78	7.4	46.3	YES	109
3	0.70	201	140.7	8.94	7.4	45.7	YES	123
4	0.69	201	138.7	9.11	7.4	45.1	YES	129
5	0.71	201	142.7	8.83	7.41	46.2	YES	127
6	0.73	201	146.7	8.61	7.41	47.0	YES	131
7	0.78	201	156.8	8.78	7.42	46.9	YES	130
8	0.80	201	160.8	9.39	7.42	45.2	YES	127
9	0.64	201	128.6	9.17	7.41	44.8	YES	125
10	0.53	201	106.5	8.67	7.38	45.3	YES	76
11	0.52	201	104.5	8.17	7.37	46.6	YES	74
12	0.57	201	114.6	8.17	7.35	46.5	YES	95
13	0.73	201	146.7	8.39	7.34	46.5	YES	99
14	0.81	201	162.8	8.50	7.34	46.6	YES	94
15	0.84	201	168.8	8.61	7.35	46.6	YES	97
16	0.88	201	176.9	8.17	7.35	48.1	YES	96
17	0.88	201	176.9	7.78	7.37	49.8	YES	95
18	0.89	201	178.9	6.50	7.37	54.2	YES	102
19	0.90	201	180.9	5.61	7.4	58.2	YES	98
20	0.88	201	176.9	5.83	7.41	57.4	YES	99
21	0.86	201	172.9	6.11	7.43	56.7	YES	101
22	0.83	201	166.8	6.78	7.42	53.8	YES	103
23	0.80	201	160.8	7.22	7.42	52.1	YES	98
24	0.78	201	156.8	7.44	7.43	51.4	YES	98
25	0.77	201	154.8	7.28	7.43	51.9	YES	101
26	0.75	201	150.8	7.11	7.42	52.2	YES	99
27	0.76	201	152.8	7.00	7.4	52.3	YES	100
28	0.80	201	160.8	7.50	7.4	50.8	YES	104
29								
30								
31								

3 If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:  
 dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350