

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Washington**
 Month/Year: **March/2026**

System Name: **Banks Water Department** ID#: **41 00076** WTP: **TP - A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day 1 [NTU]
1	0.07	0.08	0.07	0.07	0.07	0.05	0.08
2	0.07	0.07	0.07	0.07	0.07	0.05	0.08
3	0.05	0.05	0.05	0.05	0.05	0.05	0.09
4	0.05	0.05	0.04	0.04	0.04	0.04	0.06
5	0.04	0.05	0.04	0.04	0.04	0.04	0.07
6	0.04	0.04	0.04	0.04	0.04	0.04	0.05
7	0.04	0.04	0.04	0.04	0.04	0.04	0.11
8	0.04	0.05	0.04	0.04	0.04	0.04	0.06
9	0.04	0.04	0.03	0.04	0.03	0.03	0.05
10	0.03	0.03	0.03	0.03	0.03	0.03	0.04
11	0.03	0.03	0.03	0.03	0.03	0.03	0.04
12	0.04	0.03	0.04	0.04	0.05	0.09	0.10
13	0.16	0.26	0.38	0.49	0.6	0.68	0.70
14	0.7	0.68	0.7	0.79	0.66	N/A	0.91
15	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16	N/A	N/A	0.79	0.60	0.69	0.57	0.80
17	0.51	0.46	0.39	0.32	0.28	0.25	0.51
18	0.23	0.23	0.22	0.19	0.16	0.16	0.24
19	0.16	0.16	0.16	0.14	0.13	0.12	0.17
20	0.12	0.13	0.12	0.11	0.09	0.09	0.14
21	0.11	0.11	0.11	0.09	0.08	0.08	0.11
22	0.09	0.11	0.11	0.09	0.08	0.07	0.11
23	0.08	0.09	0.09	0.08	0.08	0.07	0.11
24	0.08	0.09	0.09	0.08	0.07	0.07	0.12
25	0.07	0.08	0.15	0.08	0.07	0.07	0.15
26	0.08	0.09	0.09	0.07	0.07	0.05	0.09
27	0.12	0.08	0.08	0.07	0.05	0.07	0.12
28	0.08	0.11	0.11	0.08	0.07	0.07	0.11
29	0.09	0.12	0.11	0.08	0.07	0.07	0.12
30	0.08	0.11	0.11	0.08	0.07	0.07	0.12
31	0.08	0.15	0.15	0.08	0.07	0.07	0.17

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? 2	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes: Filter was offline from 7 PM 3/14 to 7 AM 3/16 due to high turbidity event.		PRINTED NAME: Troy Van Roekel	
		SIGNATURE: <i>Troy Van Roekel</i>	DATE: 4-1-26
		PHONE #: 503-809-1349	T-9282 D-3805

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not

correspond to continuous readings' maximum. 2 Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : **A**

System Name: **Banks Water Department ID#: 41 00076 Month/Year:** **Disinfection Giardia Log**
 Inactiv: **1.0**

Date / Time	Minimum Cl ₂ Residual at 1st User (C) 3	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 3	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.83	201	166.8	8.06	7.38	48.8	YES	101
2	0.85	201	170.9	8.72	7.38	46.8	YES	100
3	0.85	201	170.9	9.17	7.4	45.7	YES	103
4	0.89	201	178.9	9.56	7.4	44.8	YES	105
5	0.92	201	184.9	9.44	7.4	45.3	YES	107
6	0.92	201	184.9	9.28	7.42	46.1	YES	103
7	0.93	201	186.9	9.89	7.43	44.5	YES	104
8	0.92	201	184.9	10.00	7.42	44.0	YES	106
9	0.92	201	184.9	9.11	7.42	46.6	YES	104
10	0.92	201	184.9	8.28	7.35	48.0	YES	69
11	0.88	201	176.9	8.50	7.4	48.0	YES	51
12	0.87	201	174.9	9.00	7.44	47.1	YES	100
13	0.76	201	152.8	9.72	7.46	44.6	YES	98
14	0.71	201	142.7	9.28	7.45	45.5	YES	95
15	0.65	201	130.7	8.94	7.72	51.1	YES	37
16	0.62	201	124.6	9.28	7.42	44.6	YES	147
17	0.63	201	126.6	9.94	7.37	41.9	YES	143
18	0.78	201	156.8	10.61	7.35	40.5	YES	114
19	0.85	201	170.9	11.00	7.35	39.8	YES	114
20	0.86	201	172.9	11.39	7.37	39.1	YES	115
21	0.91	201	182.9	10.44	7.38	42.0	YES	114
22	0.92	201	184.9	9.89	7.42	44.3	YES	113
23	0.90	201	180.9	9.94	7.43	44.2	YES	116
24	0.92	201	184.9	10.33	7.43	43.2	YES	119
25	0.90	201	180.9	9.94	7.46	44.7	YES	117
26	0.89	201	178.9	9.11	7.49	47.7	YES	119
27	0.89	201	178.9	8.94	7.51	48.6	YES	119
28	0.90	201	180.9	9.50	7.51	46.9	YES	119
29	0.89	201	178.9	9.72	7.53	46.5	YES	117
30	0.90	201	180.9	9.22	7.55	48.5	YES	115
31	0.92	201	184.9	9.50	7.56	47.8	YES	114

3 If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350