


OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: BEND WATER DEPARTMENT			ID#: OR4100100		County: Deschutes		Month/Year:	Feb, 2021
					WTP: WTP-A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day [NTU]	
1	0.0128	0.0128	0.0128	0.0128	0.0128	0.0128	0.0152	
2	0.0128	0.0128	0.0127	0.0128	0.0128	0.0128	0.0131	
3	0.0128	0.0128	0.0129	0.0129	0.013	0.0129	0.0131	
4	0.0128	0.0129	0.0129	0.013	0.013	0.0129	0.015	
5	0.0128	0.0128	0.0128	0.0129	0.0128	0.0128	0.0132	
6	0.0128	0.0128	0.0128	0.0129	0.0129	0.0128	0.0131	
7	0.0128	0.0128	0.0129	0.0129	0.0129	0.0129	0.0132	
8	0.0128	0.0129	0.0132	0.013	0.013	0.0129	0.0141	
9	0.0128	0.0128	0.0129	0.0133	0.0129	0.0129	0.0149	
10	0.0129	0.0128	0.0129	0.013	0.0148	0.0129	0.0162	
11	0.0129	0.0129	0.0129	0.0129	0.0129	0.0129	0.013	
12	0.0129	0.013	0.013	0.0131	0.0131	0.013	0.0132	
13	0.0129	0.0129	0.0129	0.013	0.0131	0.013	0.0131	
14	0.0129	0.013	0.013	0.013	0.0129	0.0128	0.0131	
15	0.0128	0.0129	0.0129	0.0129	0.0129	0.0129	0.0139	
16	0.0129	0.0129	0.013	0.0131	0.013	0.0129	0.0131	
17	0.0128	0.0129	0.0129	0.0128	0.0128	0.0128	0.017	
18	0.0128	0.0128	0.0129	0.0129	0.0129	0.0128	0.0149	
19	0.0129	0.0128	0.0129	0.0129	0.0129	0.0129	0.013	
20	0.0129	0.0128	0.0129	0.0129	0.0129	0.0129	0.013	
21	0.0128	0.013	0.013	0.0129	0.0129	0.0128	0.0139	
22	0.0128	0.0128	0.0128	0.0128	0.0128	0.0127	0.0129	
23	0.0128	0.0128	0.0132	0.0129	0.0131	0.013	0.0145	
24	0.0129	0.013	0.013	0.0131	0.0131	0.0131	0.0166	
25	0.013	0.013	0.0131	0.013	0.013	0.0129	0.0161	
26	0.0129	0.013	0.0131	0.0131	0.0131	0.0132	0.0132	
27	0.0131	0.0131	0.0131	0.0131	0.0131	0.013	0.0131	
28	0.013	0.013	0.0129	0.013	0.013	0.0129	0.0131	
29								
30								
31								
Membrane					Monthly Summary (Answer Yes or No)			
95% of daily turbidity readings ≤ 1 NTU?			YES	CT's met everyday? (see back)		All Cl ₂ residual at entry point ≥ 0.2 mg/l?		
All daily turbidity readings ≤ 5 NTU?				YES	YES		YES	
Notes:					PRINTED NAME: Rod J. Mingus			
					SIGNATURE: 		3/5/2021	
					PHONE #: (541) 317-3000		CERT #: T-08557	

OHA - Drinking Water Services - Surface Water Quality Data Form