


OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: BEND WATER DEPARTMENT			ID#: OR4100100		County: Deschutes WTP: WTP-A		Month/Year: Nov, 2021	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day [NTU]	
1	0.0121	0.0121	0.0122	0.0122	0.0121	0.0121	0.0125	
2	0.0122	0.0121	0.0122	0.0121	0.0121	0.0122	0.0126	
3	0.0122	0.0121	0.0122	0.0122	0.0122	0.0122	0.0148	
4	0.0122	0.0122	0.0122	0.0126	0.0123	0.0123	0.02	
5	0.0122	0.0122	0.0122	0.0121	0.0122	0.0122	0.0137	
6	0.0122	0.0122	0.0122	0.0122	0.0122	0.0122	0.0125	
7	0.0122	0.0122	0.0122	0.0122	0.0122	0.0122	0.0124	
8	0.0122	0.0122	0.0122	0.0122	0.0122	0.0122	0.0134	
9	0.0122	0.0122	0.0122	0.0123	0.0122	0.0123	0.0133	
10	0.0123	0.0123	0.0123	0.0122	0.0121	0.0121	0.0162	
11	0.012	0.012	0.012	0.0122	0.0121	0.012	0.0523	
12	0.012	0.012	0.012	0.012	0.012	0.012	0.0123	
13	0.012	0.012	0.012	0.012	0.012	0.012	0.0124	
14	0.012	0.012	0.012	0.012	0.012	0.012	0.0122	
15	0.012	0.012	0.012	0.0121	0.012	0.012	0.0158	
16	0.012	0.012	0.012	0.012	0.0121	0.0121	0.0124	
17	0.0121	0.012	0.0121	0.0122	0.0121	0.0121	0.0251	
18	0.0121	0.0128	0.0121	0.0121	0.0121	0.0121	0.0179	
19	0.0121	0.0121	0.012	0.0121	0.0121	0.012	0.0133	
20	0.0121	0.0121	0.0121	0.0121	0.0121	0.0121	0.0124	
21	0.0121	0.0121	0.0121	0.0121	0.0121	0.0121	0.0124	
22	0.012	0.0121	0.0122	0.0122	0.0121	0.0121	0.0125	
23	0.0121	0.0121	0.0121	0.0121	0.0121	0.0121	0.0126	
24	0.0121	0.0122	0.0122	0.0121	0.0121	0.0121	0.1058	
25	0.0121	0.0121	0.0121	0.0121	0.0121	0.0121	0.0135	
26	0.0121	0.0121	0.0121	0.0121	0.0121	0.0121	0.0123	
27	0.0121	0.0121	0.0123	0.0122	0.0122	0.0122	0.0131	
28	0.0122	0.0122	0.0121	0.0121	0.0121	0.0121	0.0125	
29	0.0121	0.0121	0.0123	0.0121	0.0121	0.0121	0.0136	
30	0.0122	0.0122	0.0122	0.0122	0.0122	0.0122	0.0125	
31								
Membrane					Monthly Summary (Answer Yes or No)			
95% of daily turbidity readings ≤ 1 NTU?		YES		CT's met everyday? (see back)		All Cl ₂ residual at entry point ≥ 0.2 mg/l?		
All daily turbidity readings ≤ 5 NTU?		YES		YES		YES		
Notes:					PRINTED NAME: Rod J. Mingus			
					SIGNATURE: 		12/5/2021	
					PHONE #: (541) 317-3000		CERT #: T-08557	

