

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: BEND WATER DEPARTMENT			ID#: OR4100100		County: Deschutes WTP: WTP-A		Month/Year: Feb, 2022
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day [NTU]
1	0.0125	0.0125	0.0125	0.0126	0.0126	0.0126	0.0187
2	0.0126	0.0125	0.0125	0.0125	0.0126	0.0126	0.0131
3	0.0125	0.0126	0.0126	0.0126	0.0126	0.0125	0.0129
4	0.0126	0.0126	0.0126	0.0126	0.0125	0.0126	0.0128
5	0.0127	0.0127	0.0126	0.0126	0.0125	0.0125	0.0128
6	0.0125	0.0127	0.0126	0.0126	0.0126	0.0126	0.0128
7	0.0126	0.0126	0.0127	0.0126	0.0126	0.0125	0.0137
8	0.0126	0.0126	0.0126	0.0126	0.0125	0.0125	0.0127
9	0.0126	0.0127	0.0126	0.0126	0.0126	0.0126	0.019
10	0.0125	0.0126	0.0126	0.0126	0.0126	0.0125	0.0141
11	0.0126	0.0125	0.0126	0.0126	0.0126	0.0126	0.0127
12	0.0126	0.0126	0.0126	0.0126	0.0125	0.0125	0.0128
13	0.0126	0.0126	0.0125	0.0126	0.0126	0.0126	0.0127
14	0.0125	0.0126	0.0126	0.0126	0.0126	0.0125	0.0137
15	0.0126	0.0126	0.0126	0.0126	0.0126	0.0125	0.0128
16	0.0125	0.0126	0.0125	0.0131	0.0126	0.0126	0.0175
17	0.0126	0.0126	0.0126	0.0125	0.0125	0.0125	0.0137
18	0.0126	0.0126	0.0126	0.0125	0.0125	0.0125	0.0128
19	0.0126	0.0126	0.0126	0.0125	0.0125	0.0125	0.0127
20	0.0126	0.0126	0.0126	0.0126	0.0126	0.0125	0.0127
21	0.0125	0.0126	0.0126	0.0125	0.0126	0.0126	0.0139
22	0.0125	0.0126	0.0126	0.0125	0.0126	0.0126	0.0128
23	0.0126	0.0125	0.0131	0.0126	0.0126	0.0126	0.0201
24	0.0128	0.0125	0.0127	0.0126	0.0126	0.0126	0.0144
25	0.0125	0.0125	0.0125	0.0125	0.0126	0.0126	0.0127
26	0.0125	0.0126	0.0126	0.0126	0.0126	0.0126	0.0127
27	0.0126	0.0126	0.0126	0.0126	0.0125	0.0125	0.0127
28	0.0125	0.0126	0.0127	0.0126	0.0126	0.0126	0.0134
29							
30							
31							
Membrane					Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings ≤ 1 NTU?				YES	CT's met everyday? (see back)		All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?				YES	YES		YES
Notes:					PRINTED NAME: Rod J. Mingus		
					SIGNATURE: 		3/7/2022
					PHONE #: (541) 317-3000		CERT #: T-08557

