

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: BEND WATER DEPARTMENT			ID#: OR4100100		County: Deschutes WTP: WTP-A		Month/Year: Apr, 2022
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day [NTU]
1	0.0122	0.0122	0.0123	0.0123	0.0122	0.0123	0.013
2	0.0122	0.0122	0.0122	0.0123	0.0123	0.0122	0.0126
3	0.0122	0.0123	0.0123	0.0123	0.0123	0.0123	0.0124
4	0.0123	0.0123	0.0123	0.0124	0.0124	0.0124	0.013
5	0.0125	0.0124	0.0124	0.0125	0.0124	0.0124	0.0127
6	0.0125	0.0125	0.0125	0.0125	0.0124	0.0125	0.0137
7	0.0124	0.0125	0.0124	0.0124	0.0123	0.0124	0.0126
8	0.0123	0.0124	0.0124	0.0124	0.0124	0.0124	0.0127
9	0.0124	0.0124	0.0124	0.0124	0.0124	0.0124	0.0126
10	0.0124	0.0123	0.0125	0.0123	0.0123	0.0124	0.0126
11	0.0124	0.0123	0.0123	0.0124	0.0124	0.0123	0.0142
12	0.0123	0.0124	0.0124	0.0124	0.0124	0.0123	0.0125
13	0.0123	0.0124	0.0124	0.0125	0.0126	0.0124	0.0878
14	0.0124	0.0124	0.0124	0.0125	0.0124	0.0124	0.0242
15	0.0125	0.0125	0.0124	0.0124	0.0125	0.0124	0.0144
16	0.0123	0.0125	0.0125	0.0124	0.0124	0.0123	0.0131
17	0.0124	0.0124	0.0124	0.0123	0.0123	0.0123	0.0129
18	0.0124	0.0124	0.0124	0.0124	0.0123	0.0123	0.0126
19	0.0124	0.0124	0.0124	0.0124	0.0123	0.0122	0.013
20	0.0122	0.0122	0.0122	0.0122	0.0122	0.0122	0.0175
21	0.0122	0.0122	0.0123	0.0123	0.0122	0.0122	0.0174
22	0.0122	0.0122	0.0122	0.0122	0.0122	0.0122	0.0124
23	0.0121	0.0123	0.0122	0.0122	0.0122	0.0121	0.0124
24	0.0122	0.0122	0.0122	0.0122	0.0122	0.0122	0.0123
25	0.0122	0.0122	0.0122	0.0122	0.0122	0.0121	0.0142
26	0.0122	0.0122	0.0122	0.0123	0.0122	0.0122	0.0124
27	0.0122	0.0122	0.0122	0.0123	0.0121	0.0121	0.0148
28	0.0121	0.0122	0.0128	0.0122	0.0122	0.0121	0.0154
29	0.0121	0.0122	0.0122	0.0121	0.0121	0.0121	0.0123
30	0.0121	0.0122	0.0122	0.0122	0.0121	0.0121	0.0123
31							
Membrane					Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings ≤ 1 NTU?				YES	CT's met everyday? (see back)		All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?				YES	YES		YES
Notes:					PRINTED NAME: Rod J. Mingus		
					SIGNATURE: 		5/5/2022
					PHONE #: (541) 317-3000		CERT #: T-08557

