


OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: BEND WATER DEPARTMENT			ID#: OR4100100		County: Deschutes WTP: WTP-A		Month/Year: Jun, 2022
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day [NTU]
1	0.0129	0.0129	0.0129	0.0129	0.0128	0.0128	0.0132
2	0.0129	0.0129	0.0129	0.013	0.0129	0.0128	0.0254
3	0.0129	0.0129	0.0129	0.0129	0.0129	0.0129	0.0154
4	0.0129	0.0129	0.0129	0.0129	0.0129	0.0128	0.0137
5	0.0128	0.0128	0.0143	0.0144	0.0143	0.0141	0.0153
6	n/a	n/a	n/a	n/a	n/a	n/a	n/a
7	n/a	n/a	n/a	n/a	n/a	n/a	n/a
8	n/a	n/a	n/a	n/a	n/a	n/a	n/a
9	n/a	n/a	n/a	n/a	n/a	n/a	n/a
10	n/a	n/a	n/a	n/a	n/a	n/a	n/a
11	n/a	n/a	n/a	n/a	n/a	n/a	n/a
12	n/a	n/a	n/a	n/a	n/a	n/a	n/a
13	n/a	n/a	n/a	n/a	n/a	n/a	n/a
14	0.0304	0.0311	0.0308	0.0129	0.0129	0.0129	0.1256
15	0.0128	0.0129	0.0129	0.0129	0.0129	0.0129	0.042
16	0.0129	0.0129	0.015	0.0129	0.0133	0.0132	0.0168
17	0.0132	0.0133	0.0132	0.0133	0.0132	0.0132	0.0142
18	0.0132	0.0133	0.0133	0.0133	0.0132	0.0132	0.0136
19	0.0132	0.0133	0.0133	0.0133	0.0132	0.0132	0.0135
20	0.0132	0.0133	0.0133	0.0133	0.0133	0.0132	0.0151
21	0.0132	0.0133	0.0133	0.0133	0.0132	0.0132	0.0814
22	0.0132	0.0133	0.0133	0.0133	0.0133	0.0132	0.0786
23	0.0132	0.0133	0.0134	0.0133	0.0132	0.0132	0.0228
24	0.0132	0.0133	0.0133	0.0133	0.0133	0.0132	0.015
25	0.0132	0.0132	0.0133	0.0133	0.0132	0.0132	0.0141
26	0.0132	0.0132	0.0133	0.0133	0.0133	0.0132	0.0136
27	0.0132	0.0133	0.0133	0.0133	0.0133	0.0132	0.0141
28	0.0131	0.0133	0.0133	0.0134	0.0133	0.0132	0.0159
29	0.0133	0.0133	0.0133	0.0133	0.0133	0.0132	0.0158
30	0.0132	0.0133	0.0133	0.0133	0.0133	0.0133	0.0178
31							
Membrane					Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings ≤ 1 NTU?		YES		CT's met everyday? (see back)		All Cl ₂ residual at entry point ≥ 0.2 mg/l?	
All daily turbidity readings ≤ 5 NTU?		YES		YES		YES	
Notes:					PRINTED NAME: Rod J. Mingus		
n/a or 0 = Down for Repairs/Maintenance					SIGNATURE: 		7/5/2022
					PHONE #: (541) 317-3000		CERT #: T-08557

