

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: BEND WATER DEPARTMENT			ID#: OR4100100		County: Deschutes WTP: WTP-A		Month/Year: Sep, 2022
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day [NTU]
1	0.0134	0.0135	0.0137	0.0135	0.0134	0.0134	0.0147
2	0.0135	0.0135	0.0136	0.0135	0.0134	0.0134	0.0138
3	0.0137	0.0138	0.0136	0.0136	0.0135	0.0134	0.0139
4	0.0135	0.0135	0.0135	0.0135	0.0135	0.0135	0.0137
5	0.0135	0.0136	0.0136	0.0136	0.0135	0.0135	0.0155
6	0.0135	0.0136	0.0136	0.0136	0.0135	0.0135	0.0137
7	0.0136	0.0136	0.0136	0.0136	0.0134	0.0135	0.015
8	0.0135	0.0135	0.0135	0.0135	0.0134	0.0134	0.015
9	0.0135	0.0135	0.0135	0.0135	0.0135	0.0135	0.0136
10	0.0136	0.0136	0.0136	0.0137	0.0135	0.0135	0.0141
11	0.0135	0.0136	0.0136	0.0136	0.0136	0.0135	0.0136
12	0.0135	0.0135	0.0136	0.0136	0.0135	0.0135	0.0147
13	0.0136	0.0136	0.0136	0.0136	0.0136	0.0136	0.0137
14	0.0136	0.0137	0.0137	0.0136	0.0135	0.0135	0.0138
15	0.0136	0.0136	0.0136	0.014	0.0138	0.0138	0.0154
16	0.0138	0.0138	0.0138	0.0138	0.0138	0.0138	0.0139
17	0.0138	0.0138	0.0138	0.0138	0.0138	0.0138	0.0139
18	0.0139	0.0139	0.0138	0.0138	0.0139	0.0138	0.014
19	0.0139	0.0139	0.0139	0.0139	0.0139	0.0138	0.0144
20	0.0139	0.0139	0.0139	0.0139	0.0139	0.0138	0.014
21	0.0139	0.0139	0.0141	0.0139	0.0139	0.0139	0.019
22	0.0139	0.0139	0.0139	0.0139	0.0138	0.0138	0.0147
23	0.0139	0.0139	0.0139	0.0139	0.0139	0.0139	0.014
24	0.0139	0.0139	0.0139	0.0139	0.0139	0.0139	0.014
25	0.0139	0.0139	0.0139	0.0139	0.0139	0.0139	0.014
26	0.0139	0.0139	0.0139	0.0139	0.0139	0.0139	0.0142
27	0.0139	0.0139	0.0139	0.0139	0.0139	0.0139	0.014
28	0.0139	0.0139	0.0139	0.0139	0.0139	0.0139	0.014
29	0.0139	0.0139	0.0139	0.0139	0.0138	0.0138	0.0162
30	0.0139	0.014	0.0139	0.0139	0.0138	0.0138	0.014
31							
Membrane					Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings ≤ 1 NTU?				YES	CT's met everyday? (see back)		All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?				YES	YES		YES
Notes:					PRINTED NAME: Rod J. Mingus		
					SIGNATURE: 		10/5/2022
					PHONE #: (541) 317-3000		CERT #: T-08557

