


**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

<b>System Name:</b> <b>BEND WATER DEPARTMENT</b>			<b>ID#:</b> <b>OR4100100</b>		<b>County: Deschutes</b> <b>WTP: WTP-A</b>		<b>Month/Year:</b> <b>Nov, 2022</b>
<b>Day</b>	<b>12 AM</b> <b>[NTU]</b>	<b>4 AM</b> <b>[NTU]</b>	<b>8 AM</b> <b>[NTU]</b>	<b>NOON</b> <b>[NTU]</b>	<b>4 PM</b> <b>[NTU]</b>	<b>8 PM</b> <b>[NTU]</b>	<b>Highest Reading of the day</b> <b>[NTU]</b>
1	n/a	n/a	n/a	n/a	n/a	n/a	n/a
2	n/a	n/a	n/a	n/a	n/a	n/a	n/a
3	n/a	n/a	n/a	n/a	n/a	n/a	n/a
4	n/a	n/a	n/a	n/a	n/a	n/a	n/a
5	n/a	n/a	n/a	n/a	n/a	n/a	n/a
6	n/a	n/a	n/a	n/a	n/a	n/a	n/a
7	n/a	n/a	n/a	n/a	n/a	n/a	n/a
8	n/a	n/a	n/a	n/a	n/a	n/a	n/a
9	n/a	n/a	n/a	n/a	n/a	n/a	n/a
10	n/a	n/a	n/a	n/a	n/a	n/a	n/a
11	n/a	n/a	n/a	n/a	n/a	n/a	n/a
12	n/a	n/a	n/a	n/a	n/a	n/a	n/a
13	n/a	n/a	n/a	n/a	n/a	n/a	n/a
14	n/a	n/a	n/a	n/a	n/a	n/a	n/a
15	n/a	n/a	n/a	n/a	n/a	n/a	n/a
16	0.1496	0.1494	0.1526	0.1577	0.0138	0.0138	0.1761
17	0.0137	0.0143	0.0144	0.0137	0.0138	0.0138	0.0413
18	0.0138	0.0137	0.0138	0.0137	0.0136	0.0136	0.0208
19	0.0136	0.0136	0.0136	0.0136	0.0136	0.0136	0.0155
20	0.0136	0.0136	0.0135	0.0135	0.0136	0.0136	0.016
21	0.0136	0.0136	0.0137	0.0138	0.014	0.014	0.0169
22	0.0141	0.0143	0.0143	0.0143	0.0144	0.0146	0.0151
23	0.0148	0.0147	0.015	0.0154	0.0158	0.0159	0.0202
24	0.0161	0.0162	0.0152	0.0155	0.0157	0.0159	0.0166
25	0.0162	0.0167	0.0175	0.0181	0.0189	0.0191	0.0198
26	0.0198	0.0204	0.0211	0.0223	0.0236	0.0239	0.0242
27	0.0231	0.0232	0.0231	0.025	0.0272	0.0271	0.028
28	0.027	0.0284	0.0307	0.034	0.0321	0.0352	0.039
29	0.0388	0.0381	0.0372	0.0367	0.0374	0.0403	0.041
30	0.0404	0.0402	0.033	0.0344	0.036	0.0336	0.0421
31							
<b>Membrane</b>					<b>Monthly Summary (Answer Yes or No)</b>		
95% of daily turbidity readings ≤ 1 NTU?		<b>YES</b>			CT's met everyday? (see back)		All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?		<b>YES</b>			<b>YES</b>		<b>YES</b>
<b>Notes:</b>					<b>PRINTED NAME:</b> <b>Rod J. Mingus</b>		
<b>n/a or 0 = Down for Repairs/Maintenance</b>					<b>SIGNATURE:</b> 		<b>12/5/2022</b>
					<b>PHONE #:</b> <b>(541) 317-3000</b>		<b>CERT #:</b> <b>T-08557</b>

