

OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: BEND WATER DEPARTMENT			ID#: OR4100100		County: Deschutes WTP: WTP-A		Month/Year: Feb, 2023
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day [NTU]
1	0.0162	0.0163	0.0163	0.0163	0.0163	0.0163	0.0199
2	0.0165	0.0164	0.0164	0.0163	0.0162	0.0163	0.0168
3	0.0165	0.0166	0.0165	0.0165	0.0163	0.0164	0.0167
4	0.0164	0.0165	0.0164	0.0164	0.0163	0.0165	0.0166
5	0.0165	0.0165	0.0164	0.0163	0.016	0.016	0.0167
6	0.0161	0.016	0.0159	0.0157	0.0158	0.0157	0.0171
7	0.0161	0.0162	0.0161	0.0159	0.0159	0.0159	0.0164
8	0.016	0.0158	0.0157	0.0155	0.0155	0.0154	0.0161
9	0.0157	0.0158	0.0155	0.0156	0.0155	0.0155	0.0204
10	0.0158	0.0159	0.0158	0.0158	0.0158	0.0158	0.016
11	0.016	0.0159	0.0159	0.0157	0.0156	0.0155	0.0161
12	0.0156	0.0156	0.0155	0.0155	0.0152	0.0153	0.0163
13	0.0156	0.0157	0.0157	0.0157	0.0157	0.0155	0.0167
14	0.0153	0.0151	0.0147	0.0145	0.0145	0.0146	0.0154
15	0.0147	0.0149	0.0152	0.0151	0.0151	0.015	0.0513
16	0.0151	0.0152	0.0153	0.0151	0.0151	0.0151	0.0249
17	0.0153	0.0153	0.0152	0.0151	0.015	0.0151	0.0156
18	0.0152	0.0153	0.0152	0.0152	0.0153	0.0154	0.0156
19	0.0155	0.0154	0.0154	0.0153	0.0153	0.0155	0.0156
20	0.0155	0.0156	0.0156	0.0155	0.0155	0.0156	0.0164
21	0.0155	0.0156	0.0156	0.0156	0.0145	0.0145	0.0157
22	0.0145	0.0145	0.0145	0.0151	0.0151	0.015	0.0159
23	0.0151	0.0151	0.0151	0.0151	0.0149	0.0148	0.0186
24	0.0149	0.0148	0.0148	0.015	0.0149	0.0148	0.0198
25	0.0148	0.015	0.015	0.015	0.0149	0.0151	0.0153
26	0.0153	0.0154	0.0154	0.0154	0.0153	0.0152	0.0156
27	0.0152	0.0152	0.0153	0.0152	0.0152	0.0153	0.016
28	0.0153	0.0154	0.0146	0.0152	0.015	0.0149	0.0161
29							
30							
31							
Membrane					Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings ≤ 1 NTU?				YES	CT's met everyday? (see back)		All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?				YES	YES		YES
Notes:					PRINTED NAME: Rod J. Mingus		
					SIGNATURE: 		3/5/2023
					PHONE #: (541) 317-3000		CERT #: T-08557

