


**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: <b>BEND WATER DEPARTMENT</b>			ID#: <b>OR4100100</b>		County: Deschutes <b>WTP: WTP-A</b>		Month/Year: <b>Apr, 2021</b>
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day [NTU]
1	0.0144	0.0145	0.0146	0.0147	0.0147	0.0142	0.0156
2	0.0144	0.0146	0.0147	0.0147	0.0147	0.0144	0.0148
3	0.0143	0.0146	0.0147	0.0147	0.0147	0.0145	0.0148
4	0.0142	0.0145	0.0146	0.0147	0.0147	0.0144	0.0148
5	0.0144	0.0145	0.0147	0.0147	0.0147	0.0147	0.0153
6	0.0146	0.0147	0.0147	0.0147	0.0147	0.0146	0.0148
7	0.0144	0.0147	0.0147	0.0149	0.0148	0.0146	0.0241
8	0.0142	0.0148	0.0148	0.0147	0.0147	0.0146	0.0159
9	0.0146	0.0147	0.0147	0.0146	0.0147	0.0146	0.0148
10	0.0145	0.0147	0.0148	0.0147	0.0147	0.0147	0.0148
11	0.0147	0.0147	0.0147	0.0146	0.0147	0.0147	0.0152
12	0.0146	0.0148	0.0148	0.0146	0.0147	0.0147	0.0154
13	0.0147	0.0148	0.0148	0.0147	0.0147	0.0146	0.0149
14	0.0147	0.0148	0.0147	0.0147	0.0148	0.0147	0.0172
15	0.0146	0.0148	0.0148	0.0148	0.0147	0.0144	0.0161
16	0.0145	0.0148	0.0148	0.0148	0.0148	0.0144	0.0149
17	0.0145	0.0149	0.0149	0.0148	0.0148	0.0142	0.015
18	0.0146	0.0149	0.0148	0.0148	0.0147	0.0142	0.015
19	0.0146	0.0149	0.0149	0.0148	0.0148	0.0143	0.0166
20	0.0147	0.0149	0.0148	0.0147	0.0148	0.0145	0.015
21	0.0148	0.0149	0.0147	0.0148	0.0164	0.0146	0.0275
22	0.0149	0.015	0.0149	0.0149	0.015	0.0147	0.0288
23	0.015	0.0151	0.015	0.0148	0.015	0.0148	0.019
24	0.0148	0.0151	0.015	0.0149	0.015	0.0148	0.0153
25	0.0149	0.015	0.0148	0.0148	0.0149	0.015	0.0152
26	0.015	0.0149	0.0149	0.0148	0.0149	0.0148	0.0167
27	0.0148	0.0148	0.0147	0.0146	0.0148	0.0147	0.0149
28	0.0148	0.015	0.0147	0.0131	0.013	0.0131	0.0152
29	0.013	0.0131	0.0131	0.0131	0.013	0.013	0.0203
30	0.013	0.0131	0.0131	0.013	0.0129	0.0129	0.0148
31							
<b>Membrane</b>					<b>Monthly Summary (Answer Yes or No)</b>		
95% of daily turbidity readings ≤ 1 NTU?		<b>YES</b>		CT's met everyday? (see back)		<b>YES</b>	
All daily turbidity readings ≤ 5 NTU?		<b>YES</b>		All Cl2 residual at entry point ≥ 0.2 mg/l?		<b>YES</b>	
<b>Notes:</b>					<b>PRINTED NAME: Rod J. Mingus</b>		
<b>n/a or 0 = Down for Repairs/Maintenance</b>					<b>SIGNATURE:</b> 		<b>5/5/2021</b>
					<b>PHONE #:</b> (541) 317-3000		<b>CERT #:</b> T-08557

