


OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: BEND WATER DEPARTMENT			ID#: OR4100100		County: Deschutes WTP: WTP-A		Month/Year: Jun, 2021	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day [NTU]	
1	0.0134	0.0134	0.0134	0.0134	0.0133	0.0132	0.1491	
2	0.0133	0.0134	0.0134	0.0134	0.0132	0.0131	0.0145	
3	0.0132	0.0134	0.0133	0.0133	0.0132	0.0131	0.0148	
4	0.0132	0.0134	0.0133	0.0133	0.0131	0.0131	0.0136	
5	0.0132	0.0133	0.0133	0.0133	0.0132	0.0131	0.0134	
6	0.0132	0.0133	0.0134	0.0134	0.0133	0.0131	0.015	
7	0.0132	0.0134	0.0134	0.0134	0.0133	0.0132	0.0143	
8	0.0133	0.0135	0.0134	0.0135	0.0134	0.0132	0.0379	
9	0.0133	0.0134	0.0135	0.0135	0.0133	0.0132	0.0503	
10	0.0132	0.0134	0.0134	0.0134	0.0133	0.0132	0.0157	
11	0.0134	0.0134	0.0134	0.0134	0.0132	0.0133	0.0138	
12	0.0133	0.0134	0.0134	0.0133	0.0133	0.0132	0.0146	
13	0.0133	0.0134	0.0133	0.0133	0.0131	0.0131	0.0145	
14	0.0133	0.0134	0.0133	0.0131	0.0139	0.0134	0.0159	
15	0.0131	0.0135	0.0136	0.0131	0.0133	0.0129	0.2756	
16	0.0129	0.0132	0.0135	0.0135	0.0132	0.0127	0.0142	
17	0.0127	0.0132	0.0134	0.0135	0.0147	0.0143	0.0159	
18	0.0142	0.0144	0.0141	0.0141	0.0141	0.0141	0.0148	
19	0.014	0.0141	0.0141	0.0139	0.014	0.014	0.0142	
20	0.014	0.0141	0.0141	0.014	0.014	0.014	0.0142	
21	0.0141	0.0141	0.0141	0.0141	0.014	0.014	0.0159	
22	0.0141	0.014	0.014	0.0141	0.0141	0.0141	0.0241	
23	0.014	0.0139	0.0139	0.014	0.014	0.014	0.0148	
24	0.0139	0.014	0.0142	0.014	0.0139	0.014	0.0165	
25	0.0139	0.0141	0.014	0.0139	0.014	0.0139	0.0144	
26	0.0138	0.014	0.014	0.014	0.0139	0.0139	0.0142	
27	0.0139	0.014	0.0142	0.0141	0.014	0.014	0.0142	
28	0.014	0.014	0.0142	0.0142	0.0141	0.014	0.0159	
29	0.014	0.014	0.0142	0.0143	0.0141	0.0141	0.0143	
30	0.014	0.014	0.0141	0.0141	0.014	0.014	0.046	
31								
Membrane					Monthly Summary (Answer Yes or No)			
95% of daily turbidity readings ≤ 1 NTU?		YES		CT's met everyday? (see back)		All Cl ₂ residual at entry point ≥ 0.2 mg/l?		
All daily turbidity readings ≤ 5 NTU?		YES		YES		YES		
Notes:					PRINTED NAME: Rod J. Mingus			
					SIGNATURE: 		7/5/2021	
					PHONE #: (541) 317-3000		CERT #: T-08557	

