

OHA - Drinking Water Services - Turbidity Monitoring Report  
 Conventional or Direct Filtration

County: Columbia

Name: FISHWALK LAKE RESERVE AND COMMUNITY ID #41: 00124 WTP: A Month/Year: JAN/2021

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	PO	PO	PO	.026	PO	PO	.036
2	PO	PO	.058	.058	.037	PO	.161 BW
3	PO	PO	PO	PO	PO	PO	P.O.
4	PO	PO	PO	PO	PO	PO	P.O.
5	PO	PO	.090	PO	.029	PO	.295 BW
6	PO	PO	PO	.206	.034	.024	.217
7	PO	PO	.029	.041	.069	PO	.071
8	PO	PO	PO	.074	.153	.025	.295 B/w
9	.024	PO	PO	.028	.201	PO	.203 B/w
10	PO	PO	PO	.193	PO	PO	<del>.203</del> .204
11	PO	PO	.080	.027	.090	PO	.106 B/w
12	PO	PO	PO	PO	PO	PO	PO
13	PO	PO	PO	PO	PO	PO	PO
14	PO	PO	PO	PO	P.O	PO	PO
15	PO	PO	.029	.027	PO	PO	.115
16	PO	PO	B/w	.084	PO	PO	.142 B/w .204
17	PO	PO	FTW	.025	.026	.027	.295 B/w
18	PO	PO	PO	<del>.033</del>	.033	.032	B/w .133
19	.031	.031	.030	.037	.033	PO	.159 B/w
20	PO	PO	.035	.029	.029	PO	.044
21	PO	PO	.038	.034	.033	PO	.221 BW
22	PO	PO	.047	.032	.032	PO	.047
23	PO	PO	PO	.032	.031	PO	.044
24	PO	PO	PO	.040	.034	.036	.266 BW
25	PO	PO	PO	.041	.066	PO	.114
26	PO	PO	PO	.116	.039	.032	.295 BW
27	PO	PO	.039	.031	PO	PO	.039
28	PO	PO	.033	.032	.033	PO	.045
29	PO	PO	PO	.038	.036	PO	.259 BW
30	PO	PO	PO	.034	.034	.035	.039
31	PO	PO	PO	.038	.040	.045	.246 BW

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	All Cl <sub>2</sub> residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Notes:		
All turbidity readings < IFE <sup>2</sup> triggers? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	PRINTED NAME: Kevin Adolphson		
SIGNATURE: Kevin Adolphson		DATE: 02 JAN 21	
PHONE #: (503) 755-0218		FE-0104 CERT #: T-08704-II D-28783-I	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Indivd. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

# OHA - Drinking Water Program - Surface Water Quality Data Form

FISHHAWK LAKE REC CLUB INC ID #: OR4100124 WTP: WTP-A Month/Year: JAN/2021

Required Log Inactivation: 1.0

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/9:15	0.78	62	60.7	7.4	7.1	47	Yes	55
2/8:50	0.94		58.2	8.1	7.1	44	Y	
3/ P.O.	P.O.		P.O.	8.4	7.1	44	P.O.	
4/ P.O.	P.O.		P.O.	8.5	7.1	44	P.O.	
5/8:50	0.89		55.1	9.3	7.0	38	Y	
6/9:05	0.95		58.9	9.4	7.1	41	Y	
7/9:30	0.97		60.1	8.9	7.1	44	Y	
8/9:00	0.92		57.0	9.0	7.1	41	Y	
9/9:30	0.90		55.8	8.7	7.0	42	Y	
10/10:00	0.82	62	50.8	8.1	7.0	42	Y	55
11/10:30	0.80		49.6	8.0	7.1	43	Y	
12/	P.O.		P.O.	8.2	7.1	P.O.	P.O.	
13/	P.O.		P.O.	8.3	7.1	P.O.	P.O.	
14/	P.O.		P.O.	8.4	7.1	P.O.	P.O.	
15/8:54	0.86		53.3	8.9	7.1	43	Y	
16/8:50	0.90		55.8	8.8	7.0	42	Y	
17/07:30	0.92		57.4	9.0	7.0	39	Y	
18/9:55	1.03		63.8	8.7	7.2	46	Y	
19/12:10	1.06		65.7	7.4	7.1	47	Y	
20/8:40	0.99	62	61.3	7.0	7.1	47	Y	55
21/8:55	0.98		60.7	6.6	7.2	51	Y	
22/8:50	0.96		59.5	6.8	7.3	53	Y	
23/10:45	0.97		60.1	7.2	7.1	47	Y	
24/11:05	0.95		58.9	6.8	7.1	49	Y	
25/9:25	0.93		57.6	6.0	7.1	49	Y	
26/9:05	0.88		54.5	5.6	7.2	54	Y	
27/8:55	0.92		57.0	5.6	7.1	52	Y	
28/8:20	0.94		58.2	5.5	7.3	56	Y	
29/9:50	0.92		57.0	5.4	7.3	56	Y	
30/10:15	0.90		55.8	6.0	7.3	53	Y	
31/		62		6.2	7.2	51	Y	55

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.