

OHA - Drinking Water Program – Turbidity Monitoring Report Form County: COLUMBIA
Conventional or Direct Filtration

System Name: FISHHANK LAKE RESERVE AND COMMUNITY ID #: 41-00124 WTP: A Month/Year: OCT/2021

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	pc	pc	pc	.038	pc	.071	.258 BW
2	.037	pc	pc	.038	.044	.047	.219 BW
3	pc	pc	pc	.043	.040	.039	.132 B/W
4	.039	pc	pc	.038	.037	.037	.8/W .161
5	.043	.038	pc	pc	pc	pc	.038
6	pc	pc	pc	pc	pc	pc	pc
7	pc	pc	pc	pc	.044	pc	.124 BW
8	pc	pc	pc	.039	.039	pc	.275 BW
9	BW	.039	.037	.037	.038	.037	.228 BW
10	pc	pc	pc	.037	.037	pc	.180 BW
11	pc	pc	pc	.039	.039	.040	.192 B/W
12	pc	pc	BW	.042	.040	pc	.295 BW
13	pc	pc	pc	.040	.039	.039	.295 BW
14	pc	pc	pc	.040	.039	pc	.295 BW
15	pc	pc	pc	.042	.041	pc	.295 B/W
16	pc	pc	B/W	.043	.044	pc	.295 B/W
17	pc	pc	.061	.043	.042	.042	.295 B/W
18	pc	pc	pc	.045	.046	pc	.295 BW
19	pc	pc	pc	.059	.054	.050	.295 BW
20	.231	pc	.045	.045	pc	pc	.295 B/W
21	pc	pc	pc	pc	.178	pc	.295 BW
22	pc	pc	.052	.048	.121	pc	.295 BW
23	pc	pc	pc	.047	.043	.042	.295 BW
24	.043	.043	BW	.046	power out again	pc	.295 BW
25	pc	pc	pc	.048	pc	pc	.1098
26	pc	pc	pc	.045	pc	.047	.119 B/W
27	pc	pc	pc	.060	.077	pc	.119 BW
28	pc	pc	pc	.102	pc	pc	.239
29	pc	pc	pc	pc	.093	pc	.239 B/W
30	pc	pc	.048	.095	pc	pc	.295 B/W
31	pc	pc	.085	pc	pc	pc	.295 B/W

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings \leq 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residuals at entry point \geq 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No	
All the 4-hour turbidity readings \leq 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No			
All turbidity readings < IFE ² triggers? <input checked="" type="radio"/> Yes / <input type="radio"/> No			
Notes:	PRINTED NAME: Kevin Adolphson		
	SIGNATURE: Kevin Adolphson		DATE: 05 NOV 21
	PHONE #: (503) 755-0218		CERT #: FE-0104 T-09781-II D-03703-I

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ²IFE = Individ. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

FISHHAWK LAKE REC CLUB INC ID #: OR4100124 WTP: WTP-A Month/Year: OCT/2021

Required Log Inactivation: 1.0

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ¹	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1/19:00	0.99	62	61.3	12.7	7.1	33	Yes	55
2/20:50	0.94		58.2	12.5	7.2	35	Y	
3/8:52	0.71		44.0	11.9	7.1	36	Y	
4/0:00	1.10		62.2	11.0	7.2	38	Y	
5/02:00	1.24		76.5	11.4	7.2	38	Y	
6/PO	PO						PO	
7/14:00	0.78		48.3	11.9	7.2	37	YES	
8/9:55	1.17		72.5	12.0	7.1	34	Y	
9/22:40	0.96		59.5	10.0	7.2	40	Y	
10/09:50	0.83		49.6	9.6	7.2	42	Y	
11/07:50	0.78		48.3	10.0	7.2	40	Y	
12/10:00	0.72		44.6	9.8	7.2	42	Y	
13/10:00	0.69		42.7	9.3	7.2	42	Y	
14/09:00	0.90		55.8	8.7	7.2	46	Y	
15/09:45	0.78	62	48.3	9.6	7.2	42	Y	55
16/10:00	0.76		47.1	9.8	7.1	41	Y	
17/09:15	0.68		42.1	10.4	7.1	38	Y	
18/10:20	0.76		47.1	10.9	7.2	40	Y	
19/11:50	0.70		43.4	10.4	7.2	40	Y	
20/10:00	0.98		60.7	9.3	7.2	43	Y	
21/16:20	1.00		62.0	9.4	7.2	45	Y	
22/08:37	0.82		50.8	10.0	7.2	40	Y	
23/12:28	0.66		40.9	10.2	7.2	40	Y	
24/9:15	0.77		47.7	10.7	7.2	40	Y	
25/09:30	0.63		39.0	11.6	7.2	38	Y	
26/10:50	0.67		41.5	11.2	7.2	35	Y	
27/09:45	0.64		39.6	11.0	7.1	36	Y	
28/11:00	0.78		48.3	11.1	7.2	37	Y	
29/15:30	0.75		46.5	11.4	7.2	37	Y	
30/08:30	0.80		49.6	11.7	7.2	36	Y	
31/10:45	0.94	62	59.5	11.0	7.1	36	Y	55

¹ If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day