

OHA - Drinking Water Program – Turbidity Monitoring Report Form County:
Conventional or Direct Filtration

System Name: FISHHAWK LAKE RESERVE AND COMMUNITY **ID #:** 41-00124 **WTP-:** A **Month/Year:** JAN/2022

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	.071	.070	.070	.135	.072	.072	.251 B/W
2	.072	.072	.071	.076	.074	.073	.200 B/W
3	po	po	power out	.076	.078	.259	.236 B/W
4	po	po	.209	.078	.105	.157	.295 BW
5	po	po	.240	.114	.074	.075	.295 BW
6	.075	po	po	po	po	po	.075
7	po	po	po	po	po	po	po
8	po	po	po	po	po	po	po
9	po	po	po	po	.081	.076	.295 BW
10	.073	.072	.072	po	po	po	.073
11	po	po	po	.089	.073	.073	.295 BW
12	.077	.090	.099	.250	.076	.080	.295 BW
13	.107	.150	.205	BW	.081	.074	.295 BW
14	.073	.074	.076	B/W	.169	.206	.216 B/W
15	.236	.269	po	.086	.091	po	.295 B/W
16	po	po	po	.078	.083	.083	.091
17	po	po	BW	.083	.084	.081	B/W .295
18	po	po	.081	.080	.109	po	.295 BW
19	po	po	po	.076	.034	.026	.115
20	po	po	po	.030	.034	po	.295 BW
21	po	po	po	po	.059	.092	.295 BW
22	po	po	po	po	po	po	.295 BW
23	po	po	po	.030	.038	po	.195 BW
24	.111	.108	po	.025	.024	po	.295 BW
25	po	po	po	.023	.023	po	.051
26	po	po	po	.027	.025	po	.210 BW
27	po	po	po	.024	.024	po	.035
28	po	po	po	.028	.025	po	.244 BW
29	po	po	po	.024	.024	.024	.053
30	po	po	BW	po	po	po	.260 BW
31	po	po	po	.024	.049	po	.295

.259

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <u>Yes</u> / No	CT's met everyday? (see back) <u>Yes</u> / No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <u>Yes</u> / No	
All the 4-hour turbidity readings ≤ 1 NTU? <u>Yes</u> / No			
All turbidity readings < IFE ² triggers? <u>Yes</u> / No ²			
Notes:		PRINTED NAME: Kevin Adolphson	
		SIGNATURE: Kevin Adolphson	DATE: 02 FEB 22
		PHONE #: (503) 755-0218	CERT #: RE-0104 T-08704-II D-08703-I

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Indivd. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program – Surface Water Quality Data Form

FISHHAWK LAKE REC CLUB INC ID #: OR4100124 WTP-: WTP-A Month/Year: JAN/2022

Required Log Inactivation: 1.0

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1/24:00	.98	62.0	60.7	5.0	7.1	52	y	55
2/10:00	.93	62.0	57.6	4.6	7.1	57	y	
3/20:00	1.02		63.2	5.2	7.2	54	y	
4/09:00	.90		55.8	5.4	7.2	54	y	
5/13:00	.98		60.7	6.0	7.2	51	y	
6/01:30	1.15		71.3	6.9	7.2	51	y	
7/	PO			6.4	7.2	51	PO	
8/	PO			7.0	7.2	48	PO	
9/11:00	.90		55.8	6.7	7.2	51	y	
10/09:50	1.20		74.4	6.6	7.2	52	y	
11/10:35	1.09		67.5	6.6	7.2	52	y	
12/14:20	1.17		72.5	7.0	7.2	49	y	
13/14:30	1.13		70.0	7.7	7.2	49	y	
14/15:00	1.19		73.7	7.9	7.2	49	y	
15/11:00	1.10	62	68.2	7.8	7.2	49	y	55
16/09:00	1.12		69.4	7.7	7.2	49	y	
17/09:00	1.14		70.6	7.3	7.2	49	y	
18/09:15	1.11		68.8	7.1	7.3	50	y	
19/23:30	1.06		65.7	7.6	7.3	50	y	
20/14:00	0.95		58.9	7.6	7.4	52	y	
21/09:20	0.92		57.0	8.0	7.4	49	y	
22/09:20	1.03		63.8	8.0	7.4	49	y	
23/10:00	0.88		54.5	8.0	7.3	49	y	
24/9:05	1.17		72.5	6.0	7.4	55	y	
25/9:45	1.11		68.8	5.9	7.3	56	y	
26/9:15	1.04		64.4	5.6	7.5	60	y	
27/9:25	1.02		63.2	5.2	7.5	60	y	
28/9:15	1.09	62	67.5	5.0	7.4	58	y	
29/9:10	1.17		72.5	4.8	7.5	65	y	
30/	PO			4.4	7.4	63	PO	
31/10:28	1.01		62.6	5.0	7.5	60	y	55

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Download form at: www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-conv-direct.pdf