

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County:
Conventional or Direct Filtration**

System Name: Fishhawk Lake Reserve and Community **ID #:** 41-00124 **WTP-:** A **Month/Year:** FEB / 2022

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	po	po	po	.026	.025	.026	.295 BW
2	.041	.208	.230	.047	.025	po	.295 BW
3	po	po	BW (.026)	.028	.025	.024	.209 BW
4	.024	.024	po	.027	.025	po	.198 BW
5	po	po	po	.025	.024	.024	.046
6	po	po	po	.033	.042	.053	.205 BW
7	po	po	po	.159	.050	.023	.218 BW
8	po	po	BW	.027	.025	.024	.172 BW
9	po	po	po	.027	.025	.024	.215 BW
10	po	po	po	.027	.025	.024	.215 BW
11	po	po	po	.027	.025	po	.223
12	po	po	po	.024	.024	.024	.1033
13	po	po	po	.027	.025	.025	B/W .219
14	.024	.025	B/W	.028	.025	.026	B/W .295
15	.026	.026	.027	.071	.029	.028	.295 BW
16	.028	.028	.027	BW	.027	.027	.295 BW
17	po	po	po	.026	.032	.027	.295 BW
18	po	po	.041	.026	.030	.027	.295 BW
19	.027	po	.041	po	po	po	.062
20	po	po	po	.028	.029	.041	.295
21	po	po	po	.028	.026	.026	.295 BW
22	.025	po	.027	po	.028	.033	.295 BW
23	po	po	po	.117	.083	.028	.261 BW
24	.047	po	po	.056	BW	.025	.295 BW
25	po	po	po	.024	.024	.024	.038
26	po	po	po	.027	.025	.025	.239 BW
27	po	po	po	.025	.025	.040	.295 BW
28	.036	po	po	po	po	po	.036
29							
30							
31							

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE ² triggers? <input checked="" type="radio"/> Yes / <input type="radio"/> No ²		
Notes:	PRINTED NAME: Kevin Adolphson	
	SIGNATURE: <i>Kevin Adolphson</i>	DATE: 01 MAR 22
	PHONE #: (503) 755-0218	CERT #: FE-0104 T-09784 T D-09783 D

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

FISHHAWK LAKE REC CLUB INC ID #: OR4100124 WTP-: WTP-A Month/Year: FEB/2022

Required Log Inactivation: 1.0

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1/13:30	1.19	62	73.7	5.7	7.4	59	YES	55
2/15:30	1.05		65.1	5.8	7.4	59	Y	
3/09:00	1.02		63.2	6.0	7.4	55	Y	
4/10:15	1.05		65.1	6.8	7.4	55	Y	
5/9:10	1.04		64.4	7.0	7.4	52	Y	
6/9:05	1.01		62.6	6.9	7.4	55	Y	
7/9:15	1.04		64.4	6.4	7.4	55	Y	
8/9:00	1.07	62	66.3	6.0	7.4	55	Y	55
9/9:10	1.12		68.2	6.4	7.4	55	Y	
10/10:00	1.08		66.9	7.0	7.4	53	Y	
11/10:00	1.04		64.4	7.8	7.3	50	Y	
12/09:30	1.04		64.4	7.8	7.3	50	Y	
13/10:00	1.03		63.8	7.6	7.3	50	Y	
14/11:00	1.0 S		66.9	6.4	7.3	53	Y	
15/11:30	1.10		68.2	7.4	7.3	50	Y	
16/12:45	1.06		65.7	6.9	7.4	55	Y	
17/10:00	1.00		62.0	7.1	7.4	52	Y	
18/8:47	1.02	62	63.2	7.5	7.5	54	Y	55
19/8:42	1.07		66.3	7.7	7.5	54	Y	
20/9:10	0.96		59.5	7.7	7.5	54	Y	
21/15:35	1.02		63.2	7.0	7.5	54	Y	
22/15:40	0.92		57.0	6.0	7.4	55	Y	
23/11:20	0.95		58.9	5.6	7.4	58	Y	
24/10:00	1.06		65.7	4.0	7.4	63	Y	
25/10:40	1.21		75.0	3.7	7.4	68	Y	
26/9:05	1.21		75.0	3.6	7.5	72	Y	
27/12:00	1.19		73.7	3.8	7.5	72	Y	
28/08:30	1.19	62	73.7	4.9	7.4	64	Y	55
29/								
30/								
31/								

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.