

OHA - Drinking Water Program – Turbidity Monitoring Report Form County:

Conventional or Direct Filtration

System Name: Fishhawk Lake Reserve and Community	ID #: 41-00124	WTP-: A	Month/Year: MAR/2022
---------------------------------------------------------	-----------------------	----------------	-----------------------------

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	PO	PO	PO	PO	.044	PO	.078
2	PO	PO	.050	.038	.027	PO	B/W .268
3	PO	PO	PO	.049	BW	.025	.295 BW
4	.025	.025	.025	.025	.028	.028	.215 BW
5	.027	.026	.025	.025	.027	.029	.217 BW
6	.027	.026	.027	.047	.027	.026	.201 BW
7	.026	.027	.026	.030	.027	.027	.198 B/W
8	PO	PO	PO	.025	.025	.025	.038
9	PO	PO	PO	.030	.027	.026	.258 BW
10	PO	PO	PO	.026	.026	PO	.031
11	PO	PO	B/W .295	.028	.026	.026	.245 B/W
12	PO	PO	.032	.026	.026	.026	.032
13	PO	PO	.029	.026	.028	PO	.058
14	PO	PO	B/W	.106	.043	.029	.295 B/W
15	PO	PO	PO	.026	.026	.027	.035
16	PO	PO	.029	.028	.033	.046	.196 BW M
17	PO	PO	PO	.097	.027	PO	.113
18	PO	PO	PO	.048	.031	.028	.178 BW
19	.027	.028	.066	.028	.030	.028	.149 BW
20	PO	PO	PO	.028	.028	.028	.039
21	PO	PO	PO	.028	.028	.029	.227 BW
22	.041	.034	.035	.033	.032	.031	.041
23	PO	PO	PO	.030	.029	PO	.054
24	PO	PO	PO	.035	.040	.045	.295 BW
25	.053	PO	PO	.141	.157	PO	.199 B/W
26	PO	PO	PO	.096	.130	PO	.133 B/W
27	PO	PO	PO	.077	.095	PO	.295 BW
28	PO	PO	PO	.149	.030	.030	.149
29	.031	.031	PO	.031	.042	.032	.042
30	PO	PO	PO	PO	.035	.034	.211 BW
31	PO	PO	PO	PO	.035	.034	.045

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? Yes / No	CT's met everyday? Yes / No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? Yes / No
All the 4-hour turbidity readings ≤ 1 NTU? Yes / No	(see back) Yes / No	
All turbidity readings < IFE ² triggers? Yes / No		
Notes:	PRINTED NAME: Kevin Adolphson	
	SIGNATURE: Kevin Adolphson	DATE: 01 APR 22
	PHONE #: (503) 755-0218	CERT #: FE-0104 T-08784-II D-08783-I

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program – Surface Water Quality Data Form

FISHHAWK LAKE REC CLUB INC ID #: OR4100124 WTP-: WTP-A Month/Year: MAR/2022

Required Log Inactivation: 1.0

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow		
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]		
1 16:33	1.19	62	73.7	5.5	7.4	59	YES	55		
2 11:00	1.09	}	64.4	6.6	7.4	55	Y	}		
3 9:02	0.99		61.3	7.3	7.2	48	Y			
4 23:55	1.18		73.1	7.9	7.2	49	Y			
5 08:00	1.16		71.9	7.6	7.2	49	Y			
6 14:00	1.19		73.7	7.2	7.2	49	Y			
7 10:20	1.13		70.0	7.4	7.2	49	Y			
8 9:20	1.19		73.7	7.0	7.3	51	Y			
9 9:07	1.10		68.2	6.8	7.3	54	Y			
10 10:00	1.10		62	68.2	7.3	7.4	53		Y	55
11 08:00	1.07		}	66.3	7.0	7.2	48		Y	}
12 09:00	1.08	66.9		6.2	7.3	54	Y			
13 08:32	1.22	75.6		6.4	7.3	54	Y			
14 10:12	1.16	71.9		7.6	7.3	50	Y			
15 14:15	1.16	71.9		7.4	7.3	50	Y			
16 09:02	1.03	63.8		8.1	7.3	47	Y			
17 10:10	1.08	66.9		8.0	7.4	49	Y			
18 23:10	1.19	73.7		7.7	7.4	53	Y			
19 12:55	1.09	67.5		8.3	7.4	50	Y			
20 19:20	1.08	62		66.9	8.4	7.4	50	Y	55	
21 09:05	1.11	}	68.8	8.0	7.4	50	Y	}		
22 14:55	1.15		71.3	7.7	7.4	53	Y			
23 09:05	1.07		66.3	8.1	7.3	47	Y			
24 09:00	1.08		66.9	9.0	7.4	46	Y			
25 13:00	1.10		68.2	8.6	7.3	47	Y			
26 10:00	1.02		63.2	8.9	7.3	47	Y			
27 11:05	1.01		62.6	8.9	7.3	47	Y			
28 12:50	0.97		60.1	9.4	7.3	45	Y			
29 1 PO	PO		PO	10.0	7.3	42	PO		}	
30 1 PO	PO		PO	9.8	7.4	44	PO			
31 12:15	0.91	62	56.4	9.6	7.4	44	Y	55		

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.