

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County:
Conventional or Direct Filtration**

System Name: FISHHAWK LAKE RESERVE AND COMMUNITY **ID #:** 41-00124 **WTP-:** A **Month/Year:** APR/2022

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	po	po	po	.034	.034	.034	.050
2	.034	po	po	.035	.035	po	.295 BW
3	po	po	po	.050	.036	.035	.050
4	po	po	po	po	po	po	po
5	po	po	.076	.039	.142	po	.295 BW
6	po	po	po	.025	.041	.072	.129 BW
7	.028	.042	.054	.039	.051	.057	.295 BW
8	.156	.115	.062	.039	.034	.030	.156
9	po	po	po	.057	.031	.026	.157 B/W
10	po	po	.026	.023	.023	po	.032
11	po	po	po	.024	po	po	.220
12	po	po	.036	.024	.025	.024	.193 BW
13	.024	.024	.023	.024	.025	.025	.231 BW
14	po	po	po	.023	.023	po	.034
15	po	po	po	.025	.028	.045	.131 BW
16	.059	po	po	.035	po	po	.058
17	po	po	po	.044	.054	po	.295 BW
18	.173	po	po	po	.022	.022	.036
19	po	po	po	.025	.111	.049	.231 B/W
20	po	po	.038	.027	.025	po	.082
21	po	po	po	.023	.023	.024	.058
22	po	po	po	.029	.026	.025	.295 B/W
23	po	po	.030	.024	.023	po	.037
24	po	po	.034	.023	.023	.027	.118 B/W
25	po	po	po	.024	.024	.024	.037
26	po	po	.025	.024	.025	po	.181 B/W
27	po	po	.025	.024	.024	.025	.027
28	po	po	.042	.027	.030	.028	.295 B/W
29	po	po	.027	.030	.025	.026	.038
30	.025	po	.027	.029	.024	po	.295
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <u>Yes/No</u>	CT's met everyday? (see back) <u>Yes/No</u>	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <u>Yes/No</u>	
All the 4-hour turbidity readings ≤ 1 NTU? <u>Yes/No</u>			
All turbidity readings < IFE ² triggers? <u>Yes/No²</u>			
Notes:	PRINTED NAME: Kevin Adolphson		
	SIGNATURE: Kevin Adolphson	DATE: 01 MAY 22	
	PHONE #: (503) 755-0218	CERT #: FE-0104 T-08784-II D-08783-I	

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ²IFE = Individ. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

FISHHAWK LAKE REC CLUB INC ID #: OR4100124 WTP-: WTP-A Month/Year: APR / 2022

Required Log Inactivation: 1.0

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 / 11:10	0.96	62	59.5	9.2	7.5	48	Yes	55
2 / 09:45	0.97		60.1	8.4	7.4	49	Y	
3 / 12:47	0.88		54.5	8.5	7.4	49	Y	
4 / PO	PO			8.7	7.4	49	PO	
5 / 11:15	0.89		55.1	9.0	7.1	45	Y	
6 / 09:47	1.02		63.2	8.7	7.4	49	Y	
7 / 11:00	1.02		74.4 59.5	8.3	7.4	49	Y	
8 / 12:30	.96		59.5	9.8	7.3	45	Y	
9 / 12:00	.94		58.2	9.5	7.3	45	Y	
10 / 10:40	.95	62	58.9	8.8	7.3	47	Y	55
11 / 14:00	.91		56.4	7.9	7.3	50	Y	
12 / 8:32	1.00		62.0	8.7	7.3	46	Y	
13 / 15:30	0.98		60.7	7.2	7.3	50	Y	
14 / 09:10	1.00		62.0	6.4	7.3	53	Y	
15 / 09:50	0.98		60.7	6.6	7.3	53	Y	
16 / 11:15	1.02		63.2	6.7	7.3	53	Y	
17 / 11:55	1.06		65.7	7.0	7.5	55	Y	
18 / 16:00	.96		59.5	7.0	7.5	55	Y	
19 / 12:00	1.08		66.9	7.7	7.4	52	Y	
20 / 9:45	1.02	62	63.2	7.8	7.4	52	Y	55
21 / 9:30	1.06		68.7	8.4	7.4	49	Y	
22 / 12:30	1.06		65.7	8.2	7.4	49	Y	
23 / 10:00	1.02		63.2	8.8	7.4	49	Y	
24 / 09:00	1.04		64.4	9.4	7.5	48	Y	
25 / 10:00	1.02		63.2	9.2	7.3	45	Y	
26 / 13:00	.98		60.7	10.0	7.3	42	Y	
27 / 08:00	1.00		62.0	9.4	7.3	45	Y	
28 / 10:00	.98		60.7	9.0	7.3	45	Y	
29 / 07:47	1.02		63.2	9.7	7.3	45	Y	
30 / 09:00	1.04	62	64.4	9.0	7.3	45	Y	55
31 /								

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.