

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County:
Conventional or Direct Filtration**

System Name: Fishhawk Lake Reserve and Community **ID #:** 91-00124 **WTP-:** A **Month/Year:** JUL/2022

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	PO	PO	PO	.044	.044	.044	.048
2	.044	.045	.047	.046	.045	.045	B/W .064
3	.046	.046	B/W	.047	.047	.047	.060
4	PO	PO	PO	.047	.047	.047	.083
5	PO	PO	B/W	.049	.048	PO	.094
6	PO	PO	PO	.049	.050	.050	.051
7	PO	PO	.072	.056	.059	PO	.123 PO B/W
8	PO	PO	.084	.068	.058	.054	.104
9	PO	PO	.083	.056	.054	.056	BW .295
10	.059	.063	.131	.053	.052	PO	.131
11	PO	PO	PO	.052	.054	.053	.084 BW
12	.053	.053	.053	.053	.055	.055	.083 BW
13	PO	PO	.096	.055	.055	.054	.096
14	PO	PO	PO	.054	.053	PO	.081
15	PO	PO	B/W	.057	.054	.053	.136 B/W
16	.052	.052	.052	.052	.053	PO	.052
17	PO	PO	.061	.059	.054	.053	.088 B/W
18	.052	.051	.051	.051	PO	PO	.052
19	PO	PO	PO	PO	PO	PO	P.O.
20	PO	PO	.059	.059	.057	.056	.118 BW
21	.056	.056	.057	.060	.061	.059	.101 BW
22	.058	PO	PO	.058	.055	.055	.095
23	PO	PO	BW	.060	.056	PO	.203 BW
24	PO	PO	PO	.054	.053	.052	.062
25	PO	PO	PO	.053	.057	.054	.109 BW
26	.053	.054	.054	.054	.080	.058	.080 B/W
27	.057	PO	.061	.059	.058	PO	.040
28	PO	PO	.108	.065	PO	PO	.181 B/W
29	.079	.061	.063	.064	.064	PO	.079
30	PO	PO	.132	.075	.072	.072	.197 B/W
31	PO	PO	.076	.065	.066	.067	.120 BW

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? Yes / No	CT's met everyday? (see back) Yes / No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? Yes / No	
All the 4-hour turbidity readings ≤ 1 NTU? Yes / No			
All turbidity readings < IFE ² triggers? Yes / No²			
Notes:		PRINTED NAME: Kevin Adolphson	
		SIGNATURE: Kevin Adolphson	DATE: 05 AUG 22
		PHONE #: (503) 755-0218	CERT #: FE-0104 T-02204 II D-02283 I

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Individ. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

FISHHAWK LAKE REC CLUB INC ID #: OR4100124 WTP-: WTP-A Month/Year: JUL/2022

Required Log
Inactivation: *i.d*

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
11/11:52	0.85	62	52.7	14.0	7.3	30	y	55
2/23:00	.88		54.5	14.4	7.3	31	y	
3/16:00	.84		52.0	13.7	7.3	33	y	
4/10:00	.70		43.4	13.4	7.3	33	y	
5/8:52	0.69		42.7	13.4	7.3	33	y	
6/09:45	0.68		42.1	13.7	7.3	33	y	
7/09:00	0.68		42.1	14.2	7.3	30	y	
8/09:05	0.50		31.0	14.3	7.3	30	y	
9/09:00	0.65		40.3	14.7	7.3	30	y	
10/09:59	0.70	62	43.4	14.6	7.4	31	y	55
11/09:30	0.74		45.8	14.4	7.3	30	y	
12/16:10	0.78		48.3	16.7	7.3	27	y	
13/09:15	0.78		48.3	16.4	7.3	27	y	
14/09:00	0.67		41.5	16.1	7.3	27	y	
15/19:45	0.64		39.6	15.6	7.3	27	y	
16/08:30	0.80		49.6	16.1	7.3	27	y	
17/07:30	0.72		44.6	15.8	7.3	27	y	
18/10:00	0.88		54.5	14.6	7.2	29	y	
19/PO	PO		PO	14.2	7.2	PO	PO	
20/8:00	0.62	.62	38.4	14.5	7.3	30.	y	55
21/13:05	0.65		40.3	17.4	7.3	27	y	
22/09:10	0.58		35.9	17.0	7.3	27	y	
23/09:00	0.59		36.5	16.4	7.3	27	y	
24/09:30	0.62		38.4	15.7	7.4	28	y	
25/09:15	0.62		38.4	16.0	7.3	27	y	
26/18:00	0.63		39.0	18.0	7.3	27	y	
27/09:00	0.62		38.4	18.9	7.3	27	y	
28/09:00	0.52		32.2	18.4	7.3	27	y	
29/15:00	0.84		52.8	19.0	7.3	27	y	
30/08:00	0.54		33.4	18.7	7.3	27	y	
31/08:50	0.52	62	32.2	19.6	7.3	27	y	55

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.