

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County:
Conventional or Direct Filtration**

System Name: Fishhawk Lake Reserve and Community **ID #:** 41-20124 **WTP-:** A **Month/Year:** AUG/2022

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	.081	.068	.063	.064	.065	.065	.081
2	po	po	.064	.079	.074	.069	.167 BW
3	.062	po	po	.052	.051	.048	.131
4	po	po	po	.059	.053	po	.112 BW
5	po	po	.062	.046	.044	.043	.093
6	.041	po	po	.047	.042	.041	.078 BW
7	po	po	po	.041	.039	.040	.090
8	po	po	B/W	.048	.046	.046	.138 B/W
9	po	po	po	.046	.045	po	.089
10	po	po	po	.045	.046	.055	.117 BW
11	po	po	.061	.048	po	.044	.061
12	po .041	po	po	.041	.040	.050	.073 B/W
13	po	po	.087	.044	.042	po	.087
14	po	po	.089	.040	.038	.037	.092
15	po	po	po	.038	.045	.042	.133 B/W
16	.042	po	po	.044	.040	po	.048
17	po	po	.039	.040	.037	.038	.039
18	po	po	B/W	.050	.049	po	.164 BW
19	po	po	.105	.054	.055	.061	.129
20	po	po	.102	.093	.084	po	.198 BW
21	po	po	po	.069	.063	.061	.084
22	po	po	po	.056	.052	po	.058
23	po	po	po	.076	.066	.064	.262 B/W
24	po	po	.077	.056	.054	.055	.077
25	po	po	po	.051	.050	.052	.056
26	po	po	B/W	.077	.075	.079	.227 B/W
27	po	po	.083	.066	.062	po	.083
28	po	po	.075	.106	.086	.074	.295 B/W
29	po	po	.109	.061	.056	.058	.109
30	po	po	.097	.048	.074	.067	.178 B/W
31	po	po	.066	.058	.058	.066	.069

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No			
All turbidity readings < IFE ² triggers? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No			
Notes:	PRINTED NAME: Kevin Adolphson		
	SIGNATURE: Kevin Adolphson	DATE: 01 SEP 22	
	PHONE #: (503) 755-0218	CERT #: FE-0104 D-08784-II D-08783-I	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Individ. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

FISHHAWK LAKE REC CLUB INC ID #: OR4100124 WTP-: WTP-A Month/Year: AUG/2022

Required Log Inactivation: 1.0

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1/23:50	0.67	62	41.5	19.6	7.3	27	YES	55
2/08:30	0.55		34.1	18.8	7.3	27	Y	
3/10:00	0.51		31.6	18.7	7.3	27	Y	
4/10:00	0.54		33.4	18.0	7.4	28	Y	
5/08:35	0.60		37.2	17.4	7.3	27	Y	
6/09:30	0.79		48.9	16.5	7.4	28	Y	
7/10:50	0.74		45.8	16.5	7.3	27	Y	
8/09:35	0.70		43.4	17.1	7.3	27	Y	
9/09:20	0.67		41.5	17.5	7.3	27	Y	
10/09:15	0.62	62	38.4	17.4	7.3	27	Y	55
11/08:30	0.66		40.9	17.2	7.3	27	Y	
12/09:41	0.70		43.4	17.0	7.4	28	Y	
13/09:00	0.70		43.4	16.7	7.3	27	Y	
14/08:52	0.67		41.5	16.0	7.3	27	Y	
15/09:10	0.73		45.2	15.6	7.3	27	Y	
16/12:00	0.70		43.4	16.6	7.3	27	Y	
17/09:00	0.64		39.6	17.0	7.3	27	Y	
18/09:00	0.64		39.6	17.6	7.3	27	Y	
19/08:57	0.51		31.6	18.4	7.3	27	Y	
20/08:45	0.46	62	28.5	19.0	7.3	27	Y	55
21/09:13	0.59		36.5	18.7	7.4	28	Y	
22/10:30	0.62		38.4	18.4	7.3	27	Y	
23/10:15	0.82		50.8	18.3	7.3	27	Y	
24/09:00	0.64		39.6	18.0	7.3	27	Y	
25/09:45	0.62		38.4	18.2	7.3	27	Y	
26/09:00	0.88		54.5	18.7	7.3	27	Y	
27/08:45	0.52		32.2	18.4	7.4	28	Y	
28/09:15	0.58		35.9	17.6	7.4	28	Y	
29/08:55	0.57		35.3	17.0	7.4	28	Y	
30/09:00	0.57		35.3	16.7	7.3	27	Y	
31/08:00	0.64	62	39.6	17.5	7.3	27	Y	55

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.