

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County:
Conventional or Direct Filtration**

System Name: Fishhawk Lake Reserve and Community **ID #:** 41-00124 **WTP-:** A **Month/Year:** SEP/2022

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	po	po	po	.060	.099	.086	.207 ^{B/W}
2	po	po	.134	.072	.072	.078	.134
3	po	po	.164	.094	.087	.084	.269 BW
4	po	po	.085	.072	.070	.067	.085
5	po	po	po	po	.079	.060	.136 BW
6	.077	.067	.062	.059	po	po	.077
7	po	po	po	.050	.048	.049	.129
8	.048	po	BW	.069	.063	.058	.231 BW
9	po	po	.087	.050	.046	.045	.087
10	po	po	.080	.060	.059	.058	.185 ^{B/W}
11	po	po	.079	.054	.051	po	.080
12	po	po	po	.049	.126	.166	.194 BW
13	po	po	po	.047	.046	po	.131
14	po	po	po	.044	.039	.038	.050
15	po	po	po	.048	.042	.040	.132 ^{B/W}
16	po	po	po	.039	.037	po	.074
17	po	po	.049	.045	.040	po	.107 BW
18	po	po	.061	.038	po	po	.064
19	po	po	.070	.035	.033	.032	.081
20	po	po	po	.033	.039	.035	.084 ^{B/W}
21	po	po	.064	.033	.033	po	.064
22	po	po	.097	.033	.032	.033	.036
23	po	po	^{B/W}	.039	.039	po	.108 ^{B/W}
24	po	po	po	.040	.039	.038	.064
25	po	po	po	.037	.035	po	.039
26	po	po	^{B/W}	.038	.036	.036	.134 ^{B/W}
27	po	po	.041	.036	.036	.036	.062
28	po	po	po	.044	.046	.046	.100 ^{B/W}
29	po	po	po	.169	.093	po	.295
30	po	po	po	.058	.050	.056	.135
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / No			
All turbidity readings < IFE ² triggers? <input checked="" type="checkbox"/> Yes / No ²			
Notes:	PRINTED NAME: Kevin Adolphson		
	SIGNATURE: Kevin Adolphson		DATE: 10/01/22
	PHONE #: (503) 755-0218		CERT #: FE-0104 T-06784-II D-05785-I

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ²IFE = Individ. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program – Surface Water Quality Data Form

FISHHAWK LAKE REC CLUB INC ID #: OR4100124 WTP-: WTP-A Month/Year: SEP/2022

Required Log Inactivation: 1.0

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
11/10:00	0.55	62	34.1	17.7	7.3	27	YES	55
21/08:55	0.49		30.3	17.7	7.3	27	Y	
31/08:58	0.50		31.0	17.6	7.3	27	Y	
41/08:42	0.56		34.7	17.2	7.3	27	Y	
51/16:30	0.76		47.1	16.9	7.3	27	Y	
61/08:30	0.78		48.3	15.7	7.3	27	Y	
71/09:15	0.60		37.2	15.0	7.3	27	Y	
81/09:08	0.80		49.6	15.6	7.4	28	Y	
91/09:00	0.65		40.3	14.8	7.3	30	Y	
10/09:00	0.70	62	43.4	14.6	7.3	30	Y	55
111/08:22	0.66		40.9	14.7	7.3	30	Y	
121/09:10	0.69		42.7	14.3	7.3	30	Y	
131/10:32	0.47		29.1	15.0	7.3	27	Y	
141/09:24	0.70		43.4	15.4	7.4	28	Y	
151/10:54	0.79		48.9	15.5	7.5	28	Y	
161/09:10	0.69		42.7	15.6	7.4	28	Y	
171/08:35	0.70		43.4	15.0	7.5	29	Y	
181/09:00	0.64		39.6	14.0	7.4	31	Y	
191/09:00	0.65		40.3	13.9	7.4	34	Y	
201/09:45	0.66	62	40.9	13.6	7.4	34	Y	55
211/09:30	0.58		35.9	13.8	7.4	33	Y	
221/09:15	0.64		39.6	13.6	7.4	34	Y	
231/10:00	0.68		42.1	13.8	7.4	34	Y	
241/10:13	0.54		34.4	14.0	7.4	31	Y	
251/09:00	0.82		50.8	14.0	7.4	31	Y	
261/09:00	0.72		44.6	13.6	7.5	35	Y	
271/09:00	0.68		42.1	13.7	7.5	35	Y	
281/10:00	0.64		39.6	14.0	7.4	31	Y	
291/14:00	0.56		34.7	14.0	7.4	31	Y	
301/13:00	0.54	62	33.4	14.2	7.4	31	Y	55
31/								

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.