

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County:
Conventional or Direct Filtration**

System Name: Fishhawk Lake Reserve and Community **ID #:** 41-00124 **WTP-:** A **Month/Year:** OCT/2022

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	po	po	po	.042	.041	po	.097
2	po	po	po	.035	.031	.030	.092
3	.030	.030	.030	.030	po	po	.054 BW
4	po	po	.054	.030	.030	.030	.054
5	po	po	.046	.031	po	po	.046
6	po	po	po	.031	.031	.031	.057 BW
7	po	po	.036 ⁰³⁶	.031	.031	.031	.036
8	po	po	po	.031	.031	.031	.034
9	po	po	po	.031	.031	.031	.042
10	po	po	B/W	.032	.032	po	.047 ^{3/4}
11	po	po	po	.063	.032	.032	.063
12	po	po	.047	.035	.033	po	.047 BW
13	po	po	po	.029	.028	po	.085
14	po	po	po	.028	.031	.028	.036 BW
15	po	po	.030	.028	.028	po	.038
16	po	po	po	po	.029	.030	.043 BW
17	.029	po	.039	.029	.030	po	.039
18	po	po	po	.030	.030	po	.078 BW
19	po	po	po	.030	.030	po	.036
20	po	po	po	.030	.030	po	.042
21	po	po	.046	.031	po	po	.046 ^{3/4}
22	po	po	po	.033	.071	po	.295
23	po	po	.220	.146	po	po	.295 ^{3/4}
24	po	po	po	.076	po	po	.077
25	po	po	po	po	.136	po	.164
26	po	po	po	.047	po	po	.295 ^{3/4}
27	po	po	po	po	.215	.040	.295 BW
28	.040	.036	.035	.034	.033	.033	.069 BW
29	.033	po	po	.033	po	po	.071 BW
30	po	po	po	.033	.033	po	.035
31	po	po	po	po	po	po	P.O.

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? Yes / No	Yes / No	CT's met everyday? (see back) Yes / No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? Yes / No
All the 4-hour turbidity readings ≤ 1 NTU? Yes / No	Yes / No		
All turbidity readings < IFE ² triggers? Yes / No	Yes / No		
Notes:		PRINTED NAME: Kevin Adelphson	
		SIGNATURE: Kevin Adelphson	DATE: 02 Nov 22
		PHONE #: (503) 755-0218	CERT #: FE-0104 T-08784-II D-08783-I

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Indivd. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program – Surface Water Quality Data Form

FISHHAWK LAKE REC CLUB INC ID #: OR4100124 WTP-: WTP-A Month/Year: OCT/2022

Required Log Inactivation: 1.0

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1/10:00	0.56	62	34.7	14.0	7.4	31	Y	55
2/10:20	0.62		48.3	14.8	7.4	31	Y	
3/08:02	0.80		49.6	14.6	7.4	31	Y	
4/09:00	0.84		52.0	14.0	7.4	31	Y	
5/10:30	0.72		44.6	14.2	7.4	31	Y	
6/09:53	0.69		42.7	14.5	7.3	31	Y	
7/09:45	0.70		43.4	14.3	7.4	31	Y	
8/09:00	0.72		44.6	14.0	7.4	28	Y	
9/10:30	0.71		44.0	13.8	7.5	35	Y	
10/9:24	0.81	62	50.2	13.6	7.4	34	Y	55
11/13:04	0.68		42.1	13.3	7.3	34	Y	
12/11:41	0.72		44.6	13.2	7.3	34	Y	
13/9:50	0.76		47.1	12.6	7.3	36	Y	
14/9:05	0.84		52.0	12.0	7.4	38	Y	
15/8:38	0.71		44.0	11.4	7.3	39	Y	
16/15:32	0.66		40.9	11.5	7.3	39	Y	
17/13:18	0.73		45.2	11.7	7.4	40	Y	
18/9:45	0.63		39.0	11.7	7.3	39	Y	
19/09:45	0.72		44.6	11.6	7.3	39	Y	
20/9:15	0.78	62	48.3	11.3	7.4	40	Y	62
21/9:29	0.88		54.5	11.2	7.4	40	Y	
22/18:00	0.70		43.4	11.2	7.5	41	Y	
23/10:57	0.86		53.3	10.5	7.4	42	Y	
24/11:05	0.77		47.7	10.1	7.3	40	Y	
25/11:11	0.67		41.5	10.2	7.2	40	Y	
26/10:40	0.68		42.1	10.7	7.3	39	Y	
27/14:43	0.70		43.4	11.4	7.5	39	Y	
28/20:07	0.86		53.3	9.6	7.3	45	Y	
29/09:40	0.91		56.4	9.9	7.3	45	Y	
30/09:15	0.82		50.8	10.2	7.2	41	Y	
31/PO	PO	62	PO	10.0	7.3	39	PO	55

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.