

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County:
Conventional or Direct Filtration**

System Name: Fishhawk Lake Resource and Community **ID #:** 41-00124 **WTP-:** A **Month/Year:** JAN/2023

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	PO	PO	PO	.044	.043	PO	.056
2	PO	PO	PO	.043	.043	.043	.054
3	PO	PO	PO	.055	.046	PO	.180 BW
4	PO	PO	PO	.044	.044	PO	.053
5	PO	PO	PO	.043	.043	.043	.051
6	PO	PO	PO	.042	.067	PO	.244 BW
7	PO	PO	PO	.046	.050	.074	.086
8	PO	PO	PO	.069	PO	PO	.102
9	PO	PO	.067	.053	.070	.061	.070
10	PO	PO	.067	.068	.058	.049	.295 BW
11	.047	.045	.045	PO	.023	.023	.047
12	.023	PO	.023	.052	.052	.273	.295
13	PO	PO	PO	.026	.025	.050	.295
14	PO	PO	.042	.105	.175	.180	.180
15	PO	PO	.086	.023	PO	PO	.295 BW
16	PO	PO	.033	.028	.029	.026	.033
17	PO	PO	.023	.023	PO	PO	.035
18	PO	PO	.034	.023	PO	PO	.024
19	PO	PO	PO	.037	.031	.025	.339 B/W
20	.023	.023	.023	PO	.022	PO	.023
21	PO	PO	PO	.023	.023	PO	.036
22	PO	PO	PO	.027	.024	PO	.254 B/W
23	PO	PO	PO	.023	.023	PO	.035
24	PO	PO	PO	.071	.024	PO	.071
25	PO	PO	PO	.024	.024	.024	.028
26	PO	PO	PO	.133%	.028	PO	.115 B/W
27	PO	PO	PO	.025	.024	.025	.030
28	PO	PO	PO	.025	.026	PO	.029
29	PO	PO	.028	.025	PO	PO	.034
30	PO	PO	PO	.025	.025	.025	.035
31	PO	PO	PO	.035	.033	PO	.163

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? Yes/No	Yes/No	CT's met everyday? (see back) Yes/No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? Yes/No
All the 4-hour turbidity readings ≤ 1 NTU? Yes/No	Yes/No		
All turbidity readings < IFE ² triggers? Yes/No	Yes/No		
Notes:		PRINTED NAME: Kevin Adolphson	
		SIGNATURE: Kevin Adolphson	DATE: 02 FEB 23
		PHONE #: (503) 755-0218	CERT #: FE-0104 T-02704-II D-02703-I

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ²IFE = Individ. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program – Surface Water Quality Data Form

FISHHAWK LAKE REC CLUB INC ID #: OR4100124 WTP:- WTP-A Month/Year:

Required Log
Inactivation:

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1/10:15	1.18	62	73.1	8.5	7.2	47	Y	55
2/10:30	1.43		88.6	8.0	7.2	47	Y	
3/10:55	1.15		76.3	7.1	7.2	50	Y	
4/10:30	1.00		62.0	7.0	7.2	48	Y	
5/12:40	1.03		63.8	7.0	7.2	48	Y	
6/9:10	1.00		62.0	7.2	7.2	48	Y	
7/11:00	0.98		60.7	7.7	7.2	48	Y	
8/10:15	0.89		55.1	8.0	7.2	46	Y	
9/9:00	0.84		52.0	8.1	7.2	46	Y	
10/9:00	0.91	62	56.4	7.7	7.2	48	Y	55
11/12:30	1.02		63.2	7.6	7.2	48	Y	
12/9:00	1.02		63.2	8.0	7.2	46	Y	
13/12:45	.84		52.0	8.4	7.1	45	Y	
14/10:30	.86		53.3	9.0	7.1	41	yes	
15/10:40	.88		54.5	9.0	7.2	42		
16/9:00	.87		53.9	9.0	7.3	44	yes	
17/9:05	1.06		65.7	8.2	7.2	46	Y	
18/10:00	1.00		62.0	8.4	7.3	47	Y	
19/10:50	0.92		57.0	9.2	7.2	43	yes	
20/14:55	1.00	.62	62.0	7.7	7.4	52	Y	55
21/08:20	0.88		54.5	7.4	7.3	50	Y	
22/9:50	0.96		59.5	7.4	7.4	51	Y	
23/9:50	0.91		56.4	8.4	7.4	42 55	Y	
24/13:30	0.90		55.8	7.7	7.4	51	Y	
25/9:00	0.92		57.0	7.5	7.3	50	Y	
26/9:00	1.00		58 62	7.4	7.3	50	Y	
27/11:00	.94		58.2	7.4	7.4	52	Y	
28/09:00	.91		56.4	8.3	7.5	53	Y	
29/9:00	.98		60.7	7.9	7.5	54	Y	
30/8:50	1.02		63.2	8.0	7.4	49 49	Y	
31/19:20	1.23	62	76.2	6.9	7.5	57	Y	55

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.