

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Conventional or Direct Filtration**

**System Name:** Fishhawk Lake Reserve and Community **ID #:** 41-00124 **WTP-:** A **Month/Year:** FEB/2023

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	PO	PO	PO	.030	.031	.030	.035
2	PO	PO	PO	.027	.028	PO	.028
3	PO	PO	.043	<del>B/W</del>	.037	PO	.160
4	PO	PO	.027	.026	PO	PO	.040
5	PO	PO	PO	.029	PO	PO	.049
6	PO	PO	.033	.034	.059	.096	.099
7	PO	PO	.130	.110	.028	PO	.295 B/W
8	PO	PO	PO	.028	.029	PO	.038
9	PO	PO	.038	.028	.030	PO	.038
10	PO	PO	PO	.035	PO	PO	.038
11	PO	PO	.038	.116	.167	PO	.217 B/W
12	PO	PO	.203	.029	.029	PO	.295 B/W
13	PO	PO	.037	.029	.029	PO	.037
14	PO	PO	PO	.031	.038	.034	.295 B/W
15	PO	PO	.043	.032	.031	.031	.046
16	.031	PO	.038	.032	.039	.035	.036
17	PO	PO	PO	.079	.044	PO	.229 B/W
18	PO	PO	PO	.034	PO	PO	.041
19	PO	PO	.037	.032	PO	PO	.051
20	PO	PO	.042	.033	.033	.033	.042
21	.033	.033	.033	.035	.035	PO	.227 B/W
22	PO	PO	PO	.037	.037	.036	.044
23	PO	PO	PO	.035	.035	PO	.050
24	PO	PO	PO	.035	.075	.101	.266 B/W
25	PO	PO	.052	.126	.167	PO	.167
26	PO	PO	PO	.107	PO	PO	.132
27	PO	PO	.064	.120	.039	.044	.120
28	PO	PO	.050	.054	.199	PO	.264 B/W
29							
30							
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl <sub>2</sub> residuals at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No			
All turbidity readings < IFE <sup>2</sup> triggers? <input checked="" type="radio"/> Yes / <input type="radio"/> No			
Notes:		PRINTED NAME: Kevin Adolphson	
		SIGNATURE: Kevin Adolphson	DATE: 06 MAR 23
		PHONE #: (503) 755-0218	CERT #: FE-0104 - 00104-II 02783-III

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Indivd. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

## OHA - Drinking Water Program - Surface Water Quality Data Form

FISHHAWK LAKE REC CLUB INC ID #: OR4100124 WTP-: WTP-A Month/Year: FEB/2023

Required Log Inactivation: 1.0

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1/19:00	1.12	62	69.4	4.0	7.5	65	Y	55
2/19:00	1.02		63.2	4.1	7.4	63 <sup>63</sup>	Y	
3/10:00	1.14		70.6	4.1	7.4	63	Y	
4/10:00	1.14		70.6	4.4	7.5	65	Y	
5/19:45	1.07		66.3	5.0	7.5	60	Y	
6/18:10	1.07		66.3	5.9	7.4	58	Y	
7/10:00	1.10		68.2	6.5	7.6	59	Y	
8/10:45	1.12		69.4	7.0	7.5	54	Y	
9/18:15	1.09		67.5	7.0	7.4	52	Y	
10/19:24	1.14		70.6	7.0	7.5	54	Y	
11/09:30	1.26		78.1	7.5	7.4	53	Y	
12/11:00	1.15		71.3	6.8	7.4	56	Y	
13/10:00	1.18		73.1	6.4	7.5	57	Y	
14/10:15	1.20	62	74.4	6.6	7.5	57	Y	55
15/10:00	1.17		72.5	5.8	7.5	61	Y	
16/10:00	1.18		73.1	5.0	7.5	60	Y	
17/10:00	1.18		73.1	5.0	7.5	60	Y	
18/10:00	1.18		73.1	5.7	7.6	60	Y	
19/18:45	1.17		72.5	6.0	7.5	58	Y	
20/18:15	1.22		75.6	6.4	7.5	57	Y	
21/16:00	1.30		80.6	7.4	7.6	57	Y	
22/19:15	1.16		71.9	7.0	7.6	57	Y	
23/18:00	1.12		69.4	5.9	7.5	60	Y	
24/10:30	1.10		68.2	5.2	7.4	58	Y	
25/11:00	1.22		75.6	3.5	7.4	70	Y	
26/12:10	1.14		70.6	3.7	7.4	70	Y	
27/19:45	1.16		71.9	4.2	7.5	67	Y	
28/10:15	1.18	62	73.1	4.0	7.3	62	Y	55
29/								
30/								
31/								

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.